



# 中国国家强制性产品认证证书

证书编号: 2009010304347484

### 委托人名称、地址

上海施耐德工业控制有限公司  
中国上海市普陀区绥德路629号

### 生产者(制造商)名称、地址

SCHNEIDER ELECTRIC INDUSTRIES SAS  
35, rue Joseph Monier-92500 RUBIL MALMAISON-France

### 生产企业名称、地址

Schneider Electric a. s.  
Cizovska 447 - 39701 Pisek - Czech Republic

### 产品名称和系列、规格、型号

#### 交流接触器

LC1F1400, LC1F1700, LC1F2100;型号解释详见附录; Ui: 1000V; LC1F1400(每极2直  
接接线排): Ith: 1400 AC-1; Ue/Ie: 1000V/1400A; LC1F1700(每极3直接接线排):  
Ith: 1700 AC-1; Ue/Ie: 1000V/1700A; LC1F2100+LA9F2100转接器(每极3接线排):  
Ith: 2000 AC-1; Ue/Ie: 1000V/2000A; LC1F2100+LA9F2100转接器(每极4接线排):  
Ith: 2100 AC-1; Ue/Ie: 1000V/2100A; Us: AC110V, 120V, 220V, 230V, 240V,  
277V, 380V, 400V, 415V, 440V, 500V 50/60Hz; DC110V, 125V, 220V, 250V,  
440V; 极数: 3P

### 产品标准和技术要求

GB 14048.4-2010

上述产品符合强制性产品认证实施规则  
CNCA-C03-02: 2014的要求, 特发此证。

发证日期: 2015年05月27日      有效期至: 2016年04月26日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2009年06月08日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>



Q 1141604



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2009010304347484

## NAME AND ADDRESS OF THE APPLICANT

Schneider Shanghai Industrial Control Co., Ltd.  
629 Sui De Road, Pu Tuo District, Shanghai, P.R.C

## NAME AND ADDRESS OF THE MANUFACTURER

SCHNEIDER ELECTRIC INDUSTRIES SAS  
35, rue Joseph Monier-92500 RUEIL MALMAISON-France

## NAME AND ADDRESS OF THE FACTORY

Schneider Electric a. s.  
Cizovska 447 - 39701 Pisek - Czech Republic

## NAME, MODEL AND SPECIFICATION

AC Contactor

LC1F1400, LC1F1700, LC1F2100 Ui: 1000V; LC1F1400(2 Direct Connectorbars/Pole): Ith: 1400 AC-1: Ue/Ie: 1000V/1400A; LC1F1700(3 Direct Connectorbars/Pole): Ith: 1700 AC-1: Ue/Ie: 1000V/1700A; LC1F2100+LA9F2100 (With Commutator, 3 Connectorbars/Pole): Ith: 2000 AC-1: Ue/Ie: 1000V/2000A; LC1F2100+LA9F2100 (With Commutator, 4 Connectorbars/Pole): Ith: 2100 AC-1: Ue/Ie: 1000V/2100A; Us: AC110V, 120V, 220V, 230V, 240V, 277V, 380V, 400V, 415V, 440V, 500V 50/60Hz; DC110V, 125V, 220V, 250V, 440V; Poles: 3P

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.4-2010

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-C03-02:2014).

Date of issue: May.27, 2015      Date of expiry: Apr.26, 2016

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original certification: Jun.08, 2009

This certificate can be verified through CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



President:

Wang Kejiao



**CHINA QUALITY CERTIFICATION CENTRE**

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

Q 1141604



# 中国国家强制性产品认证证书

附录:

第 1 页 共 2 页

证书编号: 2009010304347484

纸号: 1141604

型号的解释:

LC1	F1700	E7
I	II	III

I	产品基本型号 LC1: 单只接触器
II	规格 F1400 F1700 F2100
VI	线圈规格 见下表:

线圈规格表:

线圈代码	Us(V)	频率
F7	110	50 / 60Hz
G7	120	50 / 60Hz
M7	220	50 / 60Hz
P7	230	50 / 60Hz
U7	240	50 / 60Hz
W7	277	50 / 60Hz
Q7	380	50 / 60Hz
V7	400	50 / 60Hz
N7	415	50 / 60Hz
R7	440	50 / 60Hz
S7	500	50 / 60Hz

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





# 中国国家强制性产品认证证书

附录:

第 2 页 共 2 页

证书编号: 2009010304347484

纸号: 1141604

FD	110	DC
GD	125	DC
MD	220	DC
UD	250	DC
RD	440	DC
空白	不提供线圈,由客户自行安装本表所列线圈	

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

