



Ref. Certif. No.

CN24995-M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEMESYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC**CB TEST CERTIFICATE**Product
Produit

AC contactor

Name and address of the applicant
Nom et adresse du demandeurSchneider Shanghai Industrial Control Co.,Ltd.
No.629 Suide Road, Putuo District, Shanghai, P.R.ChinaName and address of the manufacturer
Nom et adresse du fabricantSchneider Electric a. s
Cizovska 447 - 39701 Pisek - Czech RepublicName and address of the factory
Nome et adresse de l'usineSchneider Electric a. s.
Cizovska 447 - 39701 Pisek - Czech RepublicNote: When more than one factory, please report on page 2
Note: Lorsque plus d'une usine, veuillez utiliser la 2^{ème} pageRatings and principal characteristics
Valeurs nominales et caractéristiques principales

See the Appendix

Trademark (if any)
Marque de fabrique (si elle existe)

Schneider Electric

Model / Type Ref.
Ref. De type

LC1F265, LC2F265, LC1F330, LC1F400, LC1F2654, LC2F2654, LC1F3304, LC1F4004

Additional information (if necessary may also be reported on page 2)
Les informations complémentaires (si nécessaire, peuvent être indiqués sur la 2^{ème} page)

The original CB NO is CN24995, dated 2012-11-23. The modification is to change product model and dimension of contacts.

PUBLICATION

EDITION

A sample of the product was tested and found to be in conformity with
Un échantillon de ce produit a été essayé et a été considéré conforme à la

IEC 60947-4-1:2009(3rd Edition)

As shown in the Test Report Ref. No. which forms part of this Certificate
Comme indiqué dans le Rapport d'essais numéro de référence qui constitue partie de ce Certificat

C009-CB2012CQC042924-M1

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme National de Certification

CHINA QUALITY CERTIFICATION CENTRE

Date: 2014-07-30

Signature:

Wang Kejiao



Ref. Certif. No.

CN24995-M1

LC1F265,LC2F265,LC1F330,LC1F400,LC1F2654,LC2F2654,LC1F3304,LC1F4004;Ui: 1000V

LC1F265,LC2F265:

Ith:350A;

AC-3:Ue/Ie:AC230V/229.6A,400V/230A,415V/235.5A,440V/265A,500V/224A,690V/162.4A;

AC-4:Ue/Ie:AC230V/191.4A,400V/191.7A,415V/196.3A,440V/220.9A,500V/186.7A,690V/135.4A;

AC-1:Ue/Ie:AC230V/400V/415V/440V/500V/690V/1000V/350A;3P;

LC1F330:

Ith:400A;

AC-3:Ue/Ie:AC230V/308.7A,400V/280A,415V/303.6A,440V/330A,500V/280A,690V/221.6A,1000V/112A;

AC-1:Ue/Ie:AC230V/400V/415V/440V/500V/690V/1000V/400A;3P;

LC1F400:

Ith:500A;

AC-3:Ue/Ie:AC230V/339.1A,400V/350A,415V/368.6A,440V/400A,500V/353.5A,690V/278.8A,1000V/129.5A;

AC-1:Ue/Ie:AC230V/400V/415V/440V/500V/690V/1000V/500A;3P;

LC1F2654,LC2F2654:

Ith:350A;

AC-1:Ue/Ie:AC230V/400V/415V/440V/500V/690V/1000V/350A;4P;

LC1F3304:

Ith:400A;

AC-1:Ue/Ie:230V/400V/415V/440V/500V/690V/1000V/400A;4P;

LC1F4004:

Ith:500A;

Additional information (if necessary)

Information complémentaire (si nécessaire)

Date: 2014-07-30

Signature: 
Wang Kejiao

IEC

IECEE
CB
SCHEME

Ref. Certif. No.

CN24995-M1

AC-1:Ue/Ie:230V/400V/415V/440V/500V/690V/1000V/500A;
4P
Us:AC24V,48V,110V,115V,120V,208V,220V,230V,240V,
380V,400V,415V,440V(40...400Hz);
LC1F265,LC2F265,LC1F330,LC1F2654,LC2F2654,LC1F3304:
DC24 V,48V,110V,125V,220-230V,250V,440V;
LC1F400,LC1F4004: DC48V,110V,125V,220V,250V,440V

Additional information (if necessary)

Information complémentaire (si nécessaire)

Date: 2014-07-30

Signature:



Wang Kejiao