



# 中国国家强制性产品认证证书

证书编号: 2012010309572841

## 委托人名称、地址

上海施耐德工业控制有限公司  
上海市普陀区绥德路629号

## 生产者(制造商)名称、地址

上海施耐德工业控制有限公司  
上海市普陀区绥德路629号

## 生产企业名称、地址

上海施耐德工业控制有限公司  
上海市普陀区绥德路629号

## 产品名称和系列、规格、型号

热过载继电器

LRD480C, LRE480, LRE480N, LRD481C, LRE481, LRE481N, LRD482C, LRE482, LRE482N, LRD483C, LRE483, LRE483N, LRD484C, LRE484, LRE484N, LRD485C, LRE485, LRE485N, LRD486C, LRE486, LRE486N, LRD487C, LRE487, LRE487N; 详见参数附件

## 产品标准和技术要求

GB 14048.4-2010

上述产品符合强制性产品认证实施规则  
CNCA-01C-011:2007的要求, 特发此证。

发证日期: 2012年10月09日      有效期至: 2017年10月09日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 0629894





# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2012010309572841

## NAME AND ADDRESS OF THE APPLICANT

Schneider Shanghai Industrial Control Co.,Ltd.  
No.629 Suidde Road, Putuo District, Shanghai, P.R.China

## NAME AND ADDRESS OF THE MANUFACTURER

Schneider Shanghai Industrial Control Co.,Ltd.  
No.629 Suidde Road, Putuo District, Shanghai, P.R.China

## NAME AND ADDRESS OF THE FACTORY

Schneider Shanghai Industrial Control Co.,Ltd.  
No.629 Suidde Road, Putuo District, Shanghai, P.R.China

## NAME, MODEL AND SPECIFICATION

Thermal Overload Relay

LRD480C, LRE480, LRE480N, LRD481C, LRE481, LRE481N, LRD482C, LRE482,  
LRE482N, LRD483C, LRE483, LRE483N, LRD484C, LRE484, LRE484N, LRD485C,  
LRE485, LRE485N, LRD486C, LRE486, LRE486N, LRD487C, LRE487, LRE487N; See the  
Appendix

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.4-2010

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-01C-011:2007).

Date of issue: Oct.09,2012      Date of expiry: Oct.09,2017

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: [www.enca.gov.cn](http://www.enca.gov.cn)



President:

Wang Kejiao

**CHINA QUALITY CERTIFICATION CENTRE**

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Q 0629894





# 中国国家强制性产品认证证书

附录:

第 1 页 共 2 页

证书编号: 2012010309572841

纸号: 629894

LRD480C, LRE480, LRE480N, LRD481C, LRE481, LRE481N, LRD482C,  
LRE482, LRE482N, LRD483C, LRE483, LRE483N, LRD484C, LRE484,  
LRE484N, LRD485C, LRE485, LRE485N, LRD486C, LRE486, LRE486N,  
LRD487C, LRE487, LRE487N

$U_i = AC690V$ ;

$U_e: 440V$ ;

$I_e: 51-81A, 62-99A, 84-135A, 124-198A, 146-234A, 174-279A, 208-333A,$   
 $259-414A$ ;

脱扣级别: 10A;

3P;

配用的辅助触头:(本体)

1NO+1NC;  $I_{th}: 5A$ ;

AC-15:  $U_e/I_e: 120V/3A, 500V/0.72A, 600V/0.12A$ ;

DC-13:  $U_e/I_e: 125V/0.22A, 250V/0.1A, 440V/0.06A$

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>







# 中国国家强制性产品认证证书

附录:

第 2 页 共 2 页

证书编号: 2012010309572841

纸号: 629894

型号的解释:

LRD	01	C
I	II	III
I	热过载继电器系列型号 Thermal Overload Relay reference LRD: 普通型热过载继电器 Common Thermal Overload Relay LRE: 优化型热过载继电器 Advanced Thermal Overload Relay	
II	电流范围 thermal tripping setting range (A) 480 51 - 81 A 481 62 - 99 A 482 84 - 135 A 483 124 - 198 A 484 146 - 234 A 485 174 - 279 A 486 208 - 333 A 487 259 - 414 A	
III	Options C: 中国制造普通型 (白色盖) C: Made in China common product(white cover) N: 只在国内销售 N: China offer 空白: 中国制造优化型 出口产品 (透明盖) Blank: Made in China advanced export product (transparent cover)	

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

