



# CERTIFICATE NCS/FI 30061

Our Ref. 288350-3

**Product** Thermostat

**Type** STR-10, T2300

**Trade mark** Schneider Electric (STR-10)  
ELKO (T2300)

**Certificate Holder/  
Manufacturer** Schneider Electric Industries SAS  
35, rue Joseph Monier  
92500 RUEIL MALMAISON, FRANCE

**Technical information** 10 A, 230 V, 50 Hz, Class II, IP20

**Other information** See the Appendix to this Certificate

**The product is certified  
according to the following  
standard(s)** EN 60730-2-9:2010  
EN 60730-1:2011

**Validity** This certificate is valid until 18 August 2022 provided that the Conditions for FI certification are met. This certificate includes the right to use the FI mark under the condition that product changes (if any) will be approved at SGS Fimko before the product is brought onto market.

**Directive information** The certified product(s) fulfils requirements of above mentioned standard(s) which are harmonised under the Low Voltage Directive (2014/35/EU) and EMC Directive (2014/30/EU) at the date of issue of the certificate.

**Date of issue** 18 August 2017

**SGS Fimko Ltd**

**Signature**

Seppo Lautamies  
Project Manager



This certificate has 1 appendix



This certificate is issued by the company under its General Conditions for Certification Services accessible at <http://www.sgs.fi/en/Terms-and-Conditions.aspx>. Attention is drawn to the limitations of liability defined therein and in the Test Report here above mentioned which findings are reflected in this certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Appendix to Certificate: 30061

**Manufacturing site(s)**

Lexel Fabrika SIA  
Krustpils 35a  
LV-1073 RIGA  
LATVIA

**Additional information**



Relay: 1E5 micro-disconnection  
Switch: 5E4 full-disconnection  
Features of automatic action: Type 1  
Construction: For flush mounting  
For use in normal pollution situations  
Resistance to heat and fire: Category D  
10T30  
PTI250

This certificate replaces NCS/FI certificate 27482, dated 17 August 2012, due to changed address of the manufacturing site and updated standard.

**Is based on test / Our ref.**

288350-3

Supplement to Certificate: **NCS/FI 30061**

Internal ref.  
288350-3

18 August 2017

## NORDIC CERTIFICATION SERVICE

We hereby confirm that the product(s) appearing from the certificate with above certificate reference also comply(ies) with requirements for secondary certification in the following countries: Norway, Sweden

### NOTIFICATION

<b>Certificate holder for Norway and Sweden</b>	Schneider Electric Industries SAS 35, rue Joseph Monier 92500 RUEIL MALMAISON, FRANCE <b>Please send the invoice and the certificate directly to:</b> Merten GmbH Fritz-Kotz-Str. 8 D-51674 WIEHL-BOMIG, GERMANY Attn: Mrs Rita Oehler, mailto: <a href="mailto:rita.oehler@schneider-electric.com">rita.oehler@schneider-electric.com</a>
<b>Safety standard(s) applied</b>	EN 60730-2-9:2010 EN 60730-1:2011
<b>Deviations</b>	Not applicable
<b>EMC requirements</b>	Carried out by SGS Fimko Ltd according to EN 60730-2-9:2010 EN 60730-1:2011
<b>The assignment is based on</b>	Testing in own premises from SGS Fimko Ltd.
<b>Limitations or reservations regarding the testing / examination performed</b>	None
<b>Certification marks</b>	Affixing of the certification mark(s) of the Nordic body(ies) on the product must not take place before notice about national certification is received from the individual body.
<b>Production surveillance</b>	Will be carried out by SGS Fimko according to agreed procedures.
<b>Other information</b>	Copy of the certificate, this Notification and other agreed documentation are transferred directly from SGS Fimko to NEMKO and SEMKO.
<b>Test samples must be submitted to the secondary body(ies)</b>	No
<b>Date of issue</b>	18 August 2017

This Notification may be challenged if it is more than 3 years old.

**SGS Fimko Ltd**

Signature



Seppo Lautamies  
Project Manager