



CB TEST CERTIFICATE

Ref. Certificate No.

NL-31483

IEC SYSTEM OF CONFORMITY ASSESSMENT SCHEMES FOR ELECTROTECHNICAL EQUIPMENT AND COMPONENTS (IECEE) CB SCHEME

Issued by:	DEKRA Certification B.V.		
Product:	Switch-disconnector		
Applicant:	Schneider Electric Industries SAS	Electropole 38EQI Rue Francois Quesnay 38320 Eybens	France
Manufacturer:	Schneider Electric Industries SAS	Electropole 38EQI Rue Francois Quesnay 38320 Eybens	France
Factory:	Schneider Electric Industries Polska SP.	uL Mostowa 19 32-332 Bukowno	Poland
Rating and principal characteristics:	Ui: 800 V Uimp: 8 kV Number of poles: 3 poles, 4 poles with switched neutral, 4 poles with solid neutral See annex for more information.		
Trade mark (if any):	SCHNEIDER ELECTRIC		
Type of Manufacturer's Testing Laboratories used:	WMT		
Model/Type reference:	INS 250 series		
Additional information:			
Sample of product tested to be in conformity with IEC:	60947-3(ed.3);am1		
Test Report Ref. No:	2171689.50		

This CB Test Certificate is issued by the National Certification Body:

DEKRA Certification B.V.
Meander 1051, 6825 MJ
Arnhem
The Netherlands

Signed by: F.S.Strikwerda

Date of issue: 2014-06-16



INS 250-100

le: 100 A
lthe: 100 A

	AC-22A	AC-23A
220/240 V	100 A	100 A
380/415 V	100 A	100 A
440/480 V	100 A	100 A
500/525 V	100 A	100 A
660/690 V	100 A	100 A
4 P in series 250 V	DC-22A 100 A	DC-23A 100 A

INS 250-160

le: 160 A
lthe: 160 A

	AC-22A	AC-23A
220/240 V	160 A	160 A
380/415 V	160 A	160 A
440/480 V	160 A	160 A
500/525 V	160 A	160 A
660/690 V	160 A	160 A
4 P in series 250 V	DC-22A 160 A	DC-23A 160 A

INS 250-200

le: 200 A
lthe: 200 A

	AC-22A	AC-23A
220/240 V	200 A	200 A
380/415 V	200 A	200 A
440/480 V	200 A	200 A
500/525 V	200 A	200 A
660/690 V	200 A	200 A
4 P in series 250 V	DC-22A 200 A	DC-23A 200 A

INS 250

le: 250 A
lthe: 250 A

	AC-22A	AC-23A
220/240 V	250 A	250 A
380/415 V	250 A	250 A
440/480 V	250 A	250 A
500/525 V	250 A	250 A
660/690 V	250 A	250 A
4 P in series 250 V	DC-22A 250 A	DC-23A 250 A