

# 中国国家强制性产品认证证书

证书编号: 2003010302059299

## 委托人名称、地址

上海施耐德配电电器有限公司  
上海市浦东新区康桥路833号

## 生产者(制造商)名称、地址

Prodipact SA  
AVENUE PAUL-LOUIS MERLIN, MONTMELIAN BP29, F-73805 MONTMELIAN CEDEX, FRANCE

## 生产企业名称、地址

Prodipact SA  
AVENUE PAUL-LOUIS MERLIN, MONTMELIAN BP29, F-73805 MONTMELIAN CEDEX, FRANCE

## 产品名称和系列、规格、型号

### 隔离开关

Masterpact NT06, NT08, NT10, NT12, NT16 HA;  $U_i=1000V$ ;  
 $I_{th}: 630A, 800A, 1000A, 1250A, 1600A$ ;  
 $U_e: AC400V/690V$ ;  $I_e: 630A, 800A, 1000A, 1250A, 1600A$ ;  $I_{cw}: 42kA \ 0.5s$ ;  $I_{cm}$ (峰值)  
 $=75kA$ ; AC-23A; 3P, 4P

## 产品标准和技术要求

GB 14048.3-2008


上述产品符合强制性产品认证实施规则  
CNCA-01C-011: 2007的要求, 特发此证。

发证日期: 2012年02月16日      有效期至: 2015年12月30日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2003年07月11日

本证书的相关信息可通过国家认监委网站 [www.cnca.gov.cn](http://www.cnca.gov.cn) 查询



主任:


## 中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 0489106



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2003010302059299

## NAME AND ADDRESS OF THE APPLICANT

Schneider Shanghai Power Distribution Elec.App.Co.,Ltd.  
No.833 Kangqiao Road, Pudong New District, Shanghai, P.R.China 201315

## NAME AND ADDRESS OF THE MANUFACTURER

Prodipact SA  
AVENUE PAUL-LOUIS MERLIN, MONTMELIAN BP29, F-73805 MONTMELIAN CEDEX, FRANCE

## NAME AND ADDRESS OF THE FACTORY

Prodipact SA  
AVENUE PAUL-LOUIS MERLIN, MONTMELIAN BP29, F-73805 MONTMELIAN CEDEX, FRANCE

## NAME, MODEL AND SPECIFICATION

Switch-disconnector

Masterpact NT06, NT08, NT10, NT12, NT16 HA;Ui=1000V;  
Ith:630A, 800A, 1000A, 1250A, 1600A;  
Ue:AC400V/690V;Ie:630A, 800A, 1000A, 1250A, 1600A; Icw:42kA 0.5s;Icm(Peak Value)=75kA;AC-23A;3P, 4P

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.3-2008


This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-01C-011:2007).

Date of issue: Feb.16,2012      Date of expiry: Dec.30,2015

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original certification: Jul.11,2003

This certificate can be verified through CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



President:

Wang Kejiao



**CHINA QUALITY CERTIFICATION CENTRE**

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>