

NOTIFICATION OF TEST RESULTS

Issued to: Schneider Electric Industries SAS
Electropole 38EQI, 31 rue Pierre Mendes
38050 Grenoble Cedex 9, France

For the product: Surge protective devices

Trade name: SCHNEIDER ELECTRIC

Type/Model: iQuick PRD 8r...
iQuick PRD 20r...
iQuick PRD 40r...
(for overview of types, see page 4 of test report)

Manufactured by: Schneider Electric Industries SAS
Electropole 38EQI, 31 rue Pierre Mendes
38050 Grenoble Cedex 9, France

Ratings: $U_c = 264/350$ V, $I_n = 2/5/20$ kA, $I_{max} = 8/20/40$ kA, $U_p = 1,2/1,5/1,7/2,5$ kV
(for overview of ratings, see page 4 of test report)

Pre-licence factory inspection carried out by
DEKRA Certification B.V.

A sample of the product has been tested and found to be in conformity with the current HD/EN and equivalent national standard
EN 61643-11:2012

As shown in the Test Report
2170494.50, 2170494.51, 2170494.52

This Notification of Test Results is the result of testing a sample of the product submitted, in accordance with the provisions of the relevant specific standard.

This Notification of Test Results has been established by a body, which participates in the CENELEC Certification Agreement (CCA) of 11th September 1973 as amended on 29th March 1983. Any other body participating in the CCA will take this Notification as a basis for granting a national mark of conformity or a national approval as specified in the CCA, as long as the standard referred to above is still in force in the country of that body.

Arnhem, 13 February 2015

Number: NTR NL 7361

DEKRA Certification B.V.



F.S. Strikwerda
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

CCA
CENELEC CERTIFICATION AGREEMENT
ACCORD DE CERTIFICATION DU CENELEC

DEKRA Certification B.V. Meander 1051, 6825 MJ Arnhem P.O. Box 5185, 6802 ED Arnhem, The Netherlands
T +31 88 96 83000 F +31 88 96 83100 www.dekra-certification.com Company registration 09085396