



03 March 2020

33-37 Port Wakefield Road, Gepps Cross SA 5094, Australia

Schneider Electric (Australia) Pty. Ltd.

Dear Sir / Madam,

APPROVAL OF NON-PRESCRIBED EQUIPMENT

Enclosed is the Certificate(s) in respect to your recent application received by Office of the Technical Regulator.

Please take time to check the certificate to ensure that all details are correct in accordance with your application, and that you understand all of the conditions imposed on the approval.

Should you have any queries, please contact George Nestic on telephone , or email george.nestic@sa.gov.au

Any samples that accompanied your application are available for collection, and if not collected within 20 business days of the date hereon may be disposed of.

Notification must be given to Office of the Technical Regulator of any change of registered Address within 20 business days.

Yours sincerely

A handwritten signature in blue ink that reads "George Nestic".

AUTHORISED OFFICER

Ref: OTR200079/00



Certificate Number: OTR200079/00



Certificate of Suitability

This is to certify that the Authorised officer has approved the electrical equipment described hereunder.

Registered Declarant: Schneider Electric (Australia) Pty. Ltd.
33-37 Port Wakefield Road, Gepps Cross SA 5094, Australia

Authorised Marking: OTR200079

Electrical equipment covered by this approval must comply in all respects with the approved article, and prior to being supplied or offered for supply, may be clearly and indelibly marked with the marking indicated above, or the Regulatory Compliance Mark (RCM) provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled.

Any modifications to the electrical equipment or its place of manufacture must be approved by Office of the Technical Regulator prior to the equipment being supplied or offered for supply.

Notification should be given to Office of the Technical Regulator of any change to the name or address of the holder of the certificate within 20 business days.

ARTICLE DETAILS

Electrical Equipment:	Level 1 NP: Non-Prescribed Arc Fault Detection Device (AFDD)
Relevant Standards:	AS/NZS IEC 62606:2013 + A1:2017
Expiry Date:	03 March 2025
Conditions of Approval:	

A handwritten signature in blue ink, appearing to read "George Nairn".

Authorised officer

DATE OF APPROVAL: 03 March 2022 Page: (2/ 3)
0

Certificate Number: OTR200079/00



Approval details

Model	A9TS1225
Rated at	Input: 230/240 Vac, 25 A
Trade Name	SCHNEIDER ELECTRIC
Comments	

A handwritten signature in blue ink that reads 'George Neill'.

Authorised officer

DATE OF APPROVAL: 03 March 2020 Page: (3/ 3)