

Product	Twist-on connecting device
Applicant	Schneider Electric Sverige AB CMS Product Department, Tilverkarvägen 2 SE-611 29 Nyköping Sweden
Manufacturer	Schneider Electric Sverige AB CMS Product Department, Tilverkarvägen 2 SE-611 29 Nyköping Sweden
Factory	ELSO GmbH An der Wipper 5-7 99706 Sonderhausen Germany
Ratings	440V AC
Trade mark	-
Model / Type Ref.	TORIX T6
Principal characteristics	Rated Connecting Cap: 0.5 — 6.0 mm ² . Number of Terminals :1 Rigid conductors: 2-10x0,5 mm ² / 2-10x0,75 mm ² / 2-10x1 mm ² / 2-8x1,5 mm ² / 2-5x2,5 mm ² / 2-3x4 mm ² / 2x6 mm ² . Flexible conductors, combinations: 3-10x0,5 mm ² / 2-10x0,75 mm ² / 2-10x1 mm ² / 2-8x1,5 mm ² / 2-5x2,5 mm ² / 2-3x4 mm ² / 2x6 mm ² . With test hole. Rigid and flexible conductors or combinations.
A sample of the product was tested and found to be in conformity with	INST EN 60998-1:2004 EN 60998-2-4:2005
Replaces	This certificate replaces previous certificate No. P12215365, due to new manufacturing site.
Validity	This certificate documents conformity with the standards shown, and also applies as license for use of Nemkos name and certification mark. The certificate and license is valid as long as the applicable conditions are complied with, and provided that any changes to the product are notified to Nemko for acceptance prior to implementation. New standards or amendments to the standards may imply that the product design must be updated and/or that re-testing and re-certification is necessary.
Additional information	
Additional model(s)	No additional models

Date of issue 14-10-2016



Nastaran Vadoodi

Certification Department

Nemko AS

Gaustadalléen 30, P.O. Box 73 Blindern, 0314 Oslo, Norway
TEL +47 22 96 03 30 FAX +47 22 96 05 50 EMAIL info@nemko.com
ENTERPRISE NUMBER NO974404532