

|   |  |
|---|--|
| Product   | Thermostat   |
| Applicant   | Schneider Electric Industries SAS<br>35, rue Joseph Monier<br>FR 92506 Rueil-Malmaison Cedex<br>France   |
| Manufacturer  | Schneider Electric Industries SAS<br>35, rue Joseph Monier<br>FR 92506 Rueil-Malmaison Cedex<br>France   |
| Factory   | Lexel Fabrika SIA<br>Krustpils 35a<br>LV-1073 Riga<br>Latvia   |
| Ratings   | 16A, 230 VAC, 50Hz   |
| Trade mark  | Schneider Electric   |
| Model / Type Ref.   | STF-16   |
| Principal characteristics   | Class II, IP20   |
| A sample of the product was tested and found to be in conformity with | CONT            EN 60730-1:2011<br>EN 60730-2-9:2010   |
| Validity  | This certificate documents conformity with the standards shown, and also applies as license for use of Nemkos name and certification mark. The certificate and license is valid as long as the applicable conditions are complied with, and provided that any changes to the product are notified to Nemko for acceptance prior to implementation.<br>New standards or amendments to the standards may imply that the product design must be updated and/or that re-testing and re-certification is necessary. |
| Additional information  | See page 2   |
| Additional model(s)   | (1) See page 2   |

Date of issue 04-09-2017



Nastaran Vadoodi

Certification Department

**Nemko AS**Gaustadalléen 30, P.O. Box 73 Blindern, 0314 Oslo, Norway  
TEL +47 22 96 03 30 FAX +47 22 96 05 50 EMAIL info@nemko.com  
ENTERPRISE NUMBER NO974404532

Additional model(s)

|                                       |                    |
|---------------------------------------|--------------------|
| Product                               | Thermostat         |
| Pos. No                               | 1                  |
| Model / Type Ref.                     | T16G               |
| Trade mark (if different from page 1) | ELKO               |
| Rating                                | 16A, 230 VAC, 50Hz |
| Principal characteristics             | Class II, IP20     |

Additional information

Relay: 1E5 micro-disconnection  
Switch: 5E4 full-disconnection  
Features of automatic action: Type 1  
Construction: For flush mounting  
For use in normal pollution situations  
Resistance to heat and fire: Category D  
10T30  
PTI250

Date of issue 04-09-2017



Nastaran Vadoodi

Certification Department

**Nemko AS**

Gaustadalléen 30, P.O. Box 73 Blindern, 0314 Oslo, Norway  
TEL +47 22 96 03 30 FAX +47 22 96 05 50 EMAIL info@nemko.com  
ENTERPRISE NUMBER NO974404532