

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Multiple portable socket-outlets with SPD(s)
Name and address of the applicant	American Power Conversion Holdings Inc., Taiwan Branch 5F., No. 189, Sec. 2, Jiuzong Rd., Neihu Dist., 11494 Taipei City Taiwan
Name and address of the manufacturer	Dongguan Quan Sheng Electric Co., Ltd. 2nd Industrial Zone, Ju-Tang, Housha Road, Houjie Town, 523963 Dongguan, Guangdong China
Name and address of the factory	<input type="checkbox"/> Additional information on page 2 Dongguan Quan Sheng Electric Co., Ltd. 2nd Industrial Zone, Ju-Tang, Housha Road, Houjie Town, 523963 Dongguan, Guangdong China
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	16 A, 250 V~, MAX. 2500 W (Limited to 10 A by means of circuit breaker) USB Output: 5,0 V dc 2,4 A (Shared) 12,0 W
Trademark (if any)	APC or APC by Schneider Electric
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	PM6U-GR, PM6U-RS
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2 This CB Test Certificate is an addition to CB NL-34899 with Test Report Number 4318493.50/51 dated 2015-02-28 due to deleted models, updated standard, changed USB Charger, added Trade Mark, updated enclosure and shutter box and changed applicant.
A sample of the product was tested and found to be in conformity with	IEC 60884-1:2002, IEC 60884-1:2002/AMD1:2006, IEC 60884-1:2002/AMD2:2013, IEC 60884-2-7:2011, IEC 60884-2-7:2011/AMD1:2013, IEC 61643-11:2011, IEC 62368-1:2018 National differences: DE, NL
As shown in the Test Report Ref. No. which forms part of this Certificate	4377516.50/51+6109441.50+4377094.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands