



Supplier's declaration of conformity

For compliance levels 1, 2 and 3 in Australia

As required by notices under:

- section 182 of the Australian *Radiocommunications Act 1992*.

Instructions for completion

- This completed form remains with the supplier as part of the documentation required for the compliance records. Do not return this form to ACMA.

Supplier's details

Name (name of manufacturer, importer or agent)

SCHNEIDER ELECTRIC AUSTRALIA PTY. LTD.

ACMA supplier code number

N998

OR

ABN, CAN or ARBN

Address (address of manufacturer, importer or agent)

78 Waterloo Road
Macquarie Park
NSW 2113

ABN No. 004969304

Product details

Product description – brand name, type, model, lot, batch or serial number (if available)

The IM400 is an insulation monitoring device. It injects a signal between the network (phase or neutral point) and earth. The resulting current that flows through the device is then measured. The insulation value is calculated from this current. The device indicates fault on its display and activate an alarm relay output.
The IM400VA2 is a voltage divider that adapts the voltage to the IM400 unit to a Voltage to a maximum of 1500Vac/dc input resulting a 300Vac/dc output.
IM400C is identical to IM400. IM400C is conformal coated and IM400 is not conformal coated
IM400THR is identical to IM400 and only the firmware is different between these two models. IM400THR has firmware changes to support the high voltage adaptor P1N IM400L is identical to IM400 except for DC power supply. IM400LTHR is identical to IM400THR except for DC power supply

Compliance with *Radiocommunications (Electromagnetic Compatibility) Standard 2008*

The above mentioned product complies with the requirements of the *Radiocommunications (Electromagnetic Compatibility) Standard 2008*. Evidence of compliance is demonstrated by test reports to the following applicable standards.


Applicable standards

Standard title, number and, if applicable, number of the test report

Standard: CISPR 11
Test report no.: IMD-IM400 and IMDIM400THR: R1512378C4-E-C IMD-IM400C and IMD-IM400VA2: R1512378C2-E-C IMD400L and IMD400LTHR: 4787987803-1
Date: IMD-IM400 and IMDIM400THR: 28 Nov 2012 IMD-IM400C and IMD-IM400VA2: 10 Jun 2016 IMDIM400L and IMDIM400LTHR: 30 May 2018
Test conducted by: AEMC Lab, 19, rue Francois Blumet -ZI de l'Argentiere-38360 SASSENAGE IMD400L - UL India Pvt Ltd, Kalyani Platina (Phase 1) III Floor, No.24, EPIP Zone, Phase II, Whitefield, Bangalore - 560 066

Declaration

I hereby declare that the product mentioned above complies with the requirements of the *Radiocommunications (Electromagnetic Compatibility) Standard 2008*. All products supplied under this declaration will be identical to the product identified above.

 SIGNATURE OF SUPPLIER OR AGENT
Samuel Goupel PRINT NAME

Marketing General Agent POSITION IN ORGANISATION
26/10/18 DATE