

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR
ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Residual current operated circuit-breaker (RCCB)
Name and address of the applicant	Schneider Low Voltage Terminal Apparatus Co., Ltd. 1319 Pingan Rd., Minhang Zone, Shanghai, P.R.CHINA
Name and address of the manufacturer	Same as applicant
Name and address of the factory Note: When more than one factory, please report on page 2	Same as applicant
Ratings and principal characteristics	See page 2
Trademark (if any)	
Customer's Testing Facility (CTF) Stage used	-
Model / Type Ref.	EZ9R
Additional information (if necessary may also be reported on page 2)	See page 2
A sample of the product was tested and found to be in conformity with	IEC 61008-1:2010+A1+A2 IEC 61008-2-2:1990
As shown in the Test Report Ref. No. which forms part of this Certificate	170400618SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Box 1103
SE-164 22 Kista, Sweden
Int +46 8 750 00 00

Date: 27 April 2017



Signature: 

Bo Berglöf



Ref. Certif. No.

SE-86796

Ratings and principal characteristics

Un: 230V~(1P+N), 50/60Hz

In: 25, 40, 63A

I Δ n: 0,01A (In: 25A), 0.03A(In: 25, 40, 63A), 0,1, 0,3A (In: 40, 63A), Type AC

I Δ n: 0,1, 0,3A (In: 40, 63A), type A

I Δ c= I Δ c: 4500A

I Δ m= I Δ m: 500A(In: 25A, 40A), 630A(In: 63A)

This certificate replaces CB certificate SE-71742 dated 21 January 2013. A new certificate has been issued due to standard updated.

Date:

Signature: