




Ref. Certif. No.

SE-87127

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Residual current operated circuit-breaker with integral overcurrent protection (RCBO's)
Name and address of the applicant	Schneider Electric Industries SAS 31, rue Pierre Mendès, F-38050 Grenoble Cedex 9, France
Name and address of the manufacturer	Same as factory
Name and address of the factory <i>Note: When more than one factory, please report on page 2</i>	Schneider Electric Thailand Ltd. 540 Soi 9 Bangpoo Industrial Estate, Sukhumvit Road, Muang District, Samutprakarn 10280, THAILAND
Ratings and principal characteristics	See page 2
Trademark (if any)	
Customer's Testing Facility (CTF) Stage used	-
Model / Type Ref.	QOvs
Additional information (if necessary may also be reported on page 2)	See page 2
A sample of the product was tested and found to be in conformity with	IEC 61009-1:2010+A1+A2 IEC 61009-2-2:1991
As shown in the Test Report Ref. No. which forms part of this Certificate	170300041SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Box 1103
SE-164 22 Kista, Sweden
Int +46 8 750 00 00

Date: 30 May 2017



Signature:

Bo Berglöf

Ratings and principal characteristics

Ue= 240V~

In= 6A, 10A, 16A, 20A, 25A, 32A, 40A, 50A, B and C-type

I Δ n= 10mA, 30mA, 100mA, type AC

Icn= 10000A, 6000A

Additional information (if necessary)

Also covers BS EN 61009-1:2012+A1:2014+A2:2014+A11:2015+A12:2016 and AS/NZS 61009.1:2015.

This certificate replaces SE-72667M1 dated 4 May 2015. A new certificate has been issued due to an updated standard.

Date: 30 May 2017

Signature: 