



Ref. Certif. No.

SE-87257

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBO's)

Name and address of the applicant

Schneider Electric Industries SAS
31, rue Pierre Mendès, F- 38050 Grenoble Cedex 9, France

Name and address of the manufacturer

Schneider Electric Thailand Ltd.
540 Soi 9 Bangpoo Industrial Estate, Sukhumvit Road,
Muang District, Samutprakarn 10280, THAILAND

Name and address of the factory

Note: When more than one factory, please report on page 2

Same as manufacturer

Ratings and principal characteristics

See page 2

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

iKQE

Additional information (if necessary may also be reported on page 2)

See page 2

A sample of the product was tested and found to be in conformity with

IEC 61009-2-2:1991
IEC 61009-1:2010+A1+A2

As shown in the Test Report Ref. No. which forms part of this Certificate

170300055SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Box 1103
SE-164 22 Kista, Sweden
Int +46 8 750 00 00

Intertek

Signature:

Bo Berglöf

Date: 12 June 2017

Ratings and principal characteristics

Model	Ue(V)	Icn(A)	IΔn(mA)	Type	Poles	In(A) and Type
iKQE	240V	10000	30	A	1P+N	B6, B10, B16, B20, B25, B32, B40, B45
iKQE	240V	10000	10, 30, 100	A	1P+N	C6, C10, C16, C20, C25, C32, C40, C45

Additional information (if necessary)

This certificate replaces the CB certificate No. SE-70683M1 dated May 04, 2015 to update of standard.

The product fulfils the requirements according to BS EN 61009-1:2012 + A1:2014 + A2:2014 + A11:2015 + A12: 2016 and AS/NZS 61009.1:2015.

Date: 12 June 2017

Signature: 

Intertek Testing Services Ltd, Shanghai #64
Building No. 86
1198 Qinzhou Road (North)
Caohejing Development Zone
Shanghai 200233
CHINA

Handled by
Amir Pashai Nejad
Direct telephone
+46 8 750 01 28
Reference
1712886
E-mail
amir.pashai.nejad@intertek.com
Your reference
Cherry Wang

12 June 2017

CB-certificate(s) SE-87257

We have the pleasure to enclose the requested CB-certificate(s) and the pertaining Test Report.

Yours sincerely

Intertek Semko AB
Product Certification

Enclosure CB certificate(s)