



# CERTIFICATE

## FOR EUROPEAN PRODUCT SAFETY

Reference No. SE-S-2100308R2

### Junction box

**Type designation:**

MIB-A1, MIB-A2, MIB-J

**Certificate holder:**

Schneider Electric Industries SAS  
35 rue Joseph Monier  
92500 Rueil-Malmaison France

**The product complies with the standard(s):**

EN IEC 60670-1:2021+A11

**Date of expiry:**

04 March, 2026

**EU Directive information:**

According to the principle of presumption of conformity, this certificate constitutes support for an EU Declaration of Conformity to the Low Voltage Directive 2014/35/EU.

Additional information in Appendix

**Certification Body:**

Intertek Semko AB, Product Certification

**Place:**

Kista - Stockholm

**Signed:**

**Date:**

27 November, 2023

Fredrik Wennersten

## APPENDIX:

Reference No. SE-S-2100308R2

### Technical Data:

Type designation	MIB-A1, MIB-A2, MIB-J
Rated voltage (V)	500V
Trademark	<b>THORSMAN</b>
Test Report	2308178STO-001
Product information	Flush mounted boxes of insulating material in white colour. The boxes are provided with anchorage for flexible/sheathed cable diam. 8,2-14 mm. See table below.

Type	Article no	Description
MIB-A1	20002339	Limited for built-in use in cable trunking system for single flush mounted accessories. Dimension inner ca 68x65 mm, depth 40 mm, for accessories with fixing distance of 60 mm. For single accessories and alternative provided with 2 insulating frame no. 20038167 (MIB-A1D3).
MIB-A2	20002340	Limited for built-in use in cable trunking system for double flush mounted accessories. Dimension inner ca 135x67 mm, depth 40 mm, for accessories with fixing distance of 60 mm.
MIB-J	20002341	Junction box, limited for built-in use in cable trunking system. Dimension inner ca 67x67 mm, depth 36 mm for floating terminals.



**APPENDIX:**

Reference No. SE-S-2100308R2

**Manufacturing Sites:** Schneider Electric Elda S.A.  
Ul.Bugno 1  
78-400 Szczecinek  
POLAND

According to the principle of presumption of conformity, this certificate, which includes production control, constitutes support for an EU Declaration of Conformity according to the Low Voltage Directive 2014/35/EU.

This presumption can expire before end of validity of this certificate due to new issued Standard or Amendment and changes within the EU legislation.

This certificate replaces previously issued certificate with Ref. No SE-S-2100308R1, dated 7 April 2021. A new certificate has been issued due to update of standard.

**Certification Body:** Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

**Signed:**  **Date:** 27 November, 2023

Fredrik Wennersten