

TYPE APPROVAL CERTIFICATE

This is to certify:**That the Transformer**with type designation(s)
ABL6 TS...

Issued to

Schneider Electric Automation GmbH
Marktheidenfeld, Bayern, Germany

is found to comply with

DNV GL rules for classification – Ships, offshore units, and high speed and light craft**Application :****Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.**Issued at **Hamburg** on **2021-02-23**for **DNV GL**This Certificate is valid until **2026-02-22**.DNV GL local station: **Augsburg**Approval Engineer: **Harald Amberger****Arne Schaarmann**
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV GL AS, its parent companies and subsidiaries as well as their officers, directors and employees ("DNV GL") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Product description

Single phase transformers for installation in switch cabinets, control panels

Series ABL6 TS... Transformers 230/400 V, Single winding

NOMENCLATURE:

ABL6 TS	10	B
I	II	III

- I Series designation
II Power in VA (max. 10 ... 250)
III Primary / Secondary Winding Voltage rating (B, U, J or G)

Ratings based on manufacturer's data sheet.

Rated power: 100 ... 2500 VA
Input (primary voltage): 230V AC/400V AC
Output (secondary voltage): 12/24/115/230V AC
Frequency: 50/60 Hz

Application/Limitation

Location Classes:

Temperature: B, Humidity: B, Vibration: A, IP00 (devices for indoor only)

Operating instruction of the manufacturer to be observed

Type Approval documentation

As per tech.-docs. in NPS 262.1-032882-1

Tests carried out

Environmental tests acc. DNVGL-CG-0339

Marking of product

Schneider Electric - Type designation - Main data.

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine Tests (RT) checked (if not available tests according to RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE