

Certificate of Conformity

issued by Curtis-Straus

Company: APC Corporation
Product Tested: ACF301
Testing Date: May 26, 30 and June 1, 2006
Report No.: EG0595-1

A sample of the product as configured in the accompanying test report has been found to comply with the following standards:

EMC Emissions:

- EN 55022:1998/A1:2000/A2:2003 Class A ITE emissions requirements (EU)
- ICES-003 Issue 4 Class A Digital Apparatus emissions requirements (Canada)
- FCC 47 CFR Part 15 Class A emissions requirements (USA)
- VCCI Class A ITE emissions requirements (Japan)
- AS/NZS CISPR 22:2002 Class A ITE emissions requirements (Australia)
- EN 61000-3-2:2000 Limits for harmonic current emissions (equipment input current up to and including 16A per phase)
- EN 61000-3-3:1995/A1:2001 Limitation of voltage fluctuations and flicker in low-voltage supply systems for equipment with rated current up to and including 16 A

Registration numbers for all open area test sites can be found in the *Test Equipment Used* Section starting on page 42 of the attached report.

EMC Immunity:

- EN 55024:1998/A1:2001/A2:2003 ITE - immunity characteristics
 - EN 61000-4-2 Electrostatic discharge immunity
 - EN 61000-4-3 Radiated, radio-frequency, electromagnetic field immunity
 - EN 61000-4-4 Electrical fast transient/burst immunity
 - EN 61000-4-5 Surge immunity
 - EN 61000-4-6 Immunity to conducted disturbances, induce by radio-frequency fields
 - EN 61000-4-8 Power frequency magnetic field immunity
 - EN 61000-4-11 Voltage dips, short interruptions and voltage variations immunity

Attested to by the hands and seals:

For Curtis-Straus


Test Engineer Date

For the Manufacturer or Importer

Date


EMC Manager Date