

ENEC LICENCE

Licence No. ENEC-01617
Page 1/3
Date of Issue 2017-03-29

Licence Holder SCHNEIDER ELECTRIC ESPANA S A
C/LLOBREGAT 15
MOLINS DE REI, 08750 Spain

Production site NINGBO QIYUANLIGHTING TECH CO. LTD
NO.238 HENANGU
CHAIQIAO
BEILUN
NINGBO, 315800 ZHEJIANG China

Certification Mark See Annex 1

Certified Product Class I LED luminaire for fixed installation

Model NSYLAMLDS

Trademark See page 2

Trademark 

Rated Voltage / Frequency 120-230 V~ 50/60 Hz

Rated Current / Power 10 W

Insulation Class Class I

Degree of protection (IP) IP20

Tested acc. to EN 60598-1:2015, EN 60598-2-1:1989

Test Report No. 4787675292-1 issued on 2017-02-20

Additional

Certification Manager
Jan-Erik Storgaard

This is to certify that representative sample(s) of the Product described herein ("Certified Product") have been investigated and found in compliance with the Standard(s) indicated on this License, in accordance with the ENEC Requirements. The Designated License holder is entitled to use the ENEC 15 Mark (as shown in annex 1) for the Certified Product manufactured at the production site(s) identified above in accordance with the ENEC Mark Service Agreement including without limitation the ENEC Mark Testing and Certification Services Service Terms. Only those Products bearing the ENEC Mark should be considered as being covered by UL's ENEC Mark Service. This License shall remain valid unless terminated earlier in accordance with the Service Agreement including without limitation if the Standard identified on this Certificate is amended or withdrawn prior the Date of Withdrawal of conflicting Standard(s).

Certification Body

UL International Demko A/S, Borupvang 5A, DK-2750
Ballerup, Denmark, Tel. +45 44 85 65 65, info.dk@ul.com
www.ul-europe.com



ENEC LICENCE

Licence No. ENEC-01617
Page 2/3
Date of Issue 2017-03-29

Model Details:

Variants:

The mail model:

Type ref.	Ratings	Details
NSYLAMLDS	120-230 V~ 50/60 Hz 10 W Class I IP20	With auxiliary socket outlet SHUKO

extends the following models:

Type ref.	Ratings	Details
NSYLAMLDF	120-230 V~ 50/60 Hz 10 W Class I IP20	With auxiliary socket outlet UTE
NSYLAMLDB	120-230 V~ 50/60 Hz 10 W Class I IP20	With auxiliary socket outlet UK

Certification Body

This is to certify that representative sample(s) of the Product described herein ("Certified Product") have been investigated and found in compliance with the Standard(s) indicated on this License, in accordance with the ENEC Requirements. The Designated License holder is entitled to use the ENEC 15 Mark (as shown in annex 1) for the Certified Product manufactured at the production site(s) identified above in accordance with the ENEC Mark Service Agreement including without limitation the ENEC Mark Testing and Certification Services Service Terms. Only those Products bearing the ENEC Mark should be considered as being covered by UL's ENEC Mark Service. This License shall remain valid unless terminated earlier in accordance with the Service Agreement including without limitation if the Standard identified on this Certificate is amended or withdrawn prior the Date of Withdrawal of conflicting Standard(s).



Annex 1 to Licence No.

ENEC-01617

Annex of the form of the Mark



* Identification number of the Certification Body

Size of the mark:

The size of the mark may be reduced on the condition that it remains legible and that the ratio $b/a=1,7$ is kept

Certification Body

This is to certify that representative sample(s) of the Product described herein ("Certified Product") have been investigated and found in compliance with the Standard(s) indicated on this License, in accordance with the ENEC Requirements. The Designated License holder is entitled to use the ENEC 15 Mark (as shown in annex 1) for the Certified Product manufactured at the production site(s) identified above in accordance with the ENEC Mark Service Agreement including without limitation the ENEC Mark Testing and Certification Services Service Terms. Only those Products bearing the ENEC Mark should be considered as being covered by UL's ENEC Mark Service. This License shall remain valid unless terminated earlier in accordance with the Service Agreement including without limitation if the Standard identified on this Certificate is amended or withdrawn prior the Date of Withdrawal of conflicting Standard(s).

