

CERTIFICATE OF COMPLIANCE

Certificate Number 20150430– E189035
Report Reference E189035 - 20141003
Issue Date 2015-APRIL-30

Issued to: SCHNEIDER ELECTRIC INDUSTRIES S A
Applicant Company: 35 RUE JOSEPH MONIER
92506 RUEIL MALMAISON CEDEX FRANCE

Listed Company: SCHNEIDER ELECTRIC INDUSTRIES, DBA HISPANO
MECANO ELECTRICA S A U
C/CALL 64
08786 CAPELLADES, SPAIN

This is to certify that representative samples of Industrial Control Panels
USL, CNL - Industrial Control Panel Enclosures Series NSYPHD followed by T or ZT followed by additional numbers, may be followed by the letter P.

Ratings:

NSYPHD single door enclosures are rated Type 1, 2, 3, 3R, 4, 4X, 5, 12 and 13.

NSYPHD double door enclosures are rated Type 1, 2, 3, 3R, 5, 12 and 13.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 508A, Industrial Control Panels
CSA C22.2 No. 14, Industrial Control Equipment

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

