

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20180319-E497361  
**Report Reference** E497361-20180312  
**Issue Date** 2018-MARCH-19

**Issued to:** Schneider Electric Industries SAS  
35 Rue Joseph Monier  
92500 Rueil Malmaison FRANCE

**This is to certify that  
representative samples of**

AUXILIARY DEVICES FOR USE IN HAZARDOUS  
LOCATIONS; AUXILIARY DEVICES FOR USE IN ZONE  
CLASSIFIED HAZARDOUS LOCATIONS

See Addendum

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** See Addendum

**Additional Information:** See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's  
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations>.



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20180319-E497361  
**Report Reference** E497361-20180312  
**Issue Date** 2018-MARCH-19

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Metallic Push button assemblies (22 mm line) Cat. No. XB4B followed by C, D, G, J, P, PS, S or T, followed by two, three or four digits numbers, followed by GEX for use in Class I, Zone 1, AEx db eb IIC; Zone 21, AEx tb IIIC; Class I, Division 2, Groups A, B, C and D; Class II, Division 2, Groups F and G; Class III, Division 1 and 2 Hazardous Locations.

Metallic Illuminated Push button assemblies (22 mm line) Cat. No. XB4B followed by P, followed by three digits numbers, followed by BM, followed by one digit number, followed by GEX for use in Class I, Zone 1, AEx db eb mb IIC; Zone 21, AEx tb IIIC; Class I, Division 2, Groups A, B, C and D; Class II, Division 2, Groups F and G; Class III, Division 1 and 2 Hazardous Locations.

Metallic LED pilot light assemblies (22 mm line) Cat. No. XB4B followed by V, followed by BM, followed by one digit number, followed by GEX for use in Class I, Zone 1, AEx eb mb IIC; Zone 21, AEx tb IIIC; Class I, Division 2, Groups A, B, C and D; Class II, Division 2, Groups F and G; Class III, Division 1 and 2 Hazardous Locations.

Contact blocks, Cat. No. ZBE, followed by 1, followed by two digits number, followed by GEX for use in Class I, Zone 1, AEx db eb IIC; Class I, Division 2, Groups A, B, C and D Hazardous Locations.

LED Pilot light blocks, Cat. No. ZBV followed by BM, followed by one digit number, followed by GEX for use in Class I, Zone 1, AEx eb mb IIC; Class I, Division 2, Groups A, B, C and D Hazardous Locations.

## Standard(s) for Safety:

UL 50E & CSA C22.2 No. 94-2, Enclosures for Electrical Equipment, Environmental Considerations

UL 508 & CSA C22.2 NO. 14-13, Industrial control equipment

UL 60079-0 & CSA C22.2 No. 60079-0:15, Explosive atmospheres - Part 0: Equipment - General requirements

UL 60079-1 & CSA C22.2 No. 60079-1:16, Explosive Atmospheres - Part 1: Equipment Protection by Flameproof Enclosures "d"

UL 60079-7 & CSA C22.2 No. 60079-7:16, Explosive Atmospheres - Part 7: Equipment Protection by Increased Safety "e"

UL 60079-18 & CSA C22.2 No. 60079-18:16, Explosive Atmospheres - Part 18: Equipment Protection by Encapsulation "m"

UL 60079-31 & CSA C22.2 No. 60079-31:16, Explosive Atmospheres – Part 31: Equipment Dust Ignition Protection by Enclosure "t"

UL 121201 & CSA C22.2 No. 213-17, Nonincendive electrical equipment for use in Class I and II, Division 2 and Class III, Divisions 1 and 2 hazardous (classified) locations



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations>.

