

CERTIFICATE OF COMPLIANCE

Certificate Number 20150707-E361380
Report Reference E361380-20150629
Issue Date 2015-JULY-07

Issued to: SCHNEIDER ELECTRIC AUTOMATION GMBH
SCHNEIDERPLATZ 1
97828 MARKTHEIDENFELD GERMANY

**This is to certify that
representative samples of**

PROGRAMMABLE CONTROLLERS FOR USE IN
HAZARDOUS LOCATIONS

Modicon TM4 Expansion Modules, Programmable
Controllers, for use in Class I, Division 2 Groups A, B, C
and D, Hazardous Locations. Models TM4 followed by ES4
followed by 4 or PDP followed by S, followed by 1.
TM4ES4, TM4PDPS1

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

Standard No. ANSI/ISA 12.12.01, Nonincendive Electrical
Equipment for Use in Class I and II, Division 2 and Class III,
Divisions 1 and 2 Hazardous (Classified) Locations,
Standard No. CAN/CSA C22.2 No. 213-M1987, Non-
incendive Electrical Equipment for Use in Class I, Division 2
Hazardous Locations

Additional Information:

See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

