

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Switch-disconnector
Name and address of the applicant	Schneider Electric Industries SAS 35 rue Joseph Monier 92500 Rueil-Malmaison France
Name and address of the manufacturer	Schneider Electric Industries SAS 31 Rue Pierre Mendés France, Eybens 38050 GRENOBLE Cedex 9 France
Name and address of the factory <i>Note: When more than one factory, please report on page 2</i>	Schneider Electric A.S. Cizovska 447 39701 Pisek Czech Republic
Ratings and principal characteristics	Rated operation voltage (Ue): 690 V Rated impulse withstand voltage (Uimp): 8 kV Rated insulation voltage (Ui): 690 V Conventional free air thermal current (Ith): V02: 12 A, V01: 20 A, V0: 25 A, V1: 32 A, V2: 40 A
Trademark / Brand (if any)	Schneider Electric
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	V0, V01, V1, V02, V2 to be used with rotary handle: KCC1YZ, KCE1YZ, KCD1PZ, KCF1PZ, KAD1PZ, KAF1PZ, KCC1LZ, KCE1LZ, KDD1PZ, KDF1PZ, KAC1BZ, KAE1BZ, KBD1PZ, KBF1PZ
Additional information (if necessary may also be reported on page 2)	See additional page(s) for further Additional information.
A sample of the product was tested and found to be in conformity with	IEC 60947-3:2020 IEC 60947-1:2020
As shown in the Test Report Ref. No. which forms part of this Certificate	HU23VARO 001

This CB Test Certificate is issued by the National Certification Body

TÜV Rheinland InterCert Kft., MEEI Division
H-1143 Budapest, Gizella út 51-57., Hungary
Web: www.tuv.com

Date: 2023-06-29

Signature:


Schmidt Ferencné

Additional information :


Accessories:

VZ0 (add-on main pole for V0)
VZ01 (add-on main pole for V01)
VZ1 (add-on main pole for V1)
VZ02 (add-on main pole for V02)
VZ2 (add-on main pole for V2)
VZ11 (add-on neutral pole for V02 and V2)
VZ14 (add-on PE-module for V0; V1; V01; V2; V02)
VCD0 (V0 with red rotary handle and direct mounting)
VCD01 (V01 with red rotary handle and direct mounting)
VCD1 (V1 with red rotary handle and direct mounting)
VCD02 (V02 with red rotary handle and direct mounting)
VCD2 (V2 with red rotary handle and direct mounting)
VCF0 (V0 with red rotary handle and direct mounting)
VCF01 (V01 with red rotary handle and direct mounting)
VCF1 (V1 with red rotary handle and direct mounting)
VCF02 (V02 with red rotary handle and direct mounting)
VCF2 (V2 with red rotary handle and direct mounting)
VCCD0 (V0 with red rotary handle and extended shaft)
VCCD01 (V01 with red rotary handle and extended shaft)
VCCD1 (V1 with red rotary handle and extended shaft)
VCCD02 (V02 with red rotary handle and extended shaft)
VCCD2 (V2 with red rotary handle and extended shaft)
VCCF0 (V0 with red rotary handle and extended shaft)
VCCF01 (V01 with red rotary handle and extended shaft)
VCCF1 (V1 with red rotary handle and extended shaft)
VCCF02 (V02 with red rotary handle and extended shaft)
VCCF2 (V2 with red rotary handle and extended shaft)
VBD0 (V0 with black rotary handle and direct mounting)
VBD01 (V01 with black rotary handle and direct mounting)
VBD1 (V1 with black rotary handle and direct mounting)
VBD02 (V02 with black rotary handle and direct mounting)
VBD2 (V2 with black rotary handle and direct mounting)
VBF0 (V0 with black rotary handle and direct mounting)
VBF01 (V01 with black rotary handle and direct mounting)
VBF1 (V1 with black rotary handle and direct mounting)
VBF02 (V02 with black rotary handle and direct mounting)
VBF2 (V2 with black rotary handle and direct mounting)
VVE0 (V0 with larger red rotary handle and direct mounting)
VVE1 (V1 with larger red rotary handle and direct mounting)
VVE2 (V2 with larger red rotary handle and direct mounting)
VVD0 (V0 with larger black rotary handle and direct mounting)
VVD1 (V1 with larger black rotary handle and direct mounting)
VVD2 (V2 with larger black rotary handle and direct mounting)



Date: 2023-06-29

Signature:


Schmidt Ferencné