

Certificate of Conformity

issued by Curtis-Straus LLC, a wholly owned subsidiary of BV CPS

Company: APC Corporation
Product Tested: AP9610
Testing Date: February 8, 9, 11, 14, 15, 16, and 17, 2011
Report No.: EL0142-4 Issue 2

A sample of the product as configured in the accompanying test report has been found to comply with the following standards:

EMC Emissions and Immunity:

- 47 CFR FCC Part 15 Class A emissions requirements (USA)
- EN 61000-6-4:2007 Emissions requirements for heavy industrial environments - Generic
- EN62040-2:2006 Electromagnetic compatibility (EMC) requirements for uninterruptible power systems (UPS) – Category C3

Attested to by the hands and seals:

For Curtis-Straus LLC

For the Manufacturer or Importer

Disha Vankar 5/19/11
Test Engineer Date

Date

[Signature] 5/19/11
EMC Manager Date