

# CENELEC CERTIFICATION AGREEMENT

ACCORD DE CERTIFICATION DU CENELEC  
CENELEC-ZERTIFIZIERUNGS-ABKOMMEN



## NOTIFICATION OF TEST RESULTS

NTR/AT 1862

Erzeugnis  
Product

Surge protective device \_\_\_\_\_

Geprüft im Auftrag von  
Tested by request of

Schneider Electric Industries SAS  
38050 Grenoble Cedex 9, 31 rue Pierre Mendès France,  
France \_\_\_\_\_

Hergestellt von (Firma und Ort)  
Manufactured at (name and place)

Shanghai Schneider Electric Low Voltage Terminal Apparate  
Co.Ltd.  
201109 Shanghai, 1319 PingAn Road, China \_\_\_\_\_

Werks-Erstbesichtigung durchgeführt von  
Preliminary visit carried out by

OVE \_\_\_\_\_

Betriebsdaten und wichtige Merkmale  
Rating and principal characteristics

Uc = AC 340 V (L-N); Uc = AC 260 V (N-PE);  
In = 15 kA (iPF 40), 5 kA (iPF 20), 2,5 kA (iPF 8);  
Imax = 40 kA (iPF 40), 20 kA (iPF 20), 8 kA (iPF 8);  
Uoc = 10 kV (iPF 8 only) \_\_\_\_\_

Warenzeichen (falls vorhanden)  
Trade mark (if any)

SCHNEIDER ELECTRIC \_\_\_\_\_

Typenbezeichnung  
Model/Type Ref.

iPF 40..., iPF 20..., iPF 8...,  
see page 6 of test reports \_\_\_\_\_

Zusätzliche Information (falls erforderlich)  
Additional information (if necessary)

\_\_\_\_\_

Ein Muster dieses Erzeugnisses ist geprüft und als in Übereinstimmung mit (HD/EN und gleichwertiger nationaler Norm)  
A sample of the product has been tested and found to be in conformity with (HD/EN and equivalent national standard)

EN 61643-11:2002 + A11:2007 \_\_\_\_\_

befunden worden, wie es aus den Prüfberichten hervorgeht (Aktenzeichen/Nr.)  
as shown in the test reports (reference No.) CTI-CA 755-1 to 755-8 \_\_\_\_\_

Diese Mitteilung von Prüfergebnissen ist das Ergebnis einer Prüfung, die an einem eingereichten Muster eines Erzeugnisses in Übereinstimmung mit den Bestimmungen der jeweiligen Norm durchgeführt worden ist.

Diese Mitteilung von Prüfergebnissen ist von einer Stelle ausgestellt worden, die direkt am CENELEC-Zertifizierungs-Abkommen (CCA) vom 11. September 1973, revidiert am 29. März 1983, 3. September 2004 und 18. April 2007 (einschließlich der Ergänzungen 1 bis 4) teilnimmt. Jede andere am CCA teilnehmende Stelle nimmt diese Mitteilung als Grundlage für die Erteilung eines nationalen Konformitätszeichens (Prüfzeichens) oder einer nationalen Zulassung, wie es im CCA festgelegt ist.

This Notification of Test Results is the result of testing a sample of the product submitted, in accordance with the provisions of the relevant specific standard.

This Notification of Test Results has been established by a body which participates directly in the CENELEC Certification Agreement (CCA) of September 11<sup>th</sup>, 1973 as revised on March 29<sup>th</sup>, 1983, September 3<sup>rd</sup>, 2004 and April 18<sup>th</sup>, 2007 (including addenda 1 to 4). Any other body participating in the CCA will take this Notification as a basis for granting a national mark of conformity or a national approval as specified in the CCA.

Österreichischer Verband für Elektrotechnik  
Head of Testing & Certification

Digitally signed by K. Wallner

on behalf of W. Martin

Email=k.wallner@ove.at

Dipl.-Ing. W. Martin

Vienna, 2011-10-14

OVE - Testing & Certification  
1190 Wien, Kahlenberger Str. 2A, Austria

Tel.: +43 1 370 58 06 Fax.: +43 1 370 58 06-199

ZVR: 327279890 DVR: 1055887

Accredited by the Austrian Ministry of Economy, Family and Youth as Certification Body for products and processes in the field of electrical and electronic engineering, including safety and EMC

