

EC CONFORMITY DECLARATION

The Company SCHNEIDER ELECTRIC INDUSTRIES S A, 35 RUE JOSEPH MONIER
92500 RUEIL MALMAISON FRANCE

Declares that the product: Derivation insulating boxes MUREVA BOX
ENN05---

ENN05001, ENN05021, ENN05002, ENN05022, ENN05082, ENN05032, ENN05072, ENN05004,
ENN05024, ENN05204, ENN05164, ENN05264, ENN05084, ENN05174, ENN05044, ENN05064,
ENN05003, ENN05023, ENN05083, ENN05005, ENN05025, ENN05205, ENN05165, ENN05265,
ENN05085, ENN05175, ENN05007, ENN05167, ENN05267, ENN05087, ENN05177, ENN05045,
ENN05065, ENN05010, ENN05090, ENN05013, ENN05093, ENN05017, ENN05097, ENN05019,
ENN05099

Provided that it is installed, maintained and used in the application for which it is made, with respect of the "professional practices", relevant installation and manufacturer's instructions.

Complies with the safety provisions for people and things required by the following Council Directives:

2006/95/CE *Low voltage*
89/106/CE - 93/68/CE *Construction*

Complies with the provisions of the following standards:

IEC 62208 : Empty enclosures for low-voltage switchgear and control gear assemblies - General requirements
IEC 60529 : Degrees of protection provided by enclosures (IP code) **IP55**
IEC 62262: Degrees of protection provided by enclosures for electrical equipment against external mechanical impacts (IK code) **IK07**

Additional information's:

External certifications TÜV, IMQ

This product is intended to be installed, maintained and used by professional persons.

In the case of it is incorporated into an equipment submitted to the Directive 2006/42/CE and its modifications (Machinery Directive), this machinery must not be put into service until it has been declared to conform to the provisions of the Directive.

Year of affixing "CE" marking (ancient denomination)

2005

15th June 2011



Imanol REGO
Universal Enclosures Director
Schneider Electric Industries