

EC CONFORMITY DECLARATION

The Company SCHNEIDER ELECTRIC INDUSTRIES S A, 35 RUE JOSEPH MONIER
92500 RUEIL MALMAISON FRANCE

Declares that the product: Enclosure 19" SPACIAL VDM
NSYVDM – NSYVD2M

**NSYVDM4U4P (*), NSYVDM7U4P (*), NSYVDM9U4P (*), NSYVDM13U4P (*),
NSYVDM16U4P (*), NSYVDM5U4F (*), NSYVDM8U4F (*), NSYVDM10U4F (*),
NSYVDM14U4F (*), NSYVDM17U4F (*),
NSYVD2M5U4, NSYVD2M5U5, NSYVD2M8U4, NSYVD2M8U5, NSYVD2M10U4,
NSYVD2M10U5, NSYVD2M14U4, NSYVD2M14U5, NSYVD2M17U4, NSYVD2M17U5.**

Provided that it is installed, maintained and used in the application for which it is made, with respect of the "professional practices", relevant installation and manufacturer's instructions.

Complies with the safety provisions for people and things required by the following Council Directives:

2006/95/CE <i>Low voltage</i> 89/106/CE - 93/68/CE <i>Construction</i>

Complies with the provisions of the following standards :

IEC 62208 :	Empty enclosures for low-voltage switchgear and control gear assemblies - General requirements (Only for reference with (*))
IEC 60529 :	Degrees of protection provided by enclosures (IP code) IP66
IEC 62262:	Degrees of protection provided by enclosures for electrical equipment against external mechanical impacts (IK code) IK08

Additional information:

External certifications	Only for references with (*) : BV – DNV – GL - LR
-------------------------	---------------------------------------------------

This product is intended to be installed, maintained and used by professional persons.

In the case of it is incorporated into an equipment submitted to the Directive 2006/42/CE and its modifications (Machinery Directive), this machinery must not be put into service until it has been declared to conform to the provisions of the Directive.

Year of affixing "CE" marking (ancient denomination)

2004

Year of affixing "CE" marking (NSYVDM and NSYVD2M series, new denomination)

2010



14th October 2010

Stéphane DARIEL
Universal Enclosures Director
Schneider Electric Industries