

# Certificate

No. SEBS-A.163822/16 V1.0

TÜV NORD Systems GmbH & Co. KG hereby certifies

## Schneider Electric Industries SAS

31, rue Pierre Mendès-France  
38320 Eybens  
France

that the Safe Stop function within

## TeSys™ island

Is capable for safety related application and meets the requirements listed in the following standards

- IEC 61508-1 / -2: 2010, SIL 1 / 2
- ISO 13849-1: 2015, PL c / d, Cat. 1 / 2
- ISO 13849-2: 2012, PL c / d, Cat. 1 / 2
- IEC 62061: 2005 + A1:2012 + A2:2015 + CSV/COR1:2015, SILCL 1 / 2

Certificationprogram Leittechnik (SEB-ZE-SEECERT-VA-320-20, Rev. 3/9.15)

Base of certification is the report SEBS-A.163822/16TB and the certificate tracking list in the valid version.

This certificate entitles the holder to use the pictured Safety Approved mark.

Valid until: 2024-07-12  
File reference: 8114382857

Augsburg, 2019-07-12



Bianca Pfuff

