



**SGS**

EU Type Examination Certificate Number: **0120/SGS0203**

# Schneider Electric

dba Power Measurement Ltd.  
2195 Keating Cross Road  
Saanichton, British Columbia  
Canada, V8M 2A5

Instrument Identification:  
**PM8000**

**Poly phase, Active Import/ Export (kWh), Transformer Operated, Auxilliary power supply, RS485, Dual Ethernet, 1 digital output, 3 digital inputs**

Instrument Traceable Number  
**0120/SGS0203**

has been assessed and certified as meeting the requirements of

## EU Directive 2014/32/EU

on Measuring Instruments Annex II, Module B

It is certified that the manufacturer's technical design and specimen for the above instrument has been examined and, based on the evidence submitted, it is considered that the instrument conforms to the requirements of Annex V of EU Directive 2014/32/EU

This certificate must be used in conjunction with a certificate covering the product verification as required in Annex II, Module D or Annex II, Module F

This certificate is valid until 6<sup>th</sup> September 2025  
Issue 8

Certification is based on report number(s)  
EMA195810/1 dated 28<sup>th</sup> January 2015, EMA204099 dated 28<sup>th</sup> January 2015

Authorised Signature

SGS United Kingdom Limited, Notified Body 0120  
Unit 202B Worle Parkway, Weston-super-Mare, BS22 6WA UK  
t +44 (0)1934 522917 f +44 (0)1934 522137 [www.sgs.com](http://www.sgs.com)

Contact Address  
SGS United Kingdom Ltd, Unit 10, South Industrial Estate, Bowburn, Durham, DH6 5AD UK  
t +44 (0)191 377 2000 f +44 (0)191 377 2020 [www.sgs.com](http://www.sgs.com)



This document is issued, on the Client's behalf, by the Company under its General Conditions of Service printed overleaf. The Client's attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any other holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Clients instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents.


DU\_CST-ME-002\_Rev 2

Page 1 of 6

SGSPAPER  
20295110


EU Type Examination Cert



	EU-Type Examination Certificate Number:	
	<b>0120/ SGS0203</b>	
	Issue Number: 8	Dated: 17 <sup>th</sup> September 2020

## 1. Technical Data

<b>Manufacturer</b>	Schneider Electric
<b>Meter Type</b>	PM8000
<b>Voltage Rating (<math>U_n</math>)</b>	3P3W: 3x100V to 3x600V (L-L) 3P4W: 3 x 57.7/100V to 3x400/690V
<b>Current Rating (<math>I_{min} - I_{ref} (I_{max})</math>)</b>	0.025-5(10)A
<b>Frequency (<math>F_n</math>)</b>	50Hz or 60Hz (IEC only)
<b>Active Accuracy Class (<math>kWh</math>)</b>	C (kWh)
<b>Type of circuit</b>	3P4W, 3P3W
<b>Temperature Range</b>	-25°C to +70°C
<b>Software/ Firmware Version No's</b>	Version :001.004.003. CRC: 0x0c2eda9a Version : 002.001.000. CRC: 0x5c9693a1 Version: 002.002.001. CRC: 0xd0467dc0 Version: 003.000.000. CRC: 0xe4bbde55
<b>Identification Location</b>	LCD
<b>Bill Of Materials No's</b>	EAV66596 PCBA, PSU, PM8000 EAV66599 PCBA, CVM, PM8000 EAV66594 PCBA, Comm I/O, PM8000 EAV66601 PCBA, Backplane, INT, PM8000 EAV66597 PCBA, CPU, PM8000
<b>IP Rating</b>	IP51 Front Display  Meter body not rated, must be fitted in an IP51 Enclosure
<b>Insulation Protective Class</b>	Class II
<b>LED Pulse Constant</b>	5000 imp/ kWh
<b>Impulse Voltage Rating</b>	6kV
<b>AC Voltage Rating</b>	4kV
<b>Main Cover Sealing Type</b>	Destructible rivet
<b>Integrity of meter</b>	Inaccessible without breaking rivet
<b>Intended Location of the Meter</b>	Indoor
<b>Type of Register</b>	LCD

	EU-Type Examination Certificate Number:	
	0120/ SGS0203	
	Issue Number: 8	Dated: 17 <sup>th</sup> September 2020

2. Photographs of Meter



Front View



Rear View

### 3. Calculation of the composite error/ MPE

During the type approval examination the influence factors for temperature, frequency and voltage are determined per load point. The table below presents the sum of the square values per load, determined via the following formula:-

$$\delta e(T, U, f) = \sqrt{(\delta e^2(T, I, \cos\phi) + \delta e^2(U, I, \cos\phi) + \delta e^2(f, I, \cos\phi))}$$


Where

$\delta e(T, I, \cos\phi)$  = Additional error due to variation of the temperature at the same load

$\delta e(U, I, \cos\phi)$  = Additional error due to variation of the voltage at the same load

$\delta e(f, I, \cos\phi)$  = Additional error due to variation of the frequency at the same load

Current	PF Cos	Influence Factors for temperature, frequency and voltage							
		-40°C	-25°C	-10°C	5°C	30°C	40°C	55°C	70°C
I <sub>min</sub>	1.0	0.15	0.20	0.14	0.12	0.11	0.12	0.13	0.13
I <sub>tr</sub>	1.0	0.13	0.18	0.11	0.07	0.06	0.07	0.07	0.07
10I <sub>tr</sub>	1.0	0.24	0.27	0.19	0.09	0.05	0.06	0.06	0.05
I <sub>max</sub>	1.0	0.20	0.23	0.15	0.09	0.06	0.07	0.07	0.06
I <sub>tr</sub>	0.5ind	0.27	0.19	0.21	0.11	0.08	0.08	0.10	0.15
10I <sub>tr</sub>	0.5ind	0.42	0.42	0.31	0.17	0.08	0.11	0.11	0.08
I <sub>max</sub>	0.5ind	0.45	0.44	0.32	0.19	0.08	0.10	0.09	0.10
I <sub>tr</sub>	0.8cap	0.10	0.09	0.22	0.13	0.09	0.09	0.09	0.09
10I <sub>tr</sub>	0.8cap	0.21	0.23	0.15	0.11	0.10	0.10	0.10	0.10
I <sub>max</sub>	0.8cap	0.15	0.17	0.11	0.10	0.09	0.09	0.09	0.09
L1									
I <sub>tr</sub>	1.0	0.26	0.22	0.15	0.11	0.09	0.10	0.12	0.10
10I <sub>tr</sub>	1.0	0.19	0.20	0.13	0.08	0.04	0.05	0.06	0.04
I <sub>max</sub>	1.0	0.18	0.19	0.10	0.07	0.03	0.04	0.04	0.04
I <sub>tr</sub>	0.5ind	0.29	0.33	0.24	0.17	0.14	0.17	0.23	0.31
10I <sub>tr</sub>	0.5ind	0.25	0.25	0.16	0.09	0.07	0.11	0.11	0.09
I <sub>max</sub>	0.5ind	0.21	0.22	0.14	0.09	0.07	0.08	0.06	0.20
L2									
I <sub>tr</sub>	1.0	0.19	0.20	0.17	0.15	0.15	0.15	0.15	0.15
10I <sub>tr</sub>	1.0	0.38	0.36	0.26	0.17	0.14	0.14	0.14	0.14
I <sub>max</sub>	1.0	0.31	0.29	0.22	0.18	0.15	0.15	0.15	0.15
I <sub>tr</sub>	0.5ind	0.72	0.54	0.47	0.25	0.16	0.16	0.16	0.17
10I <sub>tr</sub>	0.5ind	0.59	0.57	0.46	0.29	0.18	0.19	0.19	0.18
I <sub>max</sub>	0.5ind	0.65	0.64	0.50	0.33	0.21	0.23	0.22	0.22
L3									
I <sub>tr</sub>	1.0	0.16	0.16	0.07	0.04	0.04	0.04	0.04	0.04
10I <sub>tr</sub>	1.0	0.26	0.29	0.17	0.10	0.03	0.04	0.04	0.03
I <sub>max</sub>	1.0	0.21	0.23	0.12	0.08	0.03	0.04	0.04	0.03
I <sub>tr</sub>	0.5ind	0.41	0.28	0.28	0.15	0.06	0.06	0.06	0.06
10I <sub>tr</sub>	0.5ind	0.49	0.47	0.32	0.18	0.07	0.10	0.09	0.08
I <sub>max</sub>	0.5ind	0.47	0.47	0.31	0.19	0.02	0.09	0.08	0.07


	EU-Type Examination Certificate Number:	
	<b>0120/ SGS0203</b>	
	Issue Number: 8	Dated: 17 <sup>th</sup> September 2020

#### 4. Annex of Variants

##### Product Variant Identification Details:

Product	Model (SKU)	Description
PM8000	METSEPM82401	Poly phase, Active Import/ Export (kWh), Transformer Operated, Auxiliary Power Supply, RS485, Dual Ethernet, 1 Digital Output, 3 Digital Inputs
Aux Devices	METSEPM89M2600 METSEPM89M0024	Digital I/O module (6 digital inputs & 2 relay outputs) Analogue I/O module (4 analogue inputs & 2 analogue outputs)

Modifications to the meter(s) described according to approval No. **0120/ SGS0203** must be notified to the issuing body to confirm the meter(s) continuing compliance to the relevant pattern approval standard(s).

	EU-Type Examination Certificate Number:	
	<b>0120/ SGS0203</b>	
	Issue Number: 8	Dated: 17 <sup>th</sup> September 2020

## 5. Document Revision History

Issue	Date	Comments
1	07/09/2015	Initial Issue
2	12/10/2016	New BOM and software revision
3	11/04/2018	New firmware version
4	27/05/2018	Auxiliary devices included in product details
5	18/04/2019	New firmware version 002.001.000 & CRC checksum No. 0x5c9693a1 added.
6	03/03/2020	New firmware version 002.002.001 & CRC checksum No. 0xd0467dc0 added. BOM numbers changed to part numbers. Rear label updated to show correct marking 0120/SGS0203
7	14/04/2020	BOM number correction
8	17/09/2020	New firmware version 003.000.000 & CRC checksum No. 0xe4bbde55 added.

This document is issued by the Company subject to its General Conditions for Certification Services, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx>.

Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested *and such sample(s) are retained for 28 days only*.

**END OF CERTIFICATE**