



Lloyd's
Register

Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

This certificate is issued to:

PRODUCER	Vamp Ltd. (a member of Schneider Electric) Yrittäjänkatu 15 65380 Vaasa Finland
DESCRIPTION	Arc flash protection unit
TYPE	Vamp 125
APPLICATION	Marine, offshore and industrial applications for use in environmental categories ENV1, ENV2 and ENV3 as defined in Lloyd's Register's Type Approval System, Test Specification Number 1 – July 2015.
ADDITIONAL TESTS	Dry heat (storage): +80°C / 16h Low temperature (operational and storage): -40°C / 16h
STANDARD	IEC 60255-1: 2009 IEC 60255-27: 2013
RATINGS	Auxiliary power supply: 24 to 240V ac/dc Degree of protection: IP 20
OTHER CONDITIONS	Vamp 125 is not in contact with fluids.
PLACE OF PRODUCTION	Crimppi Oy Liikekuja 7 65380 Vaasa Finland
Certificate No.	17/20081
Issue Date	24 July 2017
Expiry Date	23 July 2022
Sheet	1 of 2



Thorsten Wolff
Hamburg Technical Support Office
Lloyd's Register EMEA

Lloyd's Register EMEA
71 Fenchurch Street, London EC3M 4BS

Lloyd's Register EMEA
Is a subsidiary of Lloyd's Register Group

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.



Lloyd's
Register



The Type Approval does not eliminate the need for normal inspection and survey procedures required by the Rules and Regulations.

If the specified standards are amended during the validity of this certificate, the product is to be re-approved prior to it being supplied to vessels to which the amended standards apply.

The Design Appraisal Document No. HTS/ETS 35585-17 and its supplementary Type Approval Terms and Conditions form part of this Certificate.

Certificate No. 17/20081
Issue Date 24 July 2017
Expiry Date 23 July 2022
Sheet 2 of 2

Thorsten Wolff
Hamburg Technical Support Office
Lloyd's Register EMEA



Lloyd's Register

LR031.1.2013.12

Thorsten Wolff
Hamburg Technical Support Office
Lloyd's Register EMEA

Lloyd's Register EMEA
71 Fenchurch Street, London EC3M 4BS

Lloyd's Register EMEA
Is a subsidiary of Lloyd's Register Group

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.