

Type Approval Certificate Extension

This is to certify that Certificate No. 91/30302(E2) for the undernoted products is extended and renumbered as shown.

This certificate is issued to:

PRODUCER	Telemecanique – Schneider Electric Industries S.A.S 33 Avenue de Chatou 92506 Rueil Malmaison Cedex France
PLACE OF PRODUCTION	Telemecanique – Schneider Electric Industries S.A.S 6-8, Rue du Bailly 21078 Dijon Cedex France
DESCRIPTION	Manual AC Motor Starters 3 pole, with Thermal Magnetic “M” Tripping Units
TYPE	GV3 M.. in 9 setting ranges GV3 ME.. in 9 setting ranges Accessories: Auxiliary Contact Blocks, type GV1 A01 trough to A07 type GV3 A01 through to A07 Undervoltage Release Coil, type GV3B 240 to 600 volts. Shunt Release Coil, type GV3D 240 to 600 volts. Fault Indicating Contact Block type GV3 A08 and A09. Enclosure GC3-CE01
APPLICATION	Marine, Offshore and Industrial use in environmental categories EVV1, ENV2 and ENV3, as defined in Type Approval System Test Specification No. 1 2002.
Certificate No.	91/30302 (E3)
Issue Date	08 November 2007
Expiry Date	19 August 2012
Sheet	1 of 2

Lloyd's Register EMEA
71 Fenchurch Street, London EC3M 4BS


J.W.J. Dijke
Type Approval Department
Lloyd's Register EMEA

"This Certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify LR of any modification or changes to the equipment in order to obtain a valid certificate."

The attached Design Appraisal Document No.ROT.TA.0790344 and its supplementary Type Approval Terms and Conditions form part of this Certificate.

All other details remain as the previous Certificate No. 91/30302 to which this extension should be attached.

Certificate No.	91/30302 (E3)
Issue Date	08 November 2007
Expiry Date	19 August 2012
Sheet	2 of 2

Lloyd's Register EMEA
71 Fenchurch Street, London EC3M 4BS


W.J. Dijke
Type Approval Department
Lloyd's Register EMEA

"Lloyd's Register, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register Group'. The Lloyd's Register Group assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register Group entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract."

Page 1 of 1
Document number ROT.TA.0790344
Issue number 1

DESIGN APPRAISAL DOCUMENT

Date 08 November 2007	Quote this reference on all future communications ROT.TA.0790344/WJD
--------------------------	---

LLOYD'S REGISTER TYPE APPROVAL SYSTEM, 2002.
Issued to: Telemecanique - Schneider Electric Industries S.A.S
For: Manual AC Motor Starters 3 pole, with Thermal Magnetic "M" Tripping Units
Type: GV3M and GV3ME
TYPE APPROVAL CERTIFICATE No. 91/30302(E3)

The undernoted documents have been reviewed for compliance with the requirements of the Lloyd's Register Type Approval System, 2002 and this Design Appraisal Document forms part of the Certificate.

APPROVAL DOCUMENTATION

See previous documentation.

TEST REPORTS

See previous test reports.


Supplementary Type Approval Terms and Conditions

Type Approval certifies that a representative sample of the product(s) referred to herein has/have been found to meet the applicable design criteria for the use specified herein. It does not mean or imply approval for any other use, nor approval of any product(s) designed or manufactured otherwise than in strict conformity with the said representative sample.

Type Approval is based on the understanding that the manufacturer's recommendations and instructions and any relevant requirements of the Rules and Regulations are complied with.

Type Approval does not eliminate the need for normal inspection and survey procedures required by the Rules and Regulations.

Lloyd's Register EMEA reserves the right to cancel or withdraw this Type Approval Certificate in accordance with the Lloyd's Register Type Approval System Procedure.



W.J. Dijke
Senior Surveyor
Type Approval Department