

# TYPE APPROVAL CERTIFICATE

**This is to certify:****That the Circuit Breaker**

with type designation(s)  
**NG125a, NG125N, NG125H and NG125L**

Issued to  
**Schneider Electric Industries SAS**  
**GRENOBLE, France**

is found to comply with  
**DNV GL rules for classification – Ships, offshore units, and high speed and light craft**

**Application :****Miniature Circuit Breakers**

**Rated Voltage (V) 240 - 525**  
**Rated Current (A) 10 - 125**  
**Frequency (Hz) 50 - 60 and DC**

Issued at **Høvik** on **2017-04-17**

for **DNV GL**

This Certificate is valid until **2022-03-17**.

DNV GL local station: **DNV Marseille**

Approval Engineer: **Nicolay Horn**

**Andreas Kristoffersen**  
**Head of Section**

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.



### Name and Place of manufacturer

MERLIN GERIN ALES  
 ZI de Croupillac BP229  
 ALES - France

### Product description

Product type	Number of poles	Rated Voltage (V)	Courbes (*)	Maximum operating current (A)	Breaking Capacity (Ics = 75%Icu)	
					Icu/Ics (kA)	U (V)
NG125a	3, 3+N, 4	415	B, C, D	80 - 125A	30,7/23 kA	240V
					16/12 kA	415V
NG125N	1	240 / 415	B, C, D	10 - 80A	50,7/38 kA	130V
					25,3/19 kA	240V
					6,7/5 kA	415V
	2, 3, 3+N, 4	240/415/525	B, C, D	10 - 125A	50,7/38 kA	240V
					25,3/19 kA	415V
					8/6 kA	525V
NG125H	1	240	B, C, D	10 - 80A	70,7/53 kA	130V
					36/27 kA	240V
	2	240/415/525	B, C, D	10 - 80A	70,7/53 kA	240V
					36/27 kA	415V
					30,7/23 kA	440V
					12/9 kA	525V
	3, 3+N, 4	240/415/525	B, C, D	10 - 80A	70,7/53 kA	240V
					36/27 kA	415V
30,7/23 kA					440V	
10,7/8 kA					525V	
NG125L	1	240	B, C, D	10 - 80A	100/75 kA	130V
					50,7/38 kA	240V
	2	240/415/525	B, C, D	10 - 80A	100/75 kA	240V
					48/36 kA	415V
					40/30 kA	440V
					14,7/11 kA	525V
	3, 3+N, 4	240/415/525	B, C, D	10 - 80A	100/75 kA	240V
					48/36 kA	415V
40/30 kA					440V	
12/9 kA					525V	

(\*) Curves: B = Ii = 4In C = Ii = 8In D = Ii = 12In

Product type	Number of poles	Rated Voltage (V)	Courbes (*)	Maximum operating current (A)	Breaking Capacity (Ics = 75%Icu)	
					Icu / Ics (kA)	U (V)
NG125a	3	350	C	80 to 125	40	350
NG125N	1	125	C	10 to 80	25	125
	2	250	C	10 to 80	25	250
	4	500	C	10 to 125	25	500
	3+N	500	C	10 to 125	25	500
NG125H	1	125	C	10 to 80	36	125
	2	250	C	10 to 80	36	250
	4	500	C	10 to 80	36	500
	3+N	500	C	10 to 80	36	500
NG125L	1	125	C	10 to 80	50	125
	2	250	C	10 to 80	50	250
	4	500	C	10 to 80	50	500

(\*) Curve: **C = Ii = 8In**

### Application/Limitation

The manufacturer's instructions to be observed.

Suitable for use in an IT system with a capacity of 1.2 times the maximum trip current at 440 V AC (IEC 60947-2, Annex H).

### Type Approval documentation

Volta test report no. 201507225 00V1 dated 2015-02-01  
 Schneider Electric test reports no. RI\_201403643\_001 dated 2014-06-05, RI\_201401175\_001 dated 2014-03-11, RI\_201308108\_001 dated 2013-11-13 & RI\_201306955\_001 dated 2013-10-09.  
 TILVA test report no. C009-CB-2007CQC-013702-A1 issued 2007-12-12,  
 Test report No. 2007-0180-00 a issued 2007-03-27.  
 Schneider Electric Certification file NG125 dated 2001-06-28.

### Tests carried out

Type tests according to IEC 60947-2 (2006+A1:2009). Environmental test in accordance to "Guidelines for the Performance of Type Approvals (2003)".

### Marking of product

Schneider Electric – Multi 9 NG 125a, N, H, L – 415 V AC – 500 V DC – 10 to 125 Amps.

### Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval is complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)



Job Id: **262.1-007050-5**  
Certificate No: **TAE00001WC**

- Results from d Routines (RT) checked (if not available tests RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate

Periodical assessment to be performed at 2 and 3.5 years and at renewal.

END OF CERTIFICATE