

Firetrol Remote Alarm Panels

for Use With Diesel Engine and Electric Fire Pump Controllers

FTA200-A & FTA200-F

Specifications

1.0 Alarm Panel

The main fire pump controller shall be a factory assembled, wired and tested unit.

1.1 Standards, Listings & Approvals

The controller shall conform to all the requirements of the latest editions of:
NFPA 20, *Standard for the Installation of Stationary Pumps for Fire Protection*
NFPA 70, *National Electrical Code*.
Factory Mutual (FM)

The controller shall be listed by:

Underwriters Laboratories, Inc., in accordance with UL508, *Standard for Industrial Controls*
Canadian Standards Association CSA-C22.2, *Standard for Industrial Control Equipment (cUL)*

1.2 Enclosure

The controller components shall be housed in a NEMA Type 2 (IEC IP22) drip-proof, wall mounted enclosure.

1.3 Control Circuit

The alarm panel shall be low voltage DC and make use of printed circuit boards which can be easily wired together for future additional alarms.

1.4 Operation

The alarm panel shall have individual pilot lights to indicate its alarm condition which shall remain lighted until the alarm condition has been corrected. The alarm panel shall also have an audible alarm which will sound when the alarm conditions occur and may be silenced by pressing a SILENCE ALARM push-button.

Each alarm initiation shall be subsequent to any and all previous alarm conditions so that the silence push-button acknowledgment of any one alarm will not prevent the audible alarm from sounding on successive alarm conditions.

The alarm panel shall have a PUSH-TO-TEST push-button for manually testing all pilot lights, audible alarms and output circuits. All alarm pilot lights and push-buttons shall be plainly marked for identification.

2.6 Manufacturer

The alarm panel shall be a Firetrol model FTA200-A for use with electric fire pump controllers or model FTA200-F for use with diesel engine fire pump controllers.

111 Corning Road
Suite 120
Cary, North Carolina 27518
P +1 919 460 5200
F +1 919 460 5250
www.firetrol.com

ASCO Power
Technologies®

While every precaution has been taken to ensure accuracy and completeness herein, ASCO Power Technologies assumes no responsibility, and disclaims all liability, for damages resulting from use of this information or for any errors or omissions. Specifications and drawings are subject to change without notice. The ASCO, ASCO Power Services, and ASCO Power Technologies marks are owned by Emerson Electric Co. or its affiliates and utilized herein under license. ©2017. Printed in USA.

Publication SP200-50 Rev. B