



NOTES:

1. POWER WIRING AND CONTROL WIRING SHOULD BE SEGREGATED.
2. TO EXTEND THE BACKUP TIME, BATTERY CUBICLES CAN BE PARALLELED.
3. INSTALLATION MUST COMPLY WITH ALL APPLICABLE NATIONAL AND LOCAL CODES.

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF AMERICAN POWER CONVERSION AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM APC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.

TITLE: SILICON 240/320kW, UPS
 BATTERY CABINET, CABLING DIAGRAM
 (H3-2C STYLE)
 240/320kW, 400V
 PROJECT: SUBMITTAL DRAWINGS SHEET 1 OF 1

DWG NO: SLB240K320H3-2C-CD
 DRAWN: Bakarrurugun 23/07/01
 CHECKED: M. Lapard 23/07/01
 ENGINEER: P. Francis 23/07/01
 SCALE: NTS
 PROJECTION: 1st Angle

