

# Network Management Card 2 (NMC2) for InfraStruxure 150 kVA PDU with 84 Poles

Supported Products: PDPB150G6F

## What's in This Document

Schneider Electric Device IP Configuration Wizard.....	1
Affected Revision Levels .....	2
AOS & TCP/IP Stack Modifications (apc_hw05_aos_682.bin).....	2
InfraStruXure PDU Application for 150 kW 84 Pole Panel (apc_hw05_x84p_682.bin).....	4
Miscellaneous.....	5

## Schneider Electric Device IP Configuration Wizard

The Device IP Configuration Wizard is a Windows application designed specifically to remotely configure the basic TCP/IP settings of Network Management Cards. The Wizard runs on Windows® 2000, Windows 2003, Windows Vista, Windows XP, Windows 7, Windows Server 2008, Windows Server 2016, Windows 8, Windows 10 and Windows 2012. This utility supports cards that have firmware version 3.X.X or higher and is for IPv4 only.

Note: In firmware version AOSv6.8.2 and higher:

The Device IP Configuration Utility only supports the discovery of unassigned devices.

You cannot search for assigned devices already on the network using an IP range unless you enable SNMPv1 and set the Community Name to "public". For more information on SNMPv1, see the User Guide.

When the NMC IP address settings are configured, to access the NMC Web UI in a browser, you must update the URL from http to https.

The Wizard is available as a free download from the APC website at [www.apc.com](http://www.apc.com):

1. Go to [www.apc.com/tools/download](http://www.apc.com/tools/download) and select **Software Upgrades > Wizards and Configurators** from the **Filter by Software/Firmware** drop-down list.
2. Click **Submit** to view the list of utilities available for download.
3. Click on the **Download** button to download the **Device IP Configuration Wizard**.

## Affected Revision Levels

File	Detail
apc_hw05_aos_682.bin	Network Management Card Operating System & TCP/IP Stack
apc_hw05_x84p_682.bin	InfraStruXure PDU Application for 150 kW 84 Pole Panel
powernet431.mib	PowerNet(R) SNMP Management Information Base (MIB)

For details on upgrading the network management card firmware, see the user's guide on the utility CD or on the APC website ([www.apc.com](http://www.apc.com)).

## AOS & TCP/IP Stack Modifications (apc\_hw05\_aos\_682.bin)

### Compatibility

apc_hw05_x84p_682.bin	InfraStruXure PDU Application for 150 kW 84 Pole Panel
powernet431.mib	PowerNet(R) SNMP Management Information Base (MIB)

## Known Issues in This Version

1. SNMPv3 communication and monitoring on some third-party SNMP management tools such as ManageEngine OpManager does not work properly.
2. IPv6 connectivity outside of local subnet does not work in all environments.
3. Modifying large groups of event actions by severity may cause an unexpected network interface restart.
4. Device and Read-only users were getting disable after upgrade from 5.x.x to 6.8.2 f/w. This is due to the fact that the 5.x.x user database is completely different from the 6.8.2 user database.

## New Features and Enhancements

1. Security Updates: AOS v6.8.2 includes several security updates following new California State legislation (Senate Bill SB-327). These updates include: The default Super User password must be changed at first log in to the NMC. The Administrator, Device, Read-Only, and Network-Only user accounts are disabled by default, and cannot be enabled until the default Super User password is changed. New Protocol Status Overview page in the Web UI, and banner in the Command Line Interface (CLI). HTTPS and SSH are now the only protocols enabled by default. These changes will not affect existing customers upgrading to AOS v6.8.2. However, these changes will be the default settings for new customers, and existing customers running with AOS v6.8.2 who reset the NMC to its default values. For more information on these changes, refer <https://apc.com/secure-nmc>. Alternatively refer the 'Network Management Card 2' user guide available on HYPERLINK "<http://www.apc.com>" [www.apc.com](http://www.apc.com)

2. Remote Monitoring Service (RMS) complete removal.
3. Additional Modbus support for:
  - a. Serial Modbus Baud Rates: 2400 & 38400.
  - b. Modbus TCP Communication Timeout (Never, 1 to 64800 secs).

## Bugs Fixed in This Version

There is no longer a memory leak when requesting an SSL connection.

# InfraStruXure PDU Application for 150 kW 84 Pole Panel (apc\_hw05\_x84p\_682.bin)

## Compatibility

apc_hw05_aos_682.bin	Network management card OS & TCP/IP Stack
powernet431.mib	PowerNet(R) SNMP Management Information Base (MIB)

See *AOS & TCP/IP Stack Modifications (apc\_hw05\_aos\_682.bin)*, page 2 for a list of modifications and enhancements that affect this application version.

## Known Issues in This Version

1. In the PowerView display, while configuring Modbus serial, target ID is not retaining to the configured value.
2. Not all alarms are mappable to output relays.
3. In the serial interface, resetToDef command doesn't prompt the NMC to reboot due to which the command isn't behaving as intended. User needs to reboot the card manually (over pin reset) after "ResetToDef" command is issued.
4. Modbus serial communication with 2400 buad rate setting is not working after restarting the NMC. To mitigate this issue, User need to configure other baud rate (9600,19200, 38400) then re-configure it to 2400 after every NMC reboot.
5. Power View shows events in wrong order if log has more than 50 events.

## New Features and Enhancements

1. Added Support to EcoStruxure IT.
2. APC Monitoring Link is replaced with Schneider Electric Downloads. Note that RMS feature has been removed from v6.8.2 and above.

## Bugs Fixed in This Version

None.

## Miscellaneous

### Recovering From a Lost Password

See the User's Guide on the Utility CD or on the APC website ([www.apc.com](http://www.apc.com)) for instructions on how to recover from a lost password.

### Event Support List

For the event names and event codes for all events supported for a currently connected APC device, first retrieve the Config.ini file from a configured network management card.

To use FTP to retrieve the Config.ini file from a configured network management card:

1. Open a connection to the network management card, using its IP Address:  
ftp> open <ip\_address>
2. Log on using the Super User/Administrator user name and password.
3. Retrieve the Config.ini file containing the settings of the network management card of the UPS.  
ftp> get config.ini.

The file is written to the folder from which you launched FTP.

In the Config.ini file, find the section heading [EventActionConfig]. In the list of events under that section heading, substitute 0x for the initial E in the code for any event to obtain the hexadecimal event code shown in the user interface and in the documentation.

For example, the hexadecimal code for the code E0033 in the Config.ini file (for the event "System: Configuration change") is 0x0033.

### Powernet MIB Reference Guide

**NOTE:** The MIB Reference Guide, available on the network management card CD and on the APC website ([www.apc.com](http://www.apc.com)), explains the structure of the MIB, types of OIDs, and the procedure for defining trap receivers. For information on specific OIDs, use a MIB browser to view their definitions and available values directly from the MIB itself. You can view the definitions of traps at the end of the MIB itself (the file powernet431.mib on the network management card CD and also downloadable from the APC website, [www.apc.com](http://www.apc.com)).

### HASH Signatures

The following are hash signatures for the upgrade utility web download:

MD5 Hash: 48e7297701b26c30de6b9f457dbdd0bd

SHA-1 Hash: 8a943aa97d050926010ae3763afce2de62472011

SHA-256 Hash:

74b4d59533ac30c104a71a139de845c8670e095d1b8206e85a74ce913d2b6c46