

Easergy MiCOM P141

Feeder Management Relay

P141/EN MC/On8 - Ed. 1

Software Version	B6
Hardware Suffix	L
IEC61850 Edition	1
Issue Date	07/2020

Model Implementation Conformance Statement (MICS)

Note

The technical manual for this device gives instructions for its installation, commissioning, and operation. However, the manual cannot cover all conceivable circumstances or include detailed information on all topics. In the event of questions or specific problems, do not take any action without proper authorization. Contact the appropriate Schneider Electric technical sales office and request the necessary information.

Any agreements, commitments, and legal relationships and any obligations on the part of Schneider Electric including settlements of warranties, result solely from the applicable purchase contract, which is not affected by the contents of the technical manual.

This device **MUST NOT** be modified. If any modification is made without the express permission of Schneider Electric, it will invalidate the warranty, and may render the product unsafe.

Easergy MiCOM and the Schneider Electric logo and any alternative version thereof are trademarks and service marks of Schneider Electric.

All trade names or trademarks mentioned herein whether registered or not, are the property of their owners.

This manual is provided for informational use only and is subject to change without notice.

© 2019, Schneider Electric. All rights reserved.

**MODEL IMPLEMENTATION
CONFORMANCE STATEMENT
(MICS)**

Date (month/year):	07/2020
Products covered by this chapter:	This chapter covers the specific versions of the MiCOM products listed below. This includes only the following combinations of Software Version and Hardware Suffix.
Hardware suffix:	L
Software version:	B6
Connection diagrams:	This includes a list of the Connection Diagrams for the Products covered by this document. 10P141xx (xx = 01 to 07) 10P142xx (xx = 01 to 07) 10P143xx (xx = 01 to 07) 10P145xx (xx = 01 to 07)

CONTENTS

	Page-
1 Introduction	7
2 Objective	8
3 Logical Device Definitions	9
3.1 IEC61850 logical device data model	9
4 Logical Node Definitions	12
4.1 Logical Node: CILO_INTERLOCK	13
4.2 Logical Node: GGIO_ALM_96	13
4.3 Logical Node: GGIO_IND_128	15
4.4 Logical Node: GGIO_IND_16	19
4.5 Logical Node: GGIO_IND_32	19
4.6 Logical Node: GGIO_IND_32_CTRL	20
4.7 Logical Node: GGIO_IND_6	21
4.8 Logical Node: GGIO_IND_64	21
4.9 Logical Node: GGIO_IND_8	23
4.10 Logical Node: LLN0_PROT	23
4.11 Logical Node: LLN0_STANDARD	24
4.12 Logical Node: LLN0_SYSTEM	24
4.13 Logical Node: LPHD_STANDARD	24
4.14 Logical Node: MMTR_PRIV	25
4.15 Logical Node: MMXU_FOURIER	25
4.16 Logical Node: MMXU_RMS_P145	26
4.17 Logical Node: MMXU_SPEC	26
4.18 Logical Node: MSQI_ALL	27
4.19 Logical Node: MSTA_I_W_VAR	27
4.20 Logical Node: PDIF_NEU	27
4.21 Logical Node: PFRC_NO_SEG	28
4.22 Logical Node: PTOC_NEU	28
4.23 Logical Node: PTOC_NO_SEG	28
4.24 Logical Node: PTOC_SEG	28
4.25 Logical Node: PTOF_NO_SEG	29
4.26 Logical Node: PTOV_NEU	29
4.27 Logical Node: PTOV_NO_SEG	29
4.28 Logical Node: PTOV_SEG	29

4.29	Logical Node: PTRC_NO_SEG	30
4.30	Logical Node: PTTR_NO_SEG	30
4.31	Logical Node: PTUF_NO_SEG	30
4.32	Logical Node: PTUV_SEG	30
4.33	Logical Node: RBRF_EXTTRIP	31
4.34	Logical Node: RDRE_BASIC	31
4.35	Logical Node: RFLO_PRIV_NDB	31
4.36	Logical Node: XCBR_BASIC	32
<hr/>		
5	Common Data Class Definitions	34
5.1	Common Data Class: ACD_NEU	34
5.2	Common Data Class: ACD_NO_SEG	34
5.3	Common Data Class: ACD_SEG	35
5.4	Common Data Class: ACT_NEU	35
5.5	Common Data Class: ACT_NO_SEG	35
5.6	Common Data Class: ACT_SEG	35
5.7	Common Data Class: BCR_PRIV	36
5.8	Common Data Class: CMV_MAG_ANG_FLOAT	36
5.9	Common Data Class: CMV_MAG_FLOAT	36
5.10	Common Data Class: CMV_MAG_FLOAT_NDB	37
5.11	Common Data Class: DEL_SEG_ANG	37
5.12	Common Data Class: DEL_SEG_D_NS	37
5.13	Common Data Class: DPC_CTRL_PRIV_NS	37
5.14	Common Data Class: DPL_STANDARD	38
5.15	Common Data Class: INC_CTRL_PRIV_NS	38
5.16	Common Data Class: INC_MOD	38
5.17	Common Data Class: INS_BASIC	38
5.18	Common Data Class: INS_BEH	39
5.19	Common Data Class: INS_BEH_D_PRIV	39
5.20	Common Data Class: INS_CBCAP	39
5.21	Common Data Class: INS_D	39
5.22	Common Data Class: INS_D_NS	39
5.23	Common Data Class: INS_HEALTH	40
5.24	Common Data Class: LPL_LLNO	40
5.25	Common Data Class: LPL_LN	40
5.26	Common Data Class: MV_FLOAT	40
5.27	Common Data Class: MV_FLOAT_D	41
5.28	Common Data Class: MV_FLOAT_D_NS	41
5.29	Common Data Class: MV_FLOAT_D_NS_NDB	41

5.30	Common Data Class: MV_FLOAT_NDB	42
5.31	Common Data Class: MV_FLOAT_NS	42
5.32	Common Data Class: SEQ_MAG_ANG	42
5.33	Common Data Class: SPC_CONTROL_NS	43
5.34	Common Data Class: SPC_CTRL_PRV_NS	43
5.35	Common Data Class: SPC_STATUS	43
5.36	Common Data Class: SPS_D	44
5.37	Common Data Class: SPS_WD	44
5.38	Common Data Class: SPS_WD_PRIV	44
5.39	Common Data Class: WYE_INET	44
5.40	Common Data Class: WYE_RES_ANG_NS	44
5.41	Common Data Class: WYE_SEG	45
5.42	Common Data Class: WYE_SEG_D	45
5.43	Common Data Class: WYE_SEG_D_NS	45
5.44	Common Data Class: WYE_SEG_RES_D	45
5.45	Common Data Class: WYE_SEG_RES_NS	45
<hr/>		
6	Common Data Attribute Type Definitions	47
6.1	Component: AnalogueValue_Float	47
6.2	Component: Originator	47
6.3	Component: RangeConfig_Deadband	47
6.4	Component: Unit	47
6.5	Component: Unit_Multiplier	47
6.6	Component: Vector_Magnitude_Float	48
6.7	Component: Vector_MagnitudeAngle_Float	48
<hr/>		
7	Enumerated Type Definitions	49
7.1	Enumerated type: AddCause	49
7.2	Enumerated type: Beh	49
7.3	Enumerated type: Bypass	49
7.4	Enumerated type: CBOpCap	50
7.5	Enumerated type: ctlModel	50
7.6	Enumerated type: dir	50
7.7	Enumerated type: Health	50
7.8	Enumerated type: Mod	50
7.9	Enumerated type: multiplier	51
7.10	Enumerated type: orCategory	51
7.11	Enumerated type: seqT	51
7.12	Enumerated type: SIUnit	51

8	MMS Data-Type Conversions
----------	----------------------------------

54

Notes:

1 Introduction

This specification is the Model Implementation Conformance Statement (MICS) and presents the top-level IEC61850 data model that has been implemented. The definitions of all used Logical Nodes and their associated Common Data Classes, components and associated enumerated values are also included for completeness.

The reader is expected to be conversant with the terminology presented within the IEC61850 part 7 series of specifications.

2 Objective

This document is applicable for P141 with the firmware B6A. The MICS is conformant to the devices associated ICD (Substation Configuration Language) file: P141_____B6A.ICD, version V2.1, according to part 6 and part 7 of the IEC61850 standards.

The layouts of the presented tables within this document are conformant to the part 6 and 7 series of the IEC61850 standard specifications with the following exceptions:

- The "Trigger Options" field is not presented
- The "M/O" field is not present as the definitions are as deployed within the model
- An additional column "X" is used to signify MiCOM custom attributes

3 Logical Device Definitions

The MiCOM relay implements an IEC61850 server that can contain one or more Logical Devices. Each Logical Device contains a data model built from instances of specific Logical Nodes and must consist of at least an instance of the LPHD Logical Node (which is responsible for providing physical device information) and an instance of the LLN0 Logical Node (for addressing common issues across the Logical Device).

The IEC61850 data model is contained within the Logical Devices detailed in the table below. All MiCOM devices will name the supported Logical Devices consistently to ensure that data model variables with the same purpose will have the same name within each MiCOM server.

Logical Device	Comment/Usage
Control	P141 Controls Domain
Measurements	P141 Measurements Domain
Protection	P141 Protection Domain
Records	P141 Records Domain
System	P141 System Domain

3.1 IEC 61850 Logical Device Data Model

The IEC61850 Logical Device top-level data model consists of instances of Logical Nodes. The data model name for a Logical Node instance is constructed from an optional prefix (known as the wrapper), the Logical Node name, and an instance ID (or suffix).

The presented data model is in an alphabetically sorted order, rather than a logical order, because this is the natural order of the data when presented by a native MMS browser. (Higher level browsers can of course impart any ordering that they desire).

LD	LN Instance	LN Type	Description
Control			
	CILO1	CILO_INTERLOCK	XCBR Interlocking
	LLN0	LLN0_STANDARD	Controls Logical Device
	LPHD1	LPHD_STANDARD	Physical Device Information
Measurements	XCBR1	XCBR_BASIC	Circuit Breaker Monitoring
	LLN0	LLN0_STANDARD	Measurements Logical Device
	LPHD1	LPHD_STANDARD	Physical Device Information
	PriFouMMXU1	MMXU_FOURIER	Primary Fourier Measurements
	PriMMTR1	MMTR_PRIV	Primary based metering quantities
	PriMSQI1	MSQI_ALL	Primary Sequence Measurements
	PriMSTA1	MSTA_I_W_VAR	Primary Metering Statistics
	PriRmsMMXU1	MMXU_RMS_P145	Primary RMS Measurements
	PriSpeMMXU1	MMXU_SPEC	Primary Specific Measurements
	SecFouMMXU1	MMXU_FOURIER	Secondary Fourier Measurements
	SecMMTR1	MMTR_PRIV	Secondary based metering quantities
	SecMSQI1	MSQI_ALL	Secondary Sequence Measurements
	SecMSTA1	MSTA_I_W_VAR	Secondary Metering Statistics
SecRmsMMXU1	MMXU_RMS_P145	Secondary RMS Measurements	
SecSpeMMXU1	MMXU_SPEC	Secondary Specific Measurements	

LD	LN Instance	LN Type	Description
Protection			
	CbfRBRF1	RBRF_EXTTRIP	CB Fail 1
	CbfRBRF2	RBRF_EXTTRIP	CB Fail 2
	DfpPFRC1	PFRC_NO_SEG	df/dt> 1 Frequency Rate of Change
	DfpPFRC2	PFRC_NO_SEG	df/dt> 2 Frequency Rate of Change
	DfpPFRC3	PFRC_NO_SEG	df/dt> 3 Frequency Rate of Change
	DfpPFRC4	PFRC_NO_SEG	df/dt> 4 Frequency Rate of Change
	DfpPFRC5	PFRC_NO_SEG	df/dt> 5 Frequency Rate of Change
	DfpPFRC6	PFRC_NO_SEG	df/dt> 6 Frequency Rate of Change
	DfpPFRC7	PFRC_NO_SEG	df/dt> 7 Frequency Rate of Change
	DfpPFRC8	PFRC_NO_SEG	df/dt> 8 Frequency Rate of Change
	DfpPFRC9	PFRC_NO_SEG	df/dt> 9 Frequency Rate of Change
	EfdPTOC1	PTOC_NEU	IN2> 1 Earth Fault (Derived)
	EfdPTOC2	PTOC_NEU	IN2> 2 Earth Fault (Derived)
	EfdPTOC3	PTOC_NEU	IN2> 3 Earth Fault (Derived)
	EfdPTOC4	PTOC_NEU	IN2> 4 Earth Fault (Derived)
	EfmPTOC1	PTOC_NEU	IN1> 1 Earth Fault (Measured)
	EfmPTOC2	PTOC_NEU	IN1> 2 Earth Fault (Measured)
	EfmPTOC3	PTOC_NEU	IN1> 3 Earth Fault (Measured)
	EfmPTOC4	PTOC_NEU	IN1> 4 Earth Fault (Measured)
	FrqPTOF1	PTOF_NO_SEG	F> 1 Over Frequency
	FrqPTOF2	PTOF_NO_SEG	F> 2 Over Frequency
	FrqPTUF1	PTUF_NO_SEG	F< 1 Under Frequency
	FrqPTUF2	PTUF_NO_SEG	F< 2 Under Frequency
	FrqPTUF3	PTUF_NO_SEG	F< 3 Under Frequency
	FrqPTUF4	PTUF_NO_SEG	F< 4 Under Frequency
	LLN0	LLN0_PROT	Protection Logical Device
	LPHD1	LPHD_STANDARD	Physical Device Information
	NgcPTOC1	PTOC_NO_SEG	I2> 1 Negative Sequence
	NgcPTOC2	PTOC_NO_SEG	I2> 2 Negative Sequence
	NgcPTOC3	PTOC_NO_SEG	I2> 3 Negative Sequence
	NgcPTOC4	PTOC_NO_SEG	I2> 4 Negative Sequence
	NgvPTOV1	PTOV_NO_SEG	V2> 1 Negative Sequence
	OcpPTOC1	PTOC_SEG	I> 1 Overcurrent
	OcpPTOC2	PTOC_SEG	I> 2 Overcurrent
	OcpPTOC3	PTOC_SEG	I> 3 Overcurrent
	OcpPTOC4	PTOC_SEG	I> 4 Overcurrent
	OcpPTOC5	PTOC_SEG	I> 5 Overcurrent
	OcpPTOC6	PTOC_SEG	I> 6 Overcurrent
	PTRC1	PTRC_NO_SEG	Protection Trip Conditioning
	SenEftPTOC1	PTOC_NEU	ISEF> 1 Sensitive Earth Fault
	SenEftPTOC2	PTOC_NEU	ISEF> 2 Sensitive Earth Fault
	SenEftPTOC3	PTOC_NEU	ISEF> 3 Sensitive Earth Fault
	SenEftPTOC4	PTOC_NEU	ISEF> 4 Sensitive Earth Fault

LD	LN Instance	LN Type	Description
	SenRefPDIF1	PDIF_NEU	IREF> 1 Restricted Earth Fault
	ThmPTTR1	PTTR_NO_SEG	Thermal Overload
	VtpPhsPTOV1	PTOV_SEG	V> 1 Overvoltage
	VtpPhsPTOV2	PTOV_SEG	V> 2 Overvoltage
	VtpPhsPTUV1	PTUV_SEG	V< 1 Undervoltage
	VtpPhsPTUV2	PTUV_SEG	V< 2 Undervoltage
	VtpResPTOV1	PTOV_NEU	VN> 1 Residual Overvoltage
	VtpResPTOV2	PTOV_NEU	VN> 2 Residual Overvoltage
Records			
	LLN0	LLN0_STANDARD	Records Logical Device
	LPHD1	LPHD_STANDARD	Physical Device Information
	RDRE1	RDRE_BASIC	Disturbance Recorder
	RFLO1	RFLO_PRIV_NDB	Fault Record (including Fault Locator)
System			
	AlmGGIO1	GGIO_ALM_96	Alarms
	GosGGIO1	GGIO_IND_128	GOOSE Input Signals
	GosGGIO2	GGIO_IND_32	GOOSE Output Signals
	LedGGIO1	GGIO_IND_8	Red LED Signals
	LinkGGIO1	GGIO_IND_6	Link Status
	LLN0	LLN0_SYSTEM	System Logical Device
	LPHD1	LPHD_STANDARD	Physical Device Information
	OptGGIO1	GGIO_IND_16	Opto Inputs
	OrdRunGGIO1	GGIO_IND_64	Uniqueness of control "Order Running" indications for Control operations
	PloGGIO1	GGIO_IND_32_CTRL	Controllable Inputs
	RlyGGIO1	GGIO_IND_16	Output Contacts

4 Logical Node Definitions

The definition tables for each of the Logical Nodes in the top-level data model are presented in the following sub-sections.

The following table presents a summary of the Logical Node templates used across the Logical Devices within the overall IEC61850 product data model:

LN Type	(LN)	Description	Name Space
CILO_INTERLOCK	(CILO)	Control Interlocking	IEC 61850-7-4:2003
GGIO_IND_8	(GGIO)	Generic Process I/O (w.r.t 8 Indication Elements)	IEC 61850-7-4:2003
GGIO_ALM_96	(GGIO)	Generic Process I/O (w.r.t 96 Alarm Elements)	IEC 61850-7-4:2003
GGIO_IND_128	(GGIO)	Generic process I/O (w.r.t 128 Indication Elements)	IEC 61850-7-4:2003
GGIO_IND_16	(GGIO)	Generic Process I/O (w.r.t 16 Indication Elements)	IEC 61850-7-4:2003
GGIO_IND_32	(GGIO)	Generic Process I/O (w.r.t 32 Indication Elements)	IEC 61850-7-4:2003
GGIO_IND_32_CTRL	(GGIO)	Generic process I/O (w.r.t 32 Indications Ctrl i/p)	IEC 61850-7-4:2003
GGIO_IND_6	(GGIO)	Generic Process I/O (w.r.t 6 Indication Elements)	IEC 61850-7-4:2003
GGIO_IND_64	(GGIO)	Generic Process I/O (w.r.t 64 Indication Elements)	IEC 61850-7-4:2003
LLN0_SYSTEM	(LLN0)	System Logical Node 0	IEC 61850-7-4:2003
LLN0_PROT	(LLN0)	Protection Domain Logical Node 0	IEC 61850-7-4:2003
LLN0_STANDARD	(LLN0)	General Logical Node 0	IEC 61850-7-4:2003
LPHD_STANDARD	(LPHD)	Px40 Physical Device Information	IEC 61850-7-4:2003
MMTR_PRIV	(MMTR)	Metering	IEC 61850-7-4:2003
MMXU_FOURIER	(MMXU)	Standard measurements	IEC 61850-7-4:2003
MMXU_RMS_P145	(MMXU)	Standard measurements (w.r.t RMS Values - P145)	IEC 61850-7-4:2003
MMXU_SPEC	(MMXU)	Specific measurements	IEC 61850-7-4:2003
MSQI_ALL	(MSQI)	Sequence and imbalance (w.r.t Pos, Neg, Zero)	IEC 61850-7-4:2003
MSTA_I_W_VAR	(MSTA)	Metering Statistics (w.r.t Current, Real + Reactive Power - Average + Max values)	IEC 61850-7-4:2003
PDIF_NEU	(PDIF)	Differential (w.r.t Neutral)	IEC 61850-7-4:2003
PFRC_NO_SEG	(PFRC)	Rate of change of frequency (w.r.t No Phase Segregation)	IEC 61850-7-4:2003
PTOC_NEU	(PTOC)	Timed Overcurrent (w.r.t Neutral)	IEC 61850-7-4:2003
PTOC_NO_SEG	(PTOC)	Timed Overcurrent (w.r.t No Phase Segregation)	IEC 61850-7-4:2003
PTOC_SEG	(PTOC)	Timed Overcurrent (w.r.t Phase Segregation)	IEC 61850-7-4:2003
PTOF_NO_SEG	(PTOF)	Over frequency (w.r.t No Phase Segregation)	IEC 61850-7-4:2003
PTOV_NO_SEG	(PTOV)	Overvoltage (w.r.t Phase Segregation)	IEC 61850-7-4:2003
PTOV_SEG	(PTOV)	Overvoltage (w.r.t Phase Segregation)	IEC 61850-7-4:2003
PTOV_NEU	(PTOV)	Overvoltage (w.r.t Neutral)	IEC 61850-7-4:2003

LN Type	(LN)	Description	Name Space
PTRC_NO_SEG	(PTRC)	Protection trip conditioning (w.r.t No Phase Segregation)	IEC 61850-7-4:2003
PTTR_NO_SEG	(PTTR)	Thermal overload (w.r.t No Phase Segregation)	IEC 61850-7-4:2003
PTUF_NO_SEG	(PTUF)	Under frequency (w.r.t No Phase Segregation)	IEC 61850-7-4:2003
PTUV_SEG	(PTUV)	Undervoltage (w.r.t Phase Segregation)	IEC 61850-7-4:2003
RBRF_EXTTRIP	(RBRF)	Breaker Failure (w.r.t External Tripping)	IEC 61850-7-4:2003
RDRE_BASIC	(RDRE)	Disturbance Recorder function (w.r.t Mandatory Attributes only)	IEC 61850-7-4:2003
RFLO_PRIV_NDB	(RFLO)	Fault record values (including fault locator) without deadband and rangeC	IEC 61850-7-4:2003
XCBR_BASIC	(XCBR)	Circuit Breaker (w.r.t Mandatory Attributes Only)	IEC 61850-7-4:2003

4.1 Logical Node: CILO_INTERLOCK

Description: Control Interlocking

LN Class: CILO

Attribute	Attr. Type	Explanation	T	X
Mod	INC_MOD	Mode		
Beh	INS_BEH	Behaviour		
Health	INS_HEALTH	Health		
NamPlt	LPL_LN	Name Plate		
EnaOpn	SPS_WD	Enable OPEN Commands		
EnaCls	SPS_WD	Enable CLOSE Commands		

4.2 Logical Node: GGIO_ALM_96

Description: Generic Process I/O (w.r.t 96 Alarm Elements)

LN Class: GGIO

Attribute	Attr. Type	Explanation	T	X
Mod	INC_MOD	Mode		
Beh	INS_BEH	Behaviour		
Health	INS_HEALTH	Health		
NamPlt	LPL_LN	Name Plate		
Alm1	SPS_D	General single alarm		
Alm2	SPS_D	General single alarm		
Alm3	SPS_D	General single alarm		
Alm4	SPS_D	General single alarm		
Alm5	SPS_D	General single alarm		
Alm6	SPS_D	General single alarm		
Alm7	SPS_D	General single alarm		
Alm8	SPS_D	General single alarm		
Alm9	SPS_D	General single alarm		
Alm10	SPS_D	General single alarm		
Alm11	SPS_D	General single alarm		
Alm12	SPS_D	General single alarm		
Alm13	SPS_D	General single alarm		

Attribute	Attr. Type	Explanation	T	X
Alm14	SPS_D	General single alarm		
Alm15	SPS_D	General single alarm		
Alm16	SPS_D	General single alarm		
Alm17	SPS_D	General single alarm		
Alm18	SPS_D	General single alarm		
Alm19	SPS_D	General single alarm		
Alm20	SPS_D	General single alarm		
Alm21	SPS_D	General single alarm		
Alm22	SPS_D	General single alarm		
Alm23	SPS_D	General single alarm		
Alm24	SPS_D	General single alarm		
Alm25	SPS_D	General single alarm		
Alm26	SPS_D	General single alarm		
Alm27	SPS_D	General single alarm		
Alm28	SPS_D	General single alarm		
Alm29	SPS_D	General single alarm		
Alm30	SPS_D	General single alarm		
Alm31	SPS_D	General single alarm		
Alm32	SPS_D	General single alarm		
Alm33	SPS_D	General single alarm		
Alm34	SPS_D	General single alarm		
Alm35	SPS_D	General single alarm		
Alm36	SPS_D	General single alarm		
Alm37	SPS_D	General single alarm		
Alm38	SPS_D	General single alarm		
Alm39	SPS_D	General single alarm		
Alm40	SPS_D	General single alarm		
Alm41	SPS_D	General single alarm		
Alm42	SPS_D	General single alarm		
Alm43	SPS_D	General single alarm		
Alm44	SPS_D	General single alarm		
Alm45	SPS_D	General single alarm		
Alm46	SPS_D	General single alarm		
Alm47	SPS_D	General single alarm		
Alm48	SPS_D	General single alarm		
Alm49	SPS_D	General single alarm		
Alm50	SPS_D	General single alarm		
Alm51	SPS_D	General single alarm		
Alm52	SPS_D	General single alarm		
Alm53	SPS_D	General single alarm		
Alm54	SPS_D	General single alarm		
Alm55	SPS_D	General single alarm		
Alm56	SPS_D	General single alarm		
Alm57	SPS_D	General single alarm		

Attribute	Attr. Type	Explanation	T	X
Alm58	SPS_D	General single alarm		
Alm59	SPS_D	General single alarm		
Alm60	SPS_D	General single alarm		
Alm61	SPS_D	General single alarm		
Alm62	SPS_D	General single alarm		
Alm63	SPS_D	General single alarm		
Alm64	SPS_D	General single alarm		
Alm65	SPS_D	General single alarm		
Alm66	SPS_D	General single alarm		
Alm67	SPS_D	General single alarm		
Alm68	SPS_D	General single alarm		
Alm69	SPS_D	General single alarm		
Alm70	SPS_D	General single alarm		
Alm71	SPS_D	General single alarm		
Alm72	SPS_D	General single alarm		
Alm73	SPS_D	General single alarm		
Alm74	SPS_D	General single alarm		
Alm75	SPS_D	General single alarm		
Alm76	SPS_D	General single alarm		
Alm77	SPS_D	General single alarm		
Alm78	SPS_D	General single alarm		
Alm79	SPS_D	General single alarm		
Alm80	SPS_D	General single alarm		
Alm81	SPS_D	General single alarm		
Alm82	SPS_D	General single alarm		
Alm83	SPS_D	General single alarm		
Alm84	SPS_D	General single alarm		
Alm85	SPS_D	General single alarm		
Alm86	SPS_D	General single alarm		
Alm87	SPS_D	General single alarm		
Alm88	SPS_D	General single alarm		
Alm89	SPS_D	General single alarm		
Alm90	SPS_D	General single alarm		
Alm91	SPS_D	General single alarm		
Alm92	SPS_D	General single alarm		
Alm93	SPS_D	General single alarm		
Alm94	SPS_D	General single alarm		
Alm95	SPS_D	General single alarm		
Alm96	SPS_D	General single alarm		

4.3 Logical Node: GGIO_IND_128

Description: Generic process I/O (w.r.t 128 Indication Elements)

LN Class: GGIO

Attribute	Attr. Type	Explanation	T	X
Mod	INC_MOD	Mode		

Attribute	Attr. Type	Explanation	T	X
Beh	INS_BEH	Behaviour		
Health	INS_HEALTH	Health		
NamPlt	LPL_LN	Name Plate		
Ind1	SPS_D	General indication (binary input)		
Ind2	SPS_D	General indication (binary input)		
Ind3	SPS_D	General indication (binary input)		
Ind4	SPS_D	General indication (binary input)		
Ind5	SPS_D	General indication (binary input)		
Ind6	SPS_D	General indication (binary input)		
Ind7	SPS_D	General indication (binary input)		
Ind8	SPS_D	General indication (binary input)		
Ind9	SPS_D	General indication (binary input)		
Ind10	SPS_D	General indication (binary input)		
Ind11	SPS_D	General indication (binary input)		
Ind12	SPS_D	General indication (binary input)		
Ind13	SPS_D	General indication (binary input)		
Ind14	SPS_D	General indication (binary input)		
Ind15	SPS_D	General indication (binary input)		
Ind16	SPS_D	General indication (binary input)		
Ind17	SPS_D	General indication (binary input)		
Ind18	SPS_D	General indication (binary input)		
Ind19	SPS_D	General indication (binary input)		
Ind20	SPS_D	General indication (binary input)		
Ind21	SPS_D	General indication (binary input)		
Ind22	SPS_D	General indication (binary input)		
Ind23	SPS_D	General indication (binary input)		
Ind24	SPS_D	General indication (binary input)		
Ind25	SPS_D	General indication (binary input)		
Ind26	SPS_D	General indication (binary input)		
Ind27	SPS_D	General indication (binary input)		
Ind28	SPS_D	General indication (binary input)		
Ind29	SPS_D	General indication (binary input)		
Ind30	SPS_D	General indication (binary input)		
Ind31	SPS_D	General indication (binary input)		
Ind32	SPS_D	General indication (binary input)		
Ind33	SPS_D	General indication (binary input)		
Ind34	SPS_D	General indication (binary input)		
Ind35	SPS_D	General indication (binary input)		
Ind36	SPS_D	General indication (binary input)		
Ind37	SPS_D	General indication (binary input)		
Ind38	SPS_D	General indication (binary input)		
Ind39	SPS_D	General indication (binary input)		
Ind40	SPS_D	General indication (binary input)		
Ind41	SPS_D	General indication (binary input)		

Attribute	Attr. Type	Explanation	T	X
Ind42	SPS_D	General indication (binary input)		
Ind43	SPS_D	General indication (binary input)		
Ind44	SPS_D	General indication (binary input)		
Ind45	SPS_D	General indication (binary input)		
Ind46	SPS_D	General indication (binary input)		
Ind47	SPS_D	General indication (binary input)		
Ind48	SPS_D	General indication (binary input)		
Ind49	SPS_D	General indication (binary input)		
Ind50	SPS_D	General indication (binary input)		
Ind51	SPS_D	General indication (binary input)		
Ind52	SPS_D	General indication (binary input)		
Ind53	SPS_D	General indication (binary input)		
Ind54	SPS_D	General indication (binary input)		
Ind55	SPS_D	General indication (binary input)		
Ind56	SPS_D	General indication (binary input)		
Ind57	SPS_D	General indication (binary input)		
Ind58	SPS_D	General indication (binary input)		
Ind59	SPS_D	General indication (binary input)		
Ind60	SPS_D	General indication (binary input)		
Ind61	SPS_D	General indication (binary input)		
Ind62	SPS_D	General indication (binary input)		
Ind63	SPS_D	General indication (binary input)		
Ind64	SPS_D	General indication (binary input)		
Ind65	SPS_D	General indication (binary input)		
Ind66	SPS_D	General indication (binary input)		
Ind67	SPS_D	General indication (binary input)		
Ind68	SPS_D	General indication (binary input)		
Ind69	SPS_D	General indication (binary input)		
Ind70	SPS_D	General indication (binary input)		
Ind71	SPS_D	General indication (binary input)		
Ind72	SPS_D	General indication (binary input)		
Ind73	SPS_D	General indication (binary input)		
Ind74	SPS_D	General indication (binary input)		
Ind75	SPS_D	General indication (binary input)		
Ind76	SPS_D	General indication (binary input)		
Ind77	SPS_D	General indication (binary input)		
Ind78	SPS_D	General indication (binary input)		
Ind79	SPS_D	General indication (binary input)		
Ind80	SPS_D	General indication (binary input)		
Ind81	SPS_D	General indication (binary input)		
Ind82	SPS_D	General indication (binary input)		
Ind83	SPS_D	General indication (binary input)		
Ind84	SPS_D	General indication (binary input)		
Ind85	SPS_D	General indication (binary input)		

Attribute	Attr. Type	Explanation	T	X
Ind86	SPS_D	General indication (binary input)		
Ind87	SPS_D	General indication (binary input)		
Ind88	SPS_D	General indication (binary input)		
Ind89	SPS_D	General indication (binary input)		
Ind90	SPS_D	General indication (binary input)		
Ind91	SPS_D	General indication (binary input)		
Ind92	SPS_D	General indication (binary input)		
Ind93	SPS_D	General indication (binary input)		
Ind94	SPS_D	General indication (binary input)		
Ind95	SPS_D	General indication (binary input)		
Ind96	SPS_D	General indication (binary input)		
Ind97	SPS_D	General indication (binary input)		
Ind98	SPS_D	General indication (binary input)		
Ind99	SPS_D	General indication (binary input)		
Ind100	SPS_D	General indication (binary input)		
Ind101	SPS_D	General indication (binary input)		
Ind102	SPS_D	General indication (binary input)		
Ind103	SPS_D	General indication (binary input)		
Ind104	SPS_D	General indication (binary input)		
Ind105	SPS_D	General indication (binary input)		
Ind106	SPS_D	General indication (binary input)		
Ind107	SPS_D	General indication (binary input)		
Ind108	SPS_D	General indication (binary input)		
Ind109	SPS_D	General indication (binary input)		
Ind110	SPS_D	General indication (binary input)		
Ind111	SPS_D	General indication (binary input)		
Ind112	SPS_D	General indication (binary input)		
Ind113	SPS_D	General indication (binary input)		
Ind114	SPS_D	General indication (binary input)		
Ind115	SPS_D	General indication (binary input)		
Ind116	SPS_D	General indication (binary input)		
Ind117	SPS_D	General indication (binary input)		
Ind118	SPS_D	General indication (binary input)		
Ind119	SPS_D	General indication (binary input)		
Ind120	SPS_D	General indication (binary input)		
Ind121	SPS_D	General indication (binary input)		
Ind122	SPS_D	General indication (binary input)		
Ind123	SPS_D	General indication (binary input)		
Ind124	SPS_D	General indication (binary input)		
Ind125	SPS_D	General indication (binary input)		
Ind126	SPS_D	General indication (binary input)		
Ind127	SPS_D	General indication (binary input)		
Ind128	SPS_D	General indication (binary input)		

4.4 Logical Node: GGIO_IND_16

Description: Generic Process I/O (w.r.t 16 Indication Elements)
 LN Class: GGIO

Attribute	Attr. Type	Explanation	T	X
Mod	INC_MOD	Mode		
Beh	INS_BEH	Behaviour		
Health	INS_HEALTH	Health		
NamPlt	LPL_LN	Name Plate		
Ind1	SPS_D	General indication (binary input)		
Ind2	SPS_D	General indication (binary input)		
Ind3	SPS_D	General indication (binary input)		
Ind4	SPS_D	General indication (binary input)		
Ind5	SPS_D	General indication (binary input)		
Ind6	SPS_D	General indication (binary input)		
Ind7	SPS_D	General indication (binary input)		
Ind8	SPS_D	General indication (binary input)		
Ind9	SPS_D	General indication (binary input)		
Ind10	SPS_D	General indication (binary input)		
Ind11	SPS_D	General indication (binary input)		
Ind12	SPS_D	General indication (binary input)		
Ind13	SPS_D	General indication (binary input)		
Ind14	SPS_D	General indication (binary input)		
Ind15	SPS_D	General indication (binary input)		
Ind16	SPS_D	General indication (binary input)		

4.5 Logical Node: GGIO_IND_32

Description: Generic Process I/O (w.r.t 32 Indication Elements)
 LN Class: GGIO

Attribute	Attr. Type	Explanation	T	X
Mod	INC_MOD	Mode		
Beh	INS_BEH	Behaviour		
Health	INS_HEALTH	Health		
NamPlt	LPL_LN	Name Plate		
Ind1	SPS_D	General indication (binary input)		
Ind2	SPS_D	General indication (binary input)		
Ind3	SPS_D	General indication (binary input)		
Ind4	SPS_D	General indication (binary input)		
Ind5	SPS_D	General indication (binary input)		
Ind6	SPS_D	General indication (binary input)		
Ind7	SPS_D	General indication (binary input)		
Ind8	SPS_D	General indication (binary input)		
Ind9	SPS_D	General indication (binary input)		
Ind10	SPS_D	General indication (binary input)		
Ind11	SPS_D	General indication (binary input)		
Ind12	SPS_D	General indication (binary input)		

Attribute	Attr. Type	Explanation	T	X
Ind13	SPS_D	General indication (binary input)		
Ind14	SPS_D	General indication (binary input)		
Ind15	SPS_D	General indication (binary input)		
Ind16	SPS_D	General indication (binary input)		
Ind17	SPS_D	General indication (binary input)		
Ind18	SPS_D	General indication (binary input)		
Ind19	SPS_D	General indication (binary input)		
Ind20	SPS_D	General indication (binary input)		
Ind21	SPS_D	General indication (binary input)		
Ind22	SPS_D	General indication (binary input)		
Ind23	SPS_D	General indication (binary input)		
Ind24	SPS_D	General indication (binary input)		
Ind25	SPS_D	General indication (binary input)		
Ind26	SPS_D	General indication (binary input)		
Ind27	SPS_D	General indication (binary input)		
Ind28	SPS_D	General indication (binary input)		
Ind29	SPS_D	General indication (binary input)		
Ind30	SPS_D	General indication (binary input)		
Ind31	SPS_D	General indication (binary input)		
Ind32	SPS_D	General indication (binary input)		

4.6 Logical Node: GGIO_IND_32_CTRL

Description: Generic process I/O (w.r.t 32 Indications Ctrl i/p)
LN Class: GGIO

Attribute	Attr. Type	Explanation	T	X
Mod	INC_MOD	Mode		
Beh	INS_BEH	Behaviour		
Health	INS_HEALTH	Health		
NamPlt	LPL_LN	Name Plate		
SPCSO1	SPC_CONTROL_NS	Single point controllable status output		
SPCSO2	SPC_CONTROL_NS	Single point controllable status output		
SPCSO3	SPC_CONTROL_NS	Single point controllable status output		
SPCSO4	SPC_CONTROL_NS	Single point controllable status output		
SPCSO5	SPC_CONTROL_NS	Single point controllable status output		
SPCSO6	SPC_CONTROL_NS	Single point controllable status output		
SPCSO7	SPC_CONTROL_NS	Single point controllable status output		
SPCSO8	SPC_CONTROL_NS	Single point controllable status output		
SPCSO9	SPC_CONTROL_NS	Single point controllable status output		
SPCSO10	SPC_CONTROL_NS	Single point controllable status output		
SPCSO11	SPC_CONTROL_NS	Single point controllable status output		
SPCSO12	SPC_CONTROL_NS	Single point controllable status output		
SPCSO13	SPC_CONTROL_NS	Single point controllable status output		
SPCSO14	SPC_CONTROL_NS	Single point controllable status output		
SPCSO15	SPC_CONTROL_NS	Single point controllable status output		
SPCSO16	SPC_CONTROL_NS	Single point controllable status output		

Attribute	Attr. Type	Explanation	T	X
SPCSO17	SPC_CONTROL_NS	Single point controllable status output		
SPCSO18	SPC_CONTROL_NS	Single point controllable status output		
SPCSO19	SPC_CONTROL_NS	Single point controllable status output		
SPCSO20	SPC_CONTROL_NS	Single point controllable status output		
SPCSO21	SPC_CONTROL_NS	Single point controllable status output		
SPCSO22	SPC_CONTROL_NS	Single point controllable status output		
SPCSO23	SPC_CONTROL_NS	Single point controllable status output		
SPCSO24	SPC_CONTROL_NS	Single point controllable status output		
SPCSO25	SPC_CONTROL_NS	Single point controllable status output		
SPCSO26	SPC_CONTROL_NS	Single point controllable status output		
SPCSO27	SPC_CONTROL_NS	Single point controllable status output		
SPCSO28	SPC_CONTROL_NS	Single point controllable status output		
SPCSO29	SPC_CONTROL_NS	Single point controllable status output		
SPCSO30	SPC_CONTROL_NS	Single point controllable status output		
SPCSO31	SPC_CONTROL_NS	Single point controllable status output		
SPCSO32	SPC_CONTROL_NS	Single point controllable status output		

4.7 Logical Node: GGIO_IND_6

Description: Generic Process I/O (w.r.t 6 Indication Elements)
 LN Class: GGIO

Attribute	Attr. Type	Explanation	T	X
Mod	INC_MOD	Mode		
Beh	INS_BEH	Behaviour		
Health	INS_HEALTH	Health		
NamPlt	LPL_LN	Name Plate		
Ind1	SPS_D	General indication (binary input)		
Ind2	SPS_D	General indication (binary input)		
Ind3	SPS_D	General indication (binary input)		
Ind4	SPS_D	General indication (binary input)		
Ind5	SPS_D	General indication (binary input)		
Ind6	SPS_D	General indication (binary input)		

4.8 Logical Node: GGIO_IND_64

Description: Generic Process I/O (w.r.t 64 Indication Elements)
 LN Class: GGIO

Attribute	Attr. Type	Explanation	T	X
Mod	INC_MOD	Mode		
Beh	INS_BEH	Behaviour		
Health	INS_HEALTH	Health		
NamPlt	LPL_LN	Name Plate		
Ind1	SPS_D	General indication (binary input)		
Ind2	SPS_D	General indication (binary input)		
Ind3	SPS_D	General indication (binary input)		
Ind4	SPS_D	General indication (binary input)		
Ind5	SPS_D	General indication (binary input)		

Attribute	Attr. Type	Explanation	T	X
Ind6	SPS_D	General indication (binary input)		
Ind7	SPS_D	General indication (binary input)		
Ind8	SPS_D	General indication (binary input)		
Ind9	SPS_D	General indication (binary input)		
Ind10	SPS_D	General indication (binary input)		
Ind11	SPS_D	General indication (binary input)		
Ind12	SPS_D	General indication (binary input)		
Ind13	SPS_D	General indication (binary input)		
Ind14	SPS_D	General indication (binary input)		
Ind15	SPS_D	General indication (binary input)		
Ind16	SPS_D	General indication (binary input)		
Ind17	SPS_D	General indication (binary input)		
Ind18	SPS_D	General indication (binary input)		
Ind19	SPS_D	General indication (binary input)		
Ind20	SPS_D	General indication (binary input)		
Ind21	SPS_D	General indication (binary input)		
Ind22	SPS_D	General indication (binary input)		
Ind23	SPS_D	General indication (binary input)		
Ind24	SPS_D	General indication (binary input)		
Ind25	SPS_D	General indication (binary input)		
Ind26	SPS_D	General indication (binary input)		
Ind27	SPS_D	General indication (binary input)		
Ind28	SPS_D	General indication (binary input)		
Ind29	SPS_D	General indication (binary input)		
Ind30	SPS_D	General indication (binary input)		
Ind31	SPS_D	General indication (binary input)		
Ind32	SPS_D	General indication (binary input)		
Ind33	SPS_D	General indication (binary input)		
Ind34	SPS_D	General indication (binary input)		
Ind35	SPS_D	General indication (binary input)		
Ind36	SPS_D	General indication (binary input)		
Ind37	SPS_D	General indication (binary input)		
Ind38	SPS_D	General indication (binary input)		
Ind39	SPS_D	General indication (binary input)		
Ind40	SPS_D	General indication (binary input)		
Ind41	SPS_D	General indication (binary input)		
Ind42	SPS_D	General indication (binary input)		
Ind43	SPS_D	General indication (binary input)		
Ind44	SPS_D	General indication (binary input)		
Ind45	SPS_D	General indication (binary input)		
Ind46	SPS_D	General indication (binary input)		
Ind47	SPS_D	General indication (binary input)		
Ind48	SPS_D	General indication (binary input)		
Ind49	SPS_D	General indication (binary input)		

Attribute	Attr. Type	Explanation	T	X
Ind50	SPS_D	General indication (binary input)		
Ind51	SPS_D	General indication (binary input)		
Ind52	SPS_D	General indication (binary input)		
Ind53	SPS_D	General indication (binary input)		
Ind54	SPS_D	General indication (binary input)		
Ind55	SPS_D	General indication (binary input)		
Ind56	SPS_D	General indication (binary input)		
Ind57	SPS_D	General indication (binary input)		
Ind58	SPS_D	General indication (binary input)		
Ind59	SPS_D	General indication (binary input)		
Ind60	SPS_D	General indication (binary input)		
Ind61	SPS_D	General indication (binary input)		
Ind62	SPS_D	General indication (binary input)		
Ind63	SPS_D	General indication (binary input)		
Ind64	SPS_D	General indication (binary input)		

4.9 Logical Node: GGIO_IND_8

Description: Generic Process I/O (w.r.t 8 Indication Elements)
 LN Class: GGIO

Attribute	Attr. Type	Explanation	T	X
Mod	INC_MOD	Mode		
Beh	INS_BEH	Behaviour		
Health	INS_HEALTH	Health		
NamPlt	LPL_LN	Name Plate		
Ind1	SPS_D	General indication (binary input)		
Ind2	SPS_D	General indication (binary input)		
Ind3	SPS_D	General indication (binary input)		
Ind4	SPS_D	General indication (binary input)		
Ind5	SPS_D	General indication (binary input)		
Ind6	SPS_D	General indication (binary input)		
Ind7	SPS_D	General indication (binary input)		
Ind8	SPS_D	General indication (binary input)		

4.10 Logical Node: LLN0_PROT

Description: Protection Domain Logical Node 0
 LN Class: LLN0

Attribute	Attr. Type	Explanation	T	X
Mod	INC_MOD	Mode		
Beh	INS_BEH	Behaviour		
Health	INS_HEALTH	Health		
NamPlt	LPL_LLNO	Name Plate		
OcpMod	INC_CTRL_PRV_NS	Overcurrent Mode		
OcpBeh	INS_BEH_D_PRIV	Overcurrent Behaviour		
NgcMod	INC_CTRL_PRV_NS	Negative Sequence Mode		
NgcBeh	INS_BEH_D_PRIV	Negative Sequence Behaviour		

Attribute	Attr. Type	Explanation	T	X
EfmMod	INC_CTRL_PRV_NS	Earth Fault 1 (Measured) Mode		
EfmBeh	INS_BEH_D_PRIV	Earth Fault 1 (Measured) Behaviour		
EfdMod	INC_CTRL_PRV_NS	Earth Fault 2 (Derived) Mode		
EfdBeh	INS_BEH_D_PRIV	Earth Fault 2 (Derived) Behaviour		
SenMod	INC_CTRL_PRV_NS	SEF/REF Mode		
SenBeh	INS_BEH_D_PRIV	SEF/REF Behaviour		
VtpMod	INC_CTRL_PRV_NS	Overvoltage/Undervoltage Mode		
VtpBeh	INS_BEH_D_PRIV	Overvoltage/Undervoltage Behaviour		
NvdMod	INC_CTRL_PRV_NS	Residual Overvoltage NVD Mode		
NvdBeh	INS_BEH_D_PRIV	Residual Overvoltage NVD Behaviour		
NgvMod	INC_CTRL_PRV_NS	Negative Sequence Overvoltage Mode		
NgvBeh	INS_BEH_D_PRIV	Negative Sequence Overvoltage Behaviour		
FrqMod	INC_CTRL_PRV_NS	Overfrequency/Underfrequency Mode		
FrqBeh	INS_BEH_D_PRIV	Overfrequency/Underfrequency Behaviour		
ThmMod	INC_CTRL_PRV_NS	Thermal Overload Mode		
ThmBeh	INS_BEH_D_PRIV	Thermal Overload Behaviour		
CbfMod	INC_CTRL_PRV_NS	CB Fail Mode		
CbfBeh	INS_BEH_D_PRIV	CB Fail Behaviour		

4.11 Logical Node: LLN0_STANDARD

Description: General Logical Node 0

LN Class: LLN0

Attribute	Attr. Type	Explanation	T	X
Mod	INC_MOD	Mode		
Beh	INS_BEH	Behaviour		
Health	INS_HEALTH	Health		
NamPlt	LPL_LLNO	Name Plate		

4.12 Logical Node: LLN0_SYSTEM

Description: System Logical Node 0

LN Class: LLN0

Attribute	Attr. Type	Explanation	T	X
Mod	INC_MOD	Mode		
Beh	INS_BEH	Behaviour		
Health	INS_HEALTH	Health		
NamPlt	LPL_LLNO	Name Plate		
LEDRs	SPC_CONTROL_NS	LED reset	T	
OrdRun	SPS_WD_PRIV	Indicate IED is operating a control object		X
SyncSt	SPS_WD_PRIV	Indicate time synchronisation in the IED is active/inactive		X

4.13 Logical Node: LPHD_STANDARD

Description: Px40 Physical Device Information

LN Class: LPHD

Attribute	Attr. Type	Explanation	T	X
PhyNam	DPL_STANDARD	Physical device name plate		

Attribute	Attr. Type	Explanation	T	X
PhyHealth	INS_HEALTH	Physical device health		
Proxy	SPS_D	Indicates if this LN is a proxy		
PwrUp	SPS_D	Power up detected		

4.14 Logical Node: MMTR_PRIV

Description: Metering
LN Class: MMTR

Attribute	Attr. Type	Explanation	T	X
Mod	INC_MOD	Mode		
Beh	INS_BEH	Behaviour		
Health	INS_HEALTH	Health		
NamPlt	LPL_LN	Name Plate		
SupWh	BCR_PRIV	Real energy supply (Energy flow towards bus bar)		
SupVArh	BCR_PRIV	Reactive energy supply (Energy flow towards bus bar)		
DmdWh	BCR_PRIV	Real energy demand (Energy flow from bus bar)		
DmdVArh	BCR_PRIV	Reactive energy demand (Energy flow from bus bar)		
MTRRs	SPC_CTRL_PRIV_NS	Reset Energy Meters		X

4.15 Logical Node: MMXU_FOURIER

Description: Standard measurements
LN Class: MMXU

Attribute	Attr. Type	Explanation	T	X
Mod	INC_MOD	Mode		
Beh	INS_BEH	Behaviour		
Health	INS_HEALTH	Health		
NamPlt	LPL_LN	Name Plate		
TotW	MV_FLOAT	Total active power (Total P)		
TotVAr	MV_FLOAT	Total reactive power (Total Q)		
TotVA	MV_FLOAT	Total apparent power (Total S)		
TotPF	MV_FLOAT	Average power factor (Total PF)		
Hz	MV_FLOAT	Frequency		
PPV	DEL_SEG_ANG	Phase to Phase voltages		
PhV	WYE_SEG_RES_D	Phase to Ground voltages		
W	WYE_SEG	Phase active power (P)		
VAr	WYE_SEG	Phase reactive power (Q)		
VA	WYE_SEG	Phase apparent power (S)		
PF	WYE_SEG	Phase power factor		
A1	WYE_SEG_RES_NS	Phase currents (Fourier Magnitudes)		X
A2	WYE_RES_ANG_NS	Phase currents (IN Measured)		X
A3	WYE_RES_ANG_NS	Phase currents (ISEF Magnitude)		X
I1	MV_FLOAT_NS	I1 Magnitude		X
I2	MV_FLOAT_NS	I2 Magnitude		X
I0	MV_FLOAT_NS	I0 Magnitude		X
V1	MV_FLOAT_NS	V1 Magnitude		X
V2	MV_FLOAT_NS	V2 Magnitude		X

Attribute	Attr. Type	Explanation	T	X
V0	MV_FLOAT_NS	V0 Magnitude		X

4.16 Logical Node: MMXU_RMS_P145

Description: Standard measurements (w.r.t RMS Values - P145)

LN Class: MMXU

Attribute	Attr. Type	Explanation	T	X
Mod	INC_MOD	Mode		
Beh	INS_BEH	Behaviour		
Health	INS_HEALTH	Health		
NamPlt	LPL_LN	Name Plate		
PhV	WYE_SEG_D	Phase to Ground voltages		
A	WYE_SEG_D	Phase currents		

4.17 Logical Node: MMXU_SPEC

Description: Specific measurements

LN Class: MMXU

Attribute	Attr. Type	Explanation	T	X
Mod	INC_MOD	Mode		
Beh	INS_BEH	Behaviour		
Health	INS_HEALTH	Health		
NamPlt	LPL_LN	Name Plate		
AphW	MV_FLOAT_D_NS	Aph Sensitive Watts		X
AphVar	MV_FLOAT_D_NS	Aph Sensitive VARs		X
AphAng	MV_FLOAT_D_NS	Aph Power Angle		X
BEf	MV_FLOAT_D_NS	Susceptance EF		X
BSef	MV_FLOAT_D_NS	Susceptance SEF		X
DfDt	MV_FLOAT_D_NS	df/dt		X
GEf	MV_FLOAT_D_NS	Conductance EF		X
GSef	MV_FLOAT_D_NS	Conductance SEF		X
IA2nd	MV_FLOAT_D_NS	IA 2nd Harmonic		X
IB2nd	MV_FLOAT_D_NS	IB 2nd Harmonic		X
IC2nd	MV_FLOAT_D_NS	IC 2nd Harmonic		X
WSef	MV_FLOAT_D_NS	SEF Power		X
YEf	MV_FLOAT_D_NS	Admittance EF		X
YSef	MV_FLOAT_D_NS	Admittance SEF		X
ZAMag	MV_FLOAT_D_NS	Phase A Impedance Magnitude		X
ZAAng	MV_FLOAT_D_NS	Phase A Impedance Angle		X
ZBMag	MV_FLOAT_D_NS	Phase B Impedance Magnitude		X
ZBAng	MV_FLOAT_D_NS	Phase B Impedance Angle		X
ZCMag	MV_FLOAT_D_NS	Phase C Impedance Magnitude		X
ZCAng	MV_FLOAT_D_NS	Phase C Impedance Angle		X
ZposMag	MV_FLOAT_D_NS	Positive sequence Impedance Magnitude		X
ZposAng	MV_FLOAT_D_NS	Positive Sequence Impedance Angle		X

4.18 Logical Node: MSQI_ALL

Description: Sequence and imbalance (w.r.t Pos, Neg, Zero)
 LN Class: MSQI

Attribute	Attr. Type	Explanation	T	X
Mod	INC_MOD	Mode		
Beh	INS_BEH	Behaviour		
Health	INS_HEALTH	Health		
NamPlt	LPL_LN	Name Plate		
SeqA	SEQ_MAG_ANG	Positive, Negative and Zero sequence current		
SeqV	SEQ_MAG_ANG	Positive, Negative and Zero sequence voltage		
ImbNgA	MV_FLOAT	Imbalance negative sequence current		

4.19 Logical Node: MSTA_I_W_VAR

Description: Metering Statistics (w.r.t Current, Real + Reactive Power - Average + Max values)
 LN Class: MSTA

Attribute	Attr. Type	Explanation	T	X
Mod	INC_MOD	Mode		
Beh	INS_BEH	Behaviour		
Health	INS_HEALTH	Health		
NamPlt	LPL_LN	Name Plate		
AvAmps1	MV_FLOAT_D	Average current		
AvAmps2	MV_FLOAT_D	Average current		
AvAmps3	MV_FLOAT_D	Average current		
AvAmps4	MV_FLOAT_D	Average current		
AvAmps5	MV_FLOAT_D	Average current		
AvAmps6	MV_FLOAT_D	Average current		
MaxAmps1	MV_FLOAT_D	Maximum current		
MaxAmps2	MV_FLOAT_D	Maximum current		
MaxAmps3	MV_FLOAT_D	Maximum current		
AvW1	MV_FLOAT_D	Average real power		
AvW2	MV_FLOAT_D	Average real power		
MaxW	MV_FLOAT_D	Maximum real power		
AvVAR1	MV_FLOAT_D	Average reactive power		
AvVAR2	MV_FLOAT_D	Average reactive power		
MaxVAR	MV_FLOAT_D	Maximum reactive power		

4.20 Logical Node: PDIF_NEU

Description: Differential (w.r.t Neutral)
 LN Class: PDIF

Attribute	Attr. Type	Explanation	T	X
Mod	INC_MOD	Mode		
Beh	INS_BEH	Behaviour		
Health	INS_HEALTH	Health		
NamPlt	LPL_LN	Name Plate		
Op	ACT_NEU	Operate	T	

Attribute	Attr. Type	Explanation	T	X
DifACIc	WYE_INET	Differential current		
RstA	WYE_INET	Restraint current		

4.21 Logical Node: PFRC_NO_SEG

Description: Rate of change of frequency (w.r.t No Phase Segregation)
LN Class: PFRC

Attribute	Attr. Type	Explanation	T	X
Mod	INC_MOD	Mode		
Beh	INS_BEH	Behaviour		
Health	INS_HEALTH	Health		
NamPlt	LPL_LN	Name Plate		
Str	ACD_NO_SEG	Start		
Op	ACT_NO_SEG	Operate	T	

4.22 Logical Node: PTOC_NEU

Description: Timed Overcurrent (w.r.t Neutral)
LN Class: PTOC

Attribute	Attr. Type	Explanation	T	X
Mod	INC_MOD	Mode		
Beh	INS_BEH	Behaviour		
Health	INS_HEALTH	Health		
NamPlt	LPL_LN	Name Plate		
Str	ACD_NEU	Start		
Op	ACT_NEU	Operate	T	

4.23 Logical Node: PTOC_NO_SEG

Description: Timed Overcurrent (w.r.t No Phase Segregation)
LN Class: PTOC

Attribute	Attr. Type	Explanation	T	X
Mod	INC_MOD	Mode		
Beh	INS_BEH	Behaviour		
Health	INS_HEALTH	Health		
NamPlt	LPL_LN	Name Plate		
Str	ACD_NO_SEG	Start		
Op	ACT_NO_SEG	Operate	T	

4.24 Logical Node: PTOC_SEG

Description: Timed Overcurrent (w.r.t Phase Segregation)
LN Class: PTOC

Attribute	Attr. Type	Explanation	T	X
Mod	INC_MOD	Mode		
Beh	INS_BEH	Behaviour		
Health	INS_HEALTH	Health		
NamPlt	LPL_LN	Name Plate		
Str	ACD_SEG	Start		

Attribute	Attr. Type	Explanation	T	X
Op	ACT_SEG	Operate	T	

4.25 Logical Node: PTOF_NO_SEG

Description: Over frequency (w.r.t No Phase Segregation)

LN Class: PTOF

Attribute	Attr. Type	Explanation	T	X
Mod	INC_MOD	Mode		
Beh	INS_BEH	Behaviour		
Health	INS_HEALTH	Health		
NamPlt	LPL_LN	Name Plate		
Str	ACD_NO_SEG	Start		
Op	ACT_NO_SEG	Operate	T	

4.26 Logical Node: PTOV_NEU

Description: Overvoltage (w.r.t Neutral)

LN Class: PTOV

Attribute	Attr. Type	Explanation	T	X
Mod	INC_MOD	Mode		
Beh	INS_BEH	Behaviour		
Health	INS_HEALTH	Health		
NamPlt	LPL_LN	Name Plate		
Str	ACD_NEU	Start		
Op	ACT_NEU	Operate	T	

4.27 Logical Node: PTOV_NO_SEG

Description: Overvoltage (w.r.t Phase Segregation)

LN Class: PTOV

Attribute	Attr. Type	Explanation	T	X
Mod	INC_MOD	Mode		
Beh	INS_BEH	Behaviour		
Health	INS_HEALTH	Health		
NamPlt	LPL_LN	Name Plate		
Str	ACD_NO_SEG	Start		
Op	ACT_NO_SEG	Operate	T	

4.28 Logical Node: PTOV_SEG

Description: Overvoltage (w.r.t Phase Segregation)

LN Class: PTOV

Attribute	Attr. Type	Explanation	T	X
Mod	INC_MOD	Mode		
Beh	INS_BEH	Behaviour		
Health	INS_HEALTH	Health		
NamPlt	LPL_LN	Name Plate		
Str	ACD_SEG	Start		
Op	ACT_SEG	Operate	T	

4.29 Logical Node: PTRC_NO_SEG

Description: Protection trip conditioning (w.r.t No Phase Segregation)
LN Class: PTRC

Attribute	Attr. Type	Explanation	T	X
Mod	INC_MOD	Mode		
Beh	INS_BEH	Behaviour		
Health	INS_HEALTH	Health		
NamPlt	LPL_LN	Name Plate		
Tr	ACT_NO_SEG	Trip		
Str	ACD_NO_SEG	Sum of all starts of all connected Logical Nodes		

4.30 Logical Node: PTTR_NO_SEG

Description: Thermal overload (w.r.t No Phase Segregation)
LN Class: PTTR

Attribute	Attr. Type	Explanation	T	X
Mod	INC_MOD	Mode		
Beh	INS_BEH	Behaviour		
Health	INS_HEALTH	Health		
NamPlt	LPL_LN	Name Plate		
Amp	MV_FLOAT	Current for thermal load model		
TmpRI	MV_FLOAT	Relation between temperature and maximum temperature		
Op	ACT_NO_SEG	Operate	T	
MTRRs	SPC_CTRL_PRV_NS	Reset Thermal State		X
AlmThm	SPS_WD	Thermal alarm	T	

4.31 Logical Node: PTUF_NO_SEG

Description: Under frequency (w.r.t No Phase Segregation)
LN Class: PTUF

Attribute	Attr. Type	Explanation	T	X
Mod	INC_MOD	Mode		
Beh	INS_BEH	Behaviour		
Health	INS_HEALTH	Health		
NamPlt	LPL_LN	Name Plate		
Str	ACD_NO_SEG	Start		
Op	ACT_NO_SEG	Operate	T	

4.32 Logical Node: PTUV_SEG

Description: Undervoltage (w.r.t Phase Segregation)
LN Class: PTUV

Attribute	Attr. Type	Explanation	T	X
Mod	INC_MOD	Mode		
Beh	INS_BEH	Behaviour		
Health	INS_HEALTH	Health		
NamPlt	LPL_LN	Name Plate		
Str	ACD_SEG	Start		

Attribute	Attr. Type	Explanation	T	X
Op	ACT_SEG	Operate	T	

4.33 Logical Node: RBRF_EXTTRIP

Description: Breaker Failure (w.r.t External Tripping)

LN Class: RBRF

Attribute	Attr. Type	Explanation	T	X
Mod	INC_MOD	Mode		
Beh	INS_BEH	Behaviour		
Health	INS_HEALTH	Health		
NamPlt	LPL_LN	Name Plate		
OpEx	ACT_NO_SEG	Breaker failure trip ("External trip")	T	

4.34 Logical Node: RDRE_BASIC

Description: Disturbance Recorder function (w.r.t Mandatory Attributes only)

LN Class: RDRE

Attribute	Attr. Type	Explanation	T	X
Mod	INC_MOD	Mode		
Beh	INS_BEH	Behaviour		
Health	INS_HEALTH	Health		
NamPlt	LPL_LN	Name Plate		
RcdMade	SPS_WD	Recording made		
FltNum	INS_BASIC	Fault number		

4.35 Logical Node: RFLO_PRIV_NDB

Description: Fault record values (including fault locator) without deadband and rangeC

LN Class: RFLO

Attribute	Attr. Type	Explanation	T	X
Mod	INC_MOD	Mode		
Beh	INS_BEH	Behaviour		
Health	INS_HEALTH	Health		
NamPlt	LPL_LN	Name Plate		
FltZ	CMV_MAG_FLOAT_NDB	Fault Impedance		
FltDiskm	MV_FLOAT_NDB	Fault Distance in km		
FltDismi	MV_FLOAT_D_NS_NDB	Fault Distance in mile		X
FltLoc	MV_FLOAT_D_NS_NDB	Fault location in percentage		X
FltPhs	INS_D_NS	Fault Phase		X
FltSt1U	INS_D_NS	Fault Start Element 1 upper bits		X
FltSt1L	INS_D_NS	Fault Start Element 1 lower bits		X
FltSt2U	INS_D_NS	Fault Start Element 2 upper bits		X
FltSt2L	INS_D_NS	Fault Start Element 2 lower bits		X
FltSt3U	INS_D_NS	Fault Start Element 3 upper bits		X
FltSt3L	INS_D_NS	Fault Start Element 3 lower bits		X
FltSt4U	INS_D_NS	Fault Start Element 4 upper bits		X
FltSt4L	INS_D_NS	Fault Start Element 4 lower bits		X
FltOp1U	INS_D_NS	Fault Trip Element 1 upper bits		X

Attribute	Attr. Type	Explanation	T	X
FltOp1L	INS_D_NS	Fault Trip Element 1 lower bits		X
FltOp2U	INS_D_NS	Fault Trip Element 2 Upper Bits		X
FltOp2L	INS_D_NS	Fault Trip Element 2 Lower bits		X
FltOp3U	INS_D_NS	Fault Trip Element 3 Upper bits		X
FltOp3L	INS_D_NS	Fault Trip Element 3 lower bits		X
FltOp4U	INS_D_NS	Fault Trip Element 4 upper bits		X
FltOp4L	INS_D_NS	Fault Trip Element 4 lower bits		X
FltAlmU	INS_D_NS	Fault Alarm Upper bits		X
FltAlmL	INS_D_NS	Fault Alarm Lower bits		X
FltTU	INS_D_NS	Fault Time Upper bits		X
FltTL	INS_D_NS	Fault Time Lower bits		X
FltTms	INS_D_NS	Fault Time ms		X
FltNum	INS_D	Total fault record number		
ActiveSG	INS_D_NS	Fault Record Active Group		X
FltHz	MV_FLOAT_D_NS_NDB	Fault Record Frequency		X
FltDur	MV_FLOAT_D_NS_NDB	Fault Record Duration		X
CBOpTm	MV_FLOAT_D_NS_NDB	Fault CB Operation Time		X
RlyOpTm	MV_FLOAT_D_NS_NDB	Fault Relay Operation Time		X
FltA	WYE_SEG_D_NS	Fault Phase Current		X
FltINMea	MV_FLOAT_D_NS_NDB	Fault IN Measured		X
FltINDer	MV_FLOAT_D_NS_NDB	Fault IN Derived		X
FltINSen	MV_FLOAT_D_NS_NDB	Fault IN Sensitive		X
FltIDiff	MV_FLOAT_D_NS_NDB	Fault IDiff		X
FltIBias	MV_FLOAT_D_NS_NDB	Fault IBias		X
FltPPV	DEL_SEG_D_NS	Fault Phase to Phase Voltage		X
FltPhV	WYE_SEG_D_NS	Fault Phase Voltage		X
FltVN	MV_FLOAT_D_NS_NDB	Fault Voltage VN Measured/Derived		X
SEFAdmit	MV_FLOAT_D_NS_NDB	Sensitive Neutral Admittance		X
SEFCond	MV_FLOAT_D_NS_NDB	Sensitive Neutral Conductance		X
SEFSusc	MV_FLOAT_D_NS_NDB	Sensitive Neutral Susceptance		X
EFAAdmit	MV_FLOAT_D_NS_NDB	Standard Neutral Admittance		X
EFCCond	MV_FLOAT_D_NS_NDB	Standard Neutral Conductance		X
EFSusc	MV_FLOAT_D_NS_NDB	Standard Neutral Susceptance		X

4.36 Logical Node: XCBR_BASIC

Description: Circuit Breaker (w.r.t Mandatory Attributes Only)

LN Class: XCBR

Attribute	Attr. Type	Explanation	T	X
Mod	INC_MOD	Mode		
Beh	INS_BEH	Behaviour		
Health	INS_HEALTH	Health		
NamPlt	LPL_LN	Name Plate		
Loc	SPS_WD	Local operation		
EEHealth	INS_HEALTH	External equipment health		
OpCnt	INS_BASIC	Operation counter		

Attribute	Attr. Type	Explanation	T	X
Pos	DPC_CTRL_PRV_NS	Switch position		
BlkOpn	SPC_STATUS	Block opening		
BlkCls	SPC_STATUS	Block closing		
CBOpCap	INS_CBCAP	Circuit Breaker operating capacity		
Lock	SPC_CTRL_PRV_NS	Prevention, i.e Lock, Trip/Close operations of the Circuit Breaker over IEC61850		X

5 Common Data Class Definitions

The definition tables for each of the Common Data Classes used in the Logical Node definitions are presented in the following sub-sections.

From an application point-of-view the data attributes of a Common Data Class are classified according to their specific use. The characterization of data attributes, and the services that they support/provide, will be through the use of 'Functional Constraints'. The Functional Constraints are specified by the table below:

FC Name	Semantic	Source Definition
BR	Buffered reports	IEC61850-7-2
CF	Configuration	IEC61850-7-2
CO	Control	IEC61850-7-2
DC	Description	IEC61850-7-2
EX	Extended Definition	IEC61850-7-2
GO	GOOSE Control	IEC61850-7-2
GS	GSSE Control (UCA2 GOOSE)	IEC61850-7-2
LG	Logging	IEC61850-7-2
MS	Multicast sampled value control	IEC61850-7-2
MX	Measurands (Analogue values)	IEC61850-7-2
RP	Unbuffered reports	IEC61850-7-2
SE	Setting Group Editable	IEC61850-7-2
SG	Setting Group	IEC61850-7-2
SP	Set Point	IEC61850-7-2
ST	Status Information	IEC61850-7-2
SV	Substitution Values	IEC61850-7-2
US	Unicast sampled value control	IEC61850-7-2
XX	Data attribute service parameters	IEC61850-7-2

5.1 Common Data Class: ACD_NEU

Description: Directional Protection Activation Information (w.r.t Neutral)
CDC Class: ACD

Attribute	Type	FC	Enumeration	Comment	X
general	BOOLEAN	ST		Trip or start has happened	
dirGeneral	ENUMERATED8 (MMS Type: INT8)	ST	dir	General direction (unknown, forward, backward or both)	
neut	BOOLEAN	ST		Trip or start event with earth current has happened	
dirNeut	ENUMERATED8 (MMS Type: INT8)	ST	dir	Earth current direction (unknown, forward or backward)	
q	Quality	ST		Quality of the protection activation information	
t	TimeStamp	ST		Timestamp of the last change in state of protection activation information	

5.2 Common Data Class: ACD_NO_SEG

Description: Directional Protection Activation Information (w,r,t No Phase Segregation)
CDC Class: ACD

Attribute	Type	FC	Enumeration	Comment	X
general	BOOLEAN	ST		Trip or start has happened	

Attribute	Type	FC	Enumeration	Comment	X
dirGeneral	ENUMERATED8 (MMS Type: INT8)	ST	dir	General direction (unknown, forward, backward or both)	
q	Quality	ST		Quality of the protection activation information	
t	TimeStamp	ST		Timestamp of the last change in state of protection activation information	

5.3 Common Data Class: ACD_SEG

Description: Directional Protection Activation Information (w.r.t Phase Segregation)
CDC Class: ACD

Attribute	Type	FC	Enumeration	Comment	X
general	BOOLEAN	ST		Trip or start has happened	
dirGeneral	ENUMERATED8 (MMS Type: INT8)	ST	dir	General direction (unknown, forward, backward or both)	
phsA	BOOLEAN	ST		Trip or start event of Phase A has happened	
dirPhsA	ENUMERATED8 (MMS Type: INT8)	ST	dir	Phase A direction (unknown, forward or backward)	
phsB	BOOLEAN	ST		Trip or start event of Phase B has happened	
dirPhsB	ENUMERATED8 (MMS Type: INT8)	ST	dir	Phase B direction (unknown, forward or backward)	
phsC	BOOLEAN	ST		Trip or start event of Phase C has happened	
dirPhsC	ENUMERATED8 (MMS Type: INT8)	ST	dir	Phase C direction (unknown, forward or backward)	
q	Quality	ST		Quality of the protection activation information	
t	TimeStamp	ST		Timestamp of the last change in state of protection activation information	

5.4 Common Data Class: ACT_NEU

Description: Protection Activation Information (w.r.t Neutral)
CDC Class: ACT

Attribute	Type	FC	Enumeration	Comment	X
general	BOOLEAN	ST		Trip or start has happened	
neut	BOOLEAN	ST		Trip or start event with earth current has happened	
q	Quality	ST		Quality of the protection activation information	
t	TimeStamp	ST		Timestamp of the last change in state of protection activation information	

5.5 Common Data Class: ACT_NO_SEG

Description: Protection Activation Information (w.r.t No Phase Segregation)
CDC Class: ACT

Attribute	Type	FC	Enumeration	Comment	X
general	BOOLEAN	ST		Trip or start has happened	
q	Quality	ST		Quality of the protection activation information	
t	TimeStamp	ST		Timestamp of the last change in state of protection activation information	

5.6 Common Data Class: ACT_SEG

Description: Protection Activation Information (w.r.t Phase Segregation)

CDC Class: ACT

Attribute	Type	FC	Enumeration	Comment	X
general	BOOLEAN	ST		Trip or start has happened	
phsA	BOOLEAN	ST		Trip or start event of Phase A has happened	
phsB	BOOLEAN	ST		Trip or start event of Phase B has happened	
phsC	BOOLEAN	ST		Trip or start event of Phase C has happened	
q	Quality	ST		Quality of the protection activation information	
t	TimeStamp	ST		Timestamp of the last change in state of protection activation information	

5.7 Common Data Class: BCR_PRIV

Description: Binary Counter Reading
 CDC Class: BCR

Attribute	Type	FC	Enumeration	Comment	X
actVal	INT32	ST		Binary counter status represented as an integer	
q	Quality	ST		Quality of counter value	
t	TimeStamp	ST		Time of last counter change	
pulsQty	FLOAT32	CF		Magnitude of the counted value 'per count' (value = actVal x pulsQty)	

5.8 Common Data Class: CMV_MAG_ANG_FLOAT

Description: Complex Measured value (w.r.t Floating Point Magnitude and Angle)
 CDC Class: CMV

Attribute	Type	FC	Enumeration	Comment	X
cVal	Vector_MagnitudeAngle_Float	MX		Deadbanded complex measured vector. Updated to the current value of instCVal when the value has changed according to the configuration parameter db.	
q	Quality	MX		Quality of the measurement value	
t	TimeStamp	MX		Time deadbanded magnitude last exceeded its db configuration parameter	
units	Unit_Multiplier	CF		Unit of the attribute representing the data	
db	INT32U	CF		Measurement deadband	
rangeC	RangeConfig_Deadband	CF		Measurement range configuration attributes	

5.9 Common Data Class: CMV_MAG_FLOAT

Description: Complex Measured value (w.r.t Floating Point Magnitude)
 CDC Class: CMV

Attribute	Type	FC	Enumeration	Comment	X
cVal	Vector_Magnitude_Float	MX		Deadbanded complex measured vector. Updated to the current value of instCVal when the value has changed according to the configuration parameter db.	
q	Quality	MX		Quality of the measurement value	
t	TimeStamp	MX		Time deadbanded magnitude last exceeded its db configuration parameter	
units	Unit_Multiplier	CF		Unit of the attribute representing the data	
db	INT32U	CF		Measurement deadband	
rangeC	RangeConfig_Deadband	CF		Measurement range configuration attributes	

5.10 Common Data Class: CMV_MAG_FLOAT_NDB

Description: Complex Measured value without db and rangeC
CDC Class: CMV

Attribute	Type	FC	Enumeration	Comment	X
cVal	Vector_Magnitude_Float	MX		Deadbanded complex measured vector. Updated to the current value of instCVal when the value has changed according to the configuration parameter db.	
q	Quality	MX		Quality of the measurement value	
t	TimeStamp	MX		Time deadbanded magnitude last exceeded its db configuration parameter	
units	Unit_Multiplier	CF		Unit of the attribute representing the data	
db	INT32U	CF		Measurement deadband	
rangeC	RangeConfig_Deadband	CF		Measurement range configuration attributes	

5.11 Common Data Class: DEL_SEG_ANG

Description: Phase to phase measurements for a 3-Phase system (w.r.t Phase Segregation + Angle)
CDC Class: DEL

Attribute	Type	FC	Enumeration	Comment	X
phsAB	CMV_MAG_ANG_FLOAT	--		Measurement values for Phase A to Phase B	
phsBC	CMV_MAG_ANG_FLOAT	--		Measurement values for Phase B to Phase C	
phsCA	CMV_MAG_ANG_FLOAT	--		Measurement values for Phase C to Phase A	

5.12 Common Data Class: DEL_SEG_D_NS

Description: Phase to phase measurements for a 3-Phase system
CDC Class: DEL

Attribute	Type	FC	Enumeration	Comment	X
phsAB	CMV_MAG_FLOAT_NDB	--		Measurement values for Phase A to Phase B	
phsBC	CMV_MAG_FLOAT_NDB	--		Measurement values for Phase B to Phase C	
phsCA	CMV_MAG_FLOAT_NDB	--		Measurement values for Phase C to Phase A	
d	VISIBLE_STRING255	DC		Description of the status element	
dataNs	VISIBLE_STRING255	EX		Data name space	

5.13 Common Data Class: DPC_CTRL_PRV_NS

Description: Controllable Double Point (NAME SPACE)
CDC Class: DPC

Attribute	Type	FC	Enumeration	Comment	X
ctlVal	BOOLEAN	CO		Control value (Off - FALSE, On - TRUE)	
origin	Originator	ST		Originator of the last change of the controllable data	
stVal	Dbpos	ST		Status value of the data (Intermediate state, Off, On or Bad-state)	
q	Quality	ST		Quality of the status value	
t	TimeStamp	ST		Timestamp of the last change in state of status value	
ctlModel	ENUMERATED8 (MMS Type: INT8)	CF	ctlModel	Control model (Corresponding to the behaviour of the data)	

Attribute	Type	FC	Enumeration	Comment	X
sboTimeout	INT32U	CF		Select Before Operate timeout period (in milliseconds)	
cdcNs	VISIBLE_STRING255	EX		Common Data Class name space	
cdcName	VISIBLE_STRING255	EX		Name of the Common Data Class	

5.14 Common Data Class: DPL_STANDARD

Description: Standard Device Name Plate
 CDC Class: DPL

Attribute	Type	FC	Enumeration	Comment	X
vendor	VISIBLE_STRING255	DC		Name of the vendor	
hwRev	VISIBLE_STRING255	DC		Hardware revision	
swRev	VISIBLE_STRING255	DC		Software revision	
serNum	VISIBLE_STRING255	DC		Serial Number	
model	VISIBLE_STRING255	DC		Model Number	
location	VISIBLE_STRING255	DC		Physical location of device	

5.15 Common Data Class: INC_CTRL_PRV_NS

Description: Controllable Integer Status NAME SPACE
 CDC Class: INC

Attribute	Type	FC	Enumeration	Comment	X
ctlVal	INT32	CO		Control value	
stVal	ENUMERATED8 (MMS Type: INT8)	ST	Mod	Status value of the data	
q	Quality	ST		Quality of the status value	
t	TimeStamp	ST		Timestamp of the last change in state of status value	
ctlModel	ENUMERATED8 (MMS Type: INT8)	CF	ctlModel	Control model (Corresponding to the behaviour of the data)	
cdcNs	VISIBLE_STRING255	EX		Common Data Class name space	
cdcName	VISIBLE_STRING255	EX		Name of the Common Data Class	
dataNs	VISIBLE_STRING255	EX		Data name space	

5.16 Common Data Class: INC_MOD

Description: Controllable Integer Status (w.r.t Mode)
 CDC Class: INC

Attribute	Type	FC	Enumeration	Comment	X
stVal	ENUMERATED8 (MMS Type: INT8)	ST	Mod	Status value of the data	
q	Quality	ST		Quality of the status value	
t	TimeStamp	ST		Timestamp of the last change in state of status value	
ctlModel	ENUMERATED8 (MMS Type: INT8)	CF	ctlModel	Control model (Corresponding to the behaviour of the data)	

5.17 Common Data Class: INS_BASIC

Description: Integer Status (w.r.t Mandatory Options Only)
 CDC Class: INS

Attribute	Type	FC	Enumeration	Comment	X
stVal	INT32	ST		The element status	
q	Quality	ST		The quality of the status value	
t	TimeStamp	ST		Timestamp of the last change in state	

5.18 Common Data Class: INS_BEH

Description: Integer Status (w.r.t Behaviour)

CDC Class: INS

Attribute	Type	FC	Enumeration	Comment	X
stVal	ENUMERATED8 (MMS Type: INT8)	ST	Beh	The element status	
q	Quality	ST		The quality of the status value	
t	TimeStamp	ST		Timestamp of the last change in state	

5.19 Common Data Class: INS_BEH_D_PRIV

Description: Integer Status (w.r.t Behaviour, with Description (Private DO))

CDC Class: INS

Attribute	Type	FC	Enumeration	Comment	X
stVal	ENUMERATED8 (MMS Type: INT8)	ST	Beh	The element status	
q	Quality	ST		The quality of the status value	
t	TimeStamp	ST		Timestamp of the last change in state	
d	VISIBLE_STRING255	DC		Description of the status element	
dataNs	VISIBLE_STRING255	EX		Data name space	

5.20 Common Data Class: INS_CBCAP

Description: Integer Status(w.r.t Circuit Breaker Operating)

CDC Class: INS

Attribute	Type	FC	Enumeration	Comment	X
stVal	INT32 (MMS Type: INT8)	ST	CBOpCap	The element status	
q	Quality	ST		The quality of the status value	
t	TimeStamp	ST		Timestamp of the last change in state	

5.21 Common Data Class: INS_D

Description: Integer Status

CDC Class: INS

Attribute	Type	FC	Enumeration	Comment	X
stVal	INT32	ST		The element status	
q	Quality	ST		The quality of the status value	
t	TimeStamp	ST		Timestamp of the last change in state	
d	VISIBLE_STRING255	DC		Description of the status element	

5.22 Common Data Class: INS_D_NS

Description: Integer Status

CDC Class: INS

Attribute	Type	FC	Enumeration	Comment	X
stVal	INT32	ST		The element status	
q	Quality	ST		The quality of the status value	
t	TimeStamp	ST		Timestamp of the last change in state	
d	VISIBLE_STRING255	DC		Description of the status element	
dataNs	VISIBLE_STRING255	EX		Data name space	

5.23 Common Data Class: INS_HEALTH

Description: Integer Status (w.r.t health)

CDC Class: INS

Attribute	Type	FC	Enumeration	Comment	X
stVal	INT32 (MMS Type: INT8)	ST	Health	The element status	
q	Quality	ST		The quality of the status value	
t	TimeStamp	ST		Timestamp of the last change in state	

5.24 Common Data Class: LPL_LLNO

Description: Logical Node 0 Name Plate

CDC Class: LPL

Attribute	Type	FC	Enumeration	Comment	X
vendor	VISIBLE_STRING255	DC		Name of the vendor	
swRev	VISIBLE_STRING255	DC		Software revision	
d	VISIBLE_STRING255	DC		Description	
configRev	VISIBLE_STRING255	DC		Uniquely identifies the configuration of a local device instance	
ldNs	VISIBLE_STRING255	EX		Logical Device name space	

5.25 Common Data Class: LPL_LN

Description: Standard Logical Node Name Plate

CDC Class: LPL

Attribute	Type	FC	Enumeration	Comment	X
vendor	VISIBLE_STRING255	DC		Name of the vendor	
swRev	VISIBLE_STRING255	DC		Software revision	
d	VISIBLE_STRING255	DC		Description	

5.26 Common Data Class: MV_FLOAT

Description: Measured value (w.r.t. Floating Point value)

CDC Class: MV

Attribute	Type	FC	Enumeration	Comment	X
mag	AnalogueValue_Float	MX		Deadbanded magnitude of the instantaneous value of a measured value or harmonic value. Updated to the current value of instMag when the value has changed according to the configuration parameter db.	
q	Quality	MX		Quality of the measurement value	
t	TimeStamp	MX		Time deadbanded magnitude last exceeded its db configuration parameter	
units	Unit_Multiplier	CF		Unit of the attribute representing the data	

Attribute	Type	FC	Enumeration	Comment	X
db	INT32U	CF		Measurement deadband	
rangeC	RangeConfig_Deadband	CF		Measurement range configuration attributes	

5.27 Common Data Class: MV_FLOAT_D

Description: Measured value (w.r.t Floating Point Value with Description)

CDC Class: MV

Attribute	Type	FC	Enumeration	Comment	X
mag	AnalogueValue_Float	MX		Deadbanded magnitude of the instantaneous value of a measured value or harmonic value. Updated to the current value of instMag when the value has changed according to the configuration parameter db.	
q	Quality	MX		Quality of the measurement value	
t	TimeStamp	MX		Time deadbanded magnitude last exceeded its db configuration parameter	
units	Unit_Multiplier	CF		Unit of the attribute representing the data	
db	INT32U	CF		Measurement deadband	
rangeC	RangeConfig_Deadband	CF		Measurement range configuration attributes	
d	VISIBLE_STRING255	DC		Description of the status element	

5.28 Common Data Class: MV_FLOAT_D_NS

Description: Measured value with namespace

CDC Class: MV

Attribute	Type	FC	Enumeration	Comment	X
mag	AnalogueValue_Float	MX		Deadbanded magnitude of the instantaneous value of a measured value or harmonic value. Updated to the current value of instMag when the value has changed according to the configuration parameter db.	
q	Quality	MX		Quality of the measurement value	
t	TimeStamp	MX		Time deadbanded magnitude last exceeded its db configuration parameter	
units	Unit	CF		Unit of the attribute representing the data	
db	INT32U	CF		Measurement deadband	
rangeC	RangeConfig_Deadband	CF		Measurement range configuration attributes	
d	VISIBLE_STRING255	DC		Description of the status element	
dataNs	VISIBLE_STRING255	EX		Data name space	

5.29 Common Data Class: MV_FLOAT_D_NS_NDB

Description: Measured value without deadband and rangeC

CDC Class: MV

Attribute	Type	FC	Enumeration	Comment	X
mag	AnalogueValue_Float	MX		Deadbanded magnitude of the instantaneous value of a measured value or harmonic value. Updated to the current value of instMag when the value has changed according to the configuration parameter db.	
q	Quality	MX		Quality of the measurement value	
t	TimeStamp	MX		Time deadbanded magnitude last exceeded its db configuration parameter	

Attribute	Type	FC	Enumeration	Comment	X
db	INT32U	CF		Measurement deadband	
units	Unit	CF		Unit of the attribute representing the data	
rangeC	RangeConfig_Deadband	CF		Measurement range configuration attributes	
d	VISIBLE_STRING255	DC		Description of the status element	
dataNs	VISIBLE_STRING255	EX		Data name space	

5.30 Common Data Class: MV_FLOAT_NDB

Description: Measured value without deadband and rangeC

CDC Class: MV

Attribute	Type	FC	Enumeration	Comment	X
mag	AnalogueValue_Float	MX		Deadbanded magnitude of the instantaneous value of a measured value or harmonic value. Updated to the current value of instMag when the value has changed according to the configuration parameter db.	
q	Quality	MX		Quality of the measurement value	
t	TimeStamp	MX		Time deadbanded magnitude last exceeded its db configuration parameter	
units	Unit_Multiplier	CF		Unit of the attribute representing the data	
db	INT32U	CF		Measurement deadband	
rangeC	RangeConfig_Deadband	CF		Measurement range configuration attributes	

5.31 Common Data Class: MV_FLOAT_NS

Description: Measured value with NS

CDC Class: MV

Attribute	Type	FC	Enumeration	Comment	X
mag	AnalogueValue_Float	MX		Deadbanded magnitude of the instantaneous value of a measured value or harmonic value. Updated to the current value of instMag when the value has changed according to the configuration parameter db.	
q	Quality	MX		Quality of the measurement value	
t	TimeStamp	MX		Time deadbanded magnitude last exceeded its db configuration parameter	
units	Unit	CF		Unit of the attribute representing the data	
db	INT32U	CF		Measurement deadband	
rangeC	RangeConfig_Deadband	CF		Measurement range configuration attributes	
dataNs	VISIBLE_STRING255	EX		Data name space	

5.32 Common Data Class: SEQ_MAG_ANG

Description: Sequence components of a measurement value (w.r.t Magnitudes + Angles)

CDC Class: SEQ

Attribute	Type	FC	Enumeration	Comment	X
c1	CMV_MAG_ANG_FLOAT	--		Sequence component 1 (For semantic meaning see seqT)	
c2	CMV_MAG_ANG_FLOAT	--		Sequence component 2 (For semantic meaning see seqT)	
c3	CMV_MAG_ANG_FLOAT	--		Sequence component 3 (For semantic meaning see seqT)	

Attribute	Type	FC	Enumeration	Comment	X
seqT	ENUMERATED8 (MMS Type: INT8)	MX	seqT	Sequence quantity measurement type (Pos-Neg-Zero or Dir-Quad-Zero)	

5.33 Common Data Class: SPC_CONTROL_NS

Description: Controllable Single Point (NAME SPACE)

CDC Class: SPC

Attribute	Type	FC	Enumeration	Comment	X
ctlVal	BOOLEAN	CO		Control value (Off - FALSE, On - TRUE)	
origin	Originator	ST		Originator of the last change of the controllable data	
stVal	BOOLEAN	ST		Status value of the data	
q	Quality	ST		Quality of the status value	
t	TimeStamp	ST		Timestamp of the last change in state of status value	
ctlModel	ENUMERATED8 (MMS Type: INT8)	CF	ctlModel	Control model (Corresponding to the behaviour of the data)	
sboTimeout	INT32U	CF		Select Before Operate timeout period (in milliseconds)	
cdcNs	VISIBLE_STRING255	EX		Common Data Class name space	
cdcName	VISIBLE_STRING255	EX		Name of the Common Data Class	

5.34 Common Data Class: SPC_CTRL_PRV_NS

Description: Controllable Single Point (NAME SPACE)

CDC Class: SPC

Attribute	Type	FC	Enumeration	Comment	X
ctlVal	BOOLEAN	CO		Control value (Off - FALSE, On - TRUE)	
origin	Originator	ST		Originator of the last change of the controllable data	
stVal	BOOLEAN	ST		Status value of the data	
q	Quality	ST		Quality of the status value	
t	TimeStamp	ST		Timestamp of the last change in state of status value	
ctlModel	ENUMERATED8 (MMS Type: INT8)	CF	ctlModel	Control model (Corresponding to the behaviour of the data)	
sboTimeout	INT32U	CF		Select Before Operate timeout period (in milliseconds)	
cdcNs	VISIBLE_STRING255	EX		Common Data Class name space	
cdcName	VISIBLE_STRING255	EX		Name of the Common Data Class	
dataNs	VISIBLE_STRING255	EX		Data name space	

5.35 Common Data Class: SPC_STATUS

Description: Controllable Single Point (w.r.t Status Only)

CDC Class: SPC

Attribute	Type	FC	Enumeration	Comment	X
stVal	BOOLEAN	ST		Status value of the data	
q	Quality	ST		Quality of the status value	
t	TimeStamp	ST		Timestamp of the last change in state of status value	

Attribute	Type	FC	Enumeration	Comment	X
ctlModel	ENUMERATED8 (MMS Type: INT8)	CF	ctlModel	Control model (Corresponding to the behaviour of the data)	

5.36 Common Data Class: SPS_D

Description: Standard Single Point Status (with Description)

CDC Class: SPS

Attribute	Type	FC	Enumeration	Comment	X
stVal	BOOLEAN	ST		The element status (TRUE or FALSE)	
q	Quality	ST		The quality of the status value	
t	TimeStamp	ST		Timestamp of the last change in state	
d	VISIBLE_STRING255	DC		Description of the status element	

5.37 Common Data Class: SPS_WD

Description: Single Point Status (without Description)

CDC Class: SPS

Attribute	Type	FC	Enumeration	Comment	X
stVal	BOOLEAN	ST		The element status (TRUE or FALSE)	
q	Quality	ST		The quality of the status value	
t	TimeStamp	ST		Timestamp of the last change in state	

5.38 Common Data Class: SPS_WD_PRIV

Description: Single Point Status (without Description with Name Space)

CDC Class: SPS

Attribute	Type	FC	Enumeration	Comment	X
stVal	BOOLEAN	ST		The element status (TRUE or FALSE)	
q	Quality	ST		The quality of the status value	
t	TimeStamp	ST		Timestamp of the last change in state	
dataNs	VISIBLE_STRING255	EX		Data name space	

5.39 Common Data Class: WYE_INET

Description: Phase to ground measurements for a 3-Phase system (w.r.t Net Current)

CDC Class: WYE

Attribute	Type	FC	Enumeration	Comment	X
net	CMV_MAG_FLOAT	--		Measurement values for the net (sum of all phases) system current	

5.40 Common Data Class: WYE_RES_ANG_NS

Description: Phase to ground measurements for a 3-Phase system

CDC Class: WYE

Attribute	Type	FC	Enumeration	Comment	X
res	CMV_MAG_ANG_FLOAT	--		Measurement values for the residual system current	
d	VISIBLE_STRING255	DC		Description of the status element	
dataNs	VISIBLE_STRING255	EX		Data name space	

5.41 Common Data Class: WYE_SEG

Description: Phase to ground measurements for a 3-Phase system (w.r.t Phase Segregation)

CDC Class: WYE

Attribute	Type	FC	Enumeration	Comment	X
phsA	CMV_MAG_FLOAT	--		Measurement values for Phase A	
phsB	CMV_MAG_FLOAT	--		Measurement values for Phase B	
phsC	CMV_MAG_FLOAT	--		Measurement values for Phase C	

5.42 Common Data Class: WYE_SEG_D

Description: Phase to ground measurements for a 3-Phase system (w.r.t Phase Segregation + Description)

CDC Class: WYE

Attribute	Type	FC	Enumeration	Comment	X
phsA	CMV_MAG_FLOAT	--		Measurement values for Phase A	
phsB	CMV_MAG_FLOAT	--		Measurement values for Phase B	
phsC	CMV_MAG_FLOAT	--		Measurement values for Phase C	
d	VISIBLE_STRING255	DC		Description of the status element	

5.43 Common Data Class: WYE_SEG_D_NS

Description: Phase to ground measurements for a 3-Phase system

CDC Class: WYE

Attribute	Type	FC	Enumeration	Comment	X
phsA	CMV_MAG_FLOAT_NDB	--		Measurement values for Phase A	
phsB	CMV_MAG_FLOAT_NDB	--		Measurement values for Phase B	
phsC	CMV_MAG_FLOAT_NDB	--		Measurement values for Phase C	
d	VISIBLE_STRING255	DC		Description of the status element	
dataNs	VISIBLE_STRING255	EX		Data name space	

5.44 Common Data Class: WYE_SEG_RES_D

Description: Phase to ground measurements for a 3-Phase system (w.r.t Phase Segregation + Residual + Description)

CDC Class: WYE

Attribute	Type	FC	Enumeration	Comment	X
phsA	CMV_MAG_ANG_FLOAT	--		Measurement values for Phase A	
phsB	CMV_MAG_ANG_FLOAT	--		Measurement values for Phase B	
phsC	CMV_MAG_ANG_FLOAT	--		Measurement values for Phase C	
neut	CMV_MAG_ANG_FLOAT	--		Measurement values for neutral input	
d	VISIBLE_STRING255	DC		Description of the status element	

5.45 Common Data Class: WYE_SEG_RES_NS

Description: Phase to ground measurements for a 3-Phase system

CDC Class: WYE

Attribute	Type	FC	Enumeration	Comment	X
phsA	CMV_MAG_ANG_FLOAT	--		Measurement values for Phase A	
phsB	CMV_MAG_ANG_FLOAT	--		Measurement values for Phase B	
phsC	CMV_MAG_ANG_FLOAT	--		Measurement values for Phase C	

Attribute	Type	FC	Enumeration	Comment	X
neut	CMV_MAG_ANG_FLOAT	--		Measurement values for neutral input	
d	VISIBLE_STRING255	DC		Description of the status element	
dataNs	VISIBLE_STRING255	EX		Data name space	

6 Common Data Attribute Type Definitions

Common data attribute types, known herein as components, are defined for use in the Common Data Classes defined in the sections above.

6.1 Component: AnalogueValue_Float

Comment: General analogue value (w.r.t Floating Point value)

Parent Type: AnalogueValue

Attribute	Type	Enumeration	Comment	X
f	FLOAT32		Floating point value	

6.2 Component: Originator

Comment: Originator of the last change of data attribute representing the value of a controllable data object

Parent Type:

Attribute	Type	Enumeration	Comment	X
orCat	ENUMERATED8 (MMS Type: INT8)	orCategory	Originator category (Not-supported, bay-control, station-control, remote-control, automatic-bay, automatic-station, automatic-remote, maintenance or process)	
orIdent	OCTET_STRING64		Originator identification (Null value indicates unknown or not reported)	

6.3 Component: RangeConfig_Deadband

Comment: Measurement range configuration

Parent Type: RangeConfig

Attribute	Type	Enumeration	Comment	X
min	AnalogueValue_Float		Minimum process measurement for which values of i and f are considered within limits	
hhLim	AnalogueValue_Float		High High range limit	
hLim	AnalogueValue_Float		High range limit	
lLim	AnalogueValue_Float		Low range limit	
max	AnalogueValue_Float		Maximum process measurement for which values of i and f are considered within limits	
llLim	AnalogueValue_Float		Low Low range limit	

6.4 Component: Unit

Comment: SI Unit definitions

Parent Type:

Attribute	Type	Enumeration	Comment	X
multiplier	ENUMERATED8 (MMS Type: INT8)	multiplier	Multiplier value, the default of which is 0 (i.e. multiplier = 1)	
SIUnit	ENUMERATED8 (MMS Type: INT8)	SIUnit	SI Unit	

6.5 Component: Unit_Multiplier

Comment: SI Unit definitions

Parent Type: Unit

Attribute	Type	Enumeration	Comment	X
multiplier	ENUMERATED8 (MMS Type: INT8)	multiplier	Multiplier value, the default of which is 0 (i.e. multiplier = 1)	
SIUnit	ENUMERATED8 (MMS Type: INT8)	SIUnit	SI Unit	

6.6 Component: Vector_Magnitude_Float

Comment: Complex vector (w.r.t Floating Point Magnitude value)

Parent Type: Vector

Attribute	Type	Enumeration	Comment	X
mag	AnalogueValue_Float		The magnitude of the complex value	

6.7 Component: Vector_MagnitudeAngle_Float

Comment: Complex vector (w.r.t Floating Point Magnitude and Angle values)

Parent Type: Vector

Attribute	Type	Enumeration	Comment	X
mag	AnalogueValue_Float		The magnitude of the complex value	
ang	AnalogueValue_Float		The angle of the complex value (the unit is degrees)	

7 Enumerated Type Definitions

The following sub-sections specify the enumerations that are associated to some Common Data Class attributes. The definition of the enumerations are according to IEC61850-7-3 and IEC61850-7-4 unless otherwise stated.

7.1 Enumerated type: AddCause

Description: AddCause

Ordinal	Semantic
0	Unknown
1	Not-supported
2	Blocked-by-switching-hierarchy
3	Select-failed
4	Invalid-position
5	Position-reached
6	Parameter-change-in-execution
7	Step-limit
8	Blocked-by-Mode
9	Blocked-by-process
10	Blocked-by-interlocking
11	Blocked-by-synchrocheck
12	Command-already-in-execution
13	Blocked-by-health
14	1-of-n-control
15	Abortion-by-cancel
16	Time-limit-over
17	Abortion-by-trip
18	Object-not-selected

7.2 Enumerated type: Beh

Description: Behaviour

Ordinal	Semantic
1	on
2	blocked
3	test
4	test/blocked
5	off

7.3 Enumerated type: Bypass

Description: Bypass

Ordinal	Semantic
0	locking-bypass
1	mode-bypass
2	automation-bypass
3	uniqueness-bypass
4	select-bypass

Ordinal	Semantic
5	status-bypass

7.4 Enumerated type: CBOpCap

Description: Enumeration for CB Operation

Ordinal	Semantic
1	None
2	Open
3	Close-Open
4	Open-Close-Open
5	Close-Open-Close-Open

7.5 Enumerated type: ctlModel

Description: Control Model

Ordinal	Semantic
0	status-only
1	direct-with-normal-security
2	sbo-with-normal-security
3	direct-with-enhanced-security
4	sbo-with-enhanced-security

7.6 Enumerated type: dir

Description: Direction

Ordinal	Semantic
0	unknown
1	forward
2	backward
3	both

7.7 Enumerated type: Health

Description: Health

Ordinal	Semantic
1	Ok
2	Warning
3	Alarm

7.8 Enumerated type: Mod

Description: Mode

Ordinal	Semantic
1	on
2	blocked
3	test
4	test/blocked
5	off

7.9 Enumerated type: multiplier

Description: Exponents of the multiplier value in base 10.

Ordinal	Semantic
-24	y
-21	z
-18	a
-15	f
-12	p
-9	n
-6	μ
-3	m
-2	c
-1	d
0	
1	da
2	h
3	k
6	M
9	G
12	T
15	P
18	E
21	Z
24	Y

7.10 Enumerated type: orCategory

Description: orCategory

Ordinal	Semantic
0	not-supported
1	bay-control
2	station-control
3	remote-control
4	automatic-bay
5	automatic-station
6	automatic-remote
7	maintenance
8	process

7.11 Enumerated type: seqT

Description: Sequence Measurement Type

Ordinal	Semantic
0	pos-neg-zero
1	dir-quad-zero

7.12 Enumerated type: SIUnit

Description: SI Units derived from ISO/IEC 1000

Ordinal	Semantic
-16	years
-15	months
-14	weeks
-13	V/s
-12	mins
-11	hours
-10	days
-9	°F
-8	ratio
-7	miles
-6	inches
-5	feet
-4	df/dt
-3	Hz/s
-2	%
-1	pu
1	none
2	m
3	kg
4	s
5	A
6	K
7	mol
8	cd
9	deg
10	rad
11	sr
21	Gy
22	q
23	°C
24	Sv
25	F
26	C
27	S
28	H
29	V
30	ohm
31	J
32	N
33	Hz
34	lx
35	Lm
36	Wb
37	T

Ordinal	Semantic
38	W
39	Pa
41	m ²
42	m ³
43	m/s
44	m/s ²
45	m ³ /s
46	m/m ³
47	M
48	kg/m ³
49	m ² /s
50	W/m K
51	J/K
52	ppm
53	1/s
54	rad/s
61	VA
62	Watts
63	VAr
64	phi
65	cos(phi)
66	Vs
67	V ²
68	As
69	A ²
70	A ² t
71	VAh
72	Wh
73	VArh
74	V/Hz

8 MMS Data-Type Conversions

The following table shows the relationships between the Part 7 and Part 8-1 data types. The definitions presented above use Part 7 data types, however these are subject to 'translation' when exposed over an MMS (Part 8-1) interface:

Part 7 Type	MMS Type	Part 7 Description
BOOLEAN	Bool	Logical TRUE/FALSE value
BSTR16	Bstring16	Bit-string -16 bits
BVstring13	BVstring13	Variable bit string (upto 13 bits)
Check	BVstring2	Control Object check flags
CODED_ENUM	Byte	Coded enumeration
CODED_ENUM2	Byte	Coded enumeration (2)
Dbpos	Bstring2	Switch positions
EntryTime	Btime6	8.1 Section 8.1.3.7
ENUMERATED16	Short	16 bit enumerated value
ENUMERATED8	Byte	8 bit enumerated value
FLOAT32	Float	32 bit floating point value
FLOAT64	Double	64 bit floating point value
INT16	Short	16 bit signed integer value
INT16U	Ushort	16 bit unsigned integer value
INT24U	Ulong	24 bit unsigned integer value
INT32	Long	32 bit signed integer value
INT32U	Ulong	32 bit unsigned integer value
INT64	Int64	64 bit signed integer value
INT8	Byte	8 bit signed integer value
INT8U	Ubyte	8 bit unsigned integer value
OCTET_STRING6	Ostring6	6 character string (8 bits per character)
OCTET_STRING64	OVstring64	64 character string (8 bits per character)
OCTET_STRING8	OVstring8	8 character string (8 bits per character)
Quality	BVstring13	IEC61850 Quality
TimeStamp	Utctime	IEC61850 Time stamp
UNICODE_STRING255	UTF8Vstring255	255 character string (16 bits per unicode character)
UTC_TM	Utctime	UTC Timestamp
VISIBLE_STRING255	Vstring255	255 character string
VISIBLE_STRING64	Vstring64	64 character string
VISIBLE_STRING65	Vstring65	65 character string
VISIBLE_STRING97	Vstring97	97 character string



Customer Care Centre

<http://www.schneider-electric.com/cc>

Schneider Electric

35 rue Joseph Monier
92506 Rueil-Malmaison
FRANCE

Phone: +33 (0) 1 41 29 70 00
Fax: +33 (0) 1 41 29 71 00

www.schneider-electric.com

Publisher: Schneider Electric

**Publication: Easergy MiCOM P141/EN MC/On8 Feeder Management Relay Software Version: B6 Hardware Suffix: L
IEC61850 Edition: 1**

07/2020