

 **DANGER**

**HAZARD OF ELECTRIC SHOCK, EXPLOSION OR ARC FLASH**

- Inspect and perform preventive maintenance only on switchgear and equipment to which power has been turned to the OFF position, disconnected, and electrically isolated (unless otherwise specified) so that no accidental contact can be made with energized parts.
- Follow safety related work practices as described in NFPA 70E - Standard for Electrical Safety Requirements for Employee Workplaces and OSHA Standards - 29 CFR Part 1910 Subpart S - Electrical.

**Failure to follow these instructions will result in death or serious injury.**

**NOTICE**

**CONTAMINATION HAZARD**

- Do not use an air hose to blow out the switchgear. The dust may settle inside relays and overcurrent devices, causing overheating and improper operation.
- Do not allow paint, chemicals, or petroleumbased solvents to contact plastics or insulating materials.

**Failure to follow these instructions can result in equipment damage.**